



Via Personal Delivery & E-Filing

Jan Sanders, Secretary
Arkansas Public Service Commission
1000 Center Street
PO Box 400
Little Rock, AR 72203

March 14, 2013

Re: PSC Docket No. 12-008-U – HSPI Second Supplemental Rebuttal Testimony and Exhibit of Paul Chernick on Behalf of the Sierra Club

Dear Ms. Sanders:

Please find enclosed an original and three copies of the HSPI/Confidential Second Supplemental Rebuttal Testimony of Paul Chernick and Confidential Exhibit PC-F7 on behalf of the Sierra Club in Docket No. 12-008-U to be filed under seal in this docket pursuant to Protective Order No. 1. Redacted versions of these documents, as well as public Sierra Club exhibits, have been submitted through the Electronic Filing System on this day.

Please let me know if you need any additional documents from me or if you have any questions. Thank you.

Sincerely,

/s/ Derek Nelson

Derek Nelson
Program Assistant
Sierra Club Environmental Law Program
85 Second Street, Second floor
San Francisco, CA 94105
(415) 977-5595
derek.nelson@sierraclub.org

TABLE OF CONTENTS

I.	Introduction.....	1
II.	Deadlines for the Shutdown of Flint Creek	6
III.	Timeline for Replacement Generation.....	15
	A. The Louisiana Market-Based Mechanism.....	16
	B. Firm Transmission Service.....	18
IV.	Timeline for Constructing Transmission to Northwest Arkansas	21
V.	Operating Without Flint Creek and Major Replacements	24
	A. Transmission Issues.....	24
	B. Short-term Local Alternatives	34

TABLE OF EXHIBITS

Exhibit PC-F1	<i>Non-Confidential Discovery Responses Cited in This Testimony</i>
Exhibit PC-F2	<i>Excerpts from AECC 2010-2012 Financial Statements</i>
Exhibit PC-F3	<i>EPA Enforcement Response Policy For Electric Reliability and MATS</i>
Exhibit PC-F4	<i>FERC Policy Statement on MATS</i>
Exhibit PC-F5	<i>Louisiana PSC Staff Report in Docket R-26172-C (2008)</i>
Exhibit PC-F6	<i>SPP 2012 EIA-411 Demand and Capacity Report</i>
Exhibit PC-F7	<i>CONFIDENTIAL Email from Erin Cullum, SPP, to Casey Roberts, Sierra Club, February 25, 2013</i>
Exhibit PC-F8	<i>2012 Transmission Planning Reliability Criteria for the AEP-SPP</i>

1 **I. Introduction**

2 **Q: Are you the same Paul Chernick who filed direct and rebuttal testimony in**
3 **this docket?**

4 A: Yes.

5 **Q: To which testimony will you be responding?**

6 A: I respond to aspects of the January 11, 2013 direct testimony of SWEPCo
7 witnesses Venita McCellon-Allen and Lanny Nickell, filed pursuant to Commis-
8 sion Order No. 10.¹

9 **Q: How does SWEPCo's evidence in this new round of testimony differ from**
10 **its sur-surrebuttal testimony?**

11 A: This new evidence adds very little substance to the record, mostly repeating
12 claims that SWEPCo made earlier in the process. The major change is that
13 SWEPCo has abandoned any technical claim that transmission would be
14 insufficient to serve northwest Arkansas. The new testimony focuses on three
15 claims:

- 16 • In the absence of the environmental retrofit projects that are the subject of
17 this proceeding, Flint Creek would need to shut down by April 2015.
18 • Building transmission to serve northwest Arkansas would take some years
19 beyond 2015, during which time reliability in northwest Arkansas would
20 be very poor.

¹This direct testimony was filed eleven months after the rest of the utilities' direct testimony. The utilities requested the opportunity to supplement the record following the close of the record and submission of briefs.

- 1 • Purchasing generation resources to replace Flint Creek would take several
2 years, during which time SWEPCo, PSO and other utilities in the AEP
3 sub-region would suffer some sort of consequences.

4 **Q: How has SWEPCo’s position changed over time regarding the role of**
5 **transmission into northwest Arkansas as an alternative to Flint Creek?**

6 A: During this proceeding SWEPCo has taken several different positions:

- 7 • In Hassink Direct at 8, SWEPCo presented a greenfield combined-cycle
8 plant combined with new transmission, capacitor banks, and VAR com-
9 pensators in northwest Arkansas as a viable alternative to Flint Creek as
10 early as March 2016.² SWEPCo’s economic analyses assumed that the line
11 would be required only if Flint Creek were retired and no new generation
12 was built in northwest Arkansas.
- 13 • In rebuttal, SWEPCo Witness Bennett took the position that regardless of
14 the fate of Flint Creek, “enhancing the transmission system is a must” for
15 northwest Arkansas (Bennett Rebuttal at 30).
- 16 • In SWEPCo’s sur-surrebuttal testimony, Witness Hassink continued to
17 present transmission as a viable alternative to Flint Creek, although he
18 pointed out that transmission energy losses would tend to be higher with
19 expanded transmission rather than generation in northwest Arkansas.
20 Witness Hassink raised the concern that studying, permitting, and
21 constructing new transmission would require four to seven years if the
22 various pre-construction activities were undertaken sequentially (Hassink
23 Sur-Surrebuttal at 5), which Witness Bennett restated as five to seven
24 years (Bennett Sur-Surrebuttal at 8). Witness Bennett (Sur-Surrebuttal at

²Specifically, a 70-mile 345-kV line from Fort Smith to Chamber Springs, plus 100 MVAR of static VAR compensators and 170 MVAR of conventional capacitor banks and reactors.

1 7) also asserted that Mr. Hassink’s sur-surrebuttal testimony showed that
2 “a transmission system solution alone cannot solve the immediate issue at
3 hand,” even though Mr. Hassink’s testimony does not make any such
4 demonstration.³

- 5 • In its January 2013 testimony, SWEPCo drops the claim that transmission
6 would not be adequate to serve northwest Arkansas for the long-term.
7 Instead the Company asserts that there would be short-term reliability
8 issues while the transmission upgrades are being put in place.

9 **Q: What topics will you address in this rebuttal?**

10 A: I respond to the following three topics discussed at length in SWEPCo’s January
11 11, 2013, testimony:

- 12 • the deadline for shutting down Flint Creek if it is not retrofitted to comply
13 with the EPA’s Mercury and Air Toxics Standards (MATS).
- 14 • the timeline for bringing new transmission and generation resources on to
15 replace Flint Creek.
- 16 • the implications of operating without Flint Creek, prior to construction of
17 new generation and transmission resources.

18 I do not respond to the less-substantive testimony of SWEPCo witness
19 Mike Malone (who simply repeats concerns about reliability based on other
20 witnesses’ testimony) and AECC witness Duane Highley (who primarily
21 discusses AECC’s lack of interest in co-owning Flint Creek if it is converted to

³The transmission witness for AECC asserted that no amount of transmission into northwest Arkansas would be adequate without baseload generation in northwest Arkansas (Bittle Sur-Surrebuttal at 5), although its witness later admitted that his difference of opinion with SWEPCo’s transmission witness, Mr. Hassink, was merely “philosophical” (Tr. 1672:6-18).

1 gas). Witness Highley also estimates that retirement of Flint Creek would
2 require AECC to

3 record any remaining net plant value as a loss on its income statement. If
4 Flint Creek were abandoned today, the loss would be more than \$25
5 million. The loss will either result in a decrease in AECC's member
6 cooperative's equity or will have to be recovered in future increased rates"
7 (Highley Direct at 5).⁴

8 Mr. Highley does not mention that AECC's member equity was \$512
9 million in October 2012, and has been growing over the years (from \$495
10 million in October 2011, \$460 in October 2010, and \$434 million in 2009)
11 (AECC 2012 Financial Statements at 3; 2010 Annual Report at 5. These docu-
12 ments attached as Exhibit PC-F2). If that trend continues, the write-off of Flint
13 Creek would slow, but not eliminate, the increase in equity in the year.

14 **Q: What are your conclusions?**

15 A: My most important conclusion is that SWEPCo is incorrect when it claims that
16 rejection of the Flint Creek controls package would require the plant to be
17 retired by April 2015. The EPA is highly unlikely to require the retirement of
18 Flint Creek so long as it is needed for reliability and SWEPCo is working on
19 replacement resources. Hence, all of SWEPCo's other projections of the effects
20 of that retirement on reliability are irrelevant.

21 In addition, SWEPCo has overstated the following concerns:

- 22 • the time required for planning and building new transmission to serve
23 northwest Arkansas.

⁴Depreciation on AECC's portion of Flint Creek is 3.1% of the gross investment of \$108 million (Exhibit PC-F2, AECC 2012 Financial Statements at 8), or over \$3 million annually, so much of the remaining investment would be depreciated by the time Flint Creek would be retired around 2017.

- 1 • the problems involved in purchasing existing generation resources and
2 obtaining transmission rights between those resources and the AEP region,
3 • the problems that would arise if northwest Arkansas were to operate
4 without Flint Creek (due to retirement or forced outage) prior to com-
5 pletion of a new transmission line.

6 In short, SWEPCo has not demonstrated that retiring Flint Creek and
7 replacing it with existing combined-cycle capacity and (if necessary) new
8 transmission into northwest Arkansas is not feasible.

9 **Q: What exhibits do you attach to this testimony?**

10 A: I have attached eight exhibits, which provide the following information:

- 11 • the EPA's position on extending MATS compliance deadlines for
12 generators essential to reliability.
13 • the FERC's position on reviewing reliability in support of the EPA's
14 determinations of need.
15 • an email from SPP that provided informal responses to certain of Sierra
16 Club's formal discovery.
17 • financial data from AECC.
18 • a Louisiana PSC Staff Report on the operation of the Market-Based
19 Mechanism.
20 • excerpts from the SPP's 2012 For EIA-411.
21 • transmission-planning reliability criteria for AEP-SPP.
22 • for the Commission's convenience, copies of the non-confidential
23 discovery responses I cite.

1 **II. Deadlines for the Shutdown of Flint Creek**

2 **Q: What is SWEPCo's position regarding the deadline for the shutdown of the**
3 **Flint Creek coal plant if it does not install equipment to meet MATS?**

4 A: The nominal deadline for compliance with MATS is April 16, 2015, as pointed
5 out by Ms. McCellon-Allen (Direct at 10) and Ms. Bennett (Sur-Surrebuttal at
6 8). In her January 2013 direct testimony, Ms. McCellon-Allen portrays the April
7 2015 date as a drop-dead date, after which Flint Creek could no longer be
8 operated, and by which time all replacement resources must be procured:

9 the Flint Creek plant must be retrofitted to dramatically reduce emissions or
10 it will have to be retired by April 2015. (McCellon-Allen Direct at 30)

11 [replacement resources must] be implemented as soon as possible after the
12 April, 2015 date when Flint Creek will no longer be available to serve
13 customers. (McCellon-Allen Direct at 10)

14 obtaining additional capacity from [merchant] generating resources by
15 2015 presents considerable challenges. (McCellon-Allen Direct at 19)

16 Flint Creek would no longer be available for dispatch past April, 2015....
17 (McCellon-Allen Direct 20)

18 **Q: Is April 2015 the actual drop-dead date for shutdown of Flint Creek if it is**
19 **not retrofit to meet MATS?**

20 A: No. Despite her repeated insistence that Flint Creek would no longer be
21 available past April 2015, even Ms. McCellon-Allen admits that development of
22 a compliance plan would give Flint Creek another year:

23 If...there is no other plan for compliance with MATS that will allow the
24 facility to avail itself of the 1-year compliance extension, Flint Creek will
25 not be permitted under state or federal regulation to operate beyond April
26 2015. (McCellon-Allen Direct at 10, footnote 1)

27 A plan to retire Flint Creek would be that "other plan for compliance with
28 MATS that will allow the facility to avail itself of the 1-year compliance
29 extension." Indeed, AEP has experience with this deadline in association with

1 retirement of units that are not being retrofitted for MATS compliance, since
2 April 16, 2016 is the deadline for shutdown of the uncontrolled unit at PSO's
3 Northeastern unit. Hence, Ms. McCellon-Allen's repeated assertions of a 2015
4 deadline amount to nothing more than an attempt to mislead and panic the
5 Commission into approving SWEPCo's proposed retrofits, regardless of the
6 existence of less-expensive alternatives.

7 In sur-surrebuttal testimony, SWEPCo was more candid. Ms. Bennett
8 acknowledged that "with a mitigating solution in the works...[SWEPCo] could
9 petition the State for an extra year to comply," referring to the one-year
10 extension option available under Clean Air Act §112(i)(3)(B). This extra year
11 makes the effective deadline 2016, not 2015 (Bennett Sur-surrebuttal at 8).

12 **Q: So is April 2016 the actual date at which Flint Creek would be required to**
13 **shut down?**

14 A: No. The April 2016 deadline does not apply to units that are required for
15 reliability. Exhibit PC-F3 is the EPA's memorandum on its enforcement
16 response policy for MATS for plants that are required for electric reliability.
17 Under the process described in that policy, a generator could continue to
18 operate, without penalty, until at least April 2017, as needed to maintain reliabi-
19 lity. As the EPA explains in that memorandum,

20 Where there is a conflict between timely compliance with a particular
21 requirement and electric reliability, the EPA intends to carefully exercise
22 its authorities to ensure compliance with environmental standards while
23 addressing genuine risks to reliability in a manner that protects public
24 health and welfare. (Exhibit PC-F3 at 1)

1 The EPA generally does not speak publicly to the intended scope of its
2 enforcement efforts, particularly years in advance of the date when a
3 violation may occur. The Agency is doing so now with respect to the
4 MATS to provide confidence with respect to electric reliability. EGUs may
5 be needed to operate to maintain the reliability of the electric grid when
6 they would prefer, or could be required, to halt operations...indefinitely
7 (through deactivation of a unit). This policy describes the EPA's intended
8 enforcement response in such instances. The policy is informed, as are our
9 enforcement actions in general, by the need to find an appropriate balance
10 between critical public interests, bearing in mind the resources and process
11 time required for any enforcement response. (Exhibit PC-F3 at 4)

12 Specifically, the EPA states that it will issue an Administrative Order (AO)
13 for a generator that requires another year to comply—until April 2017—due to
14 reliability constraints:

15 Some sources may take all steps necessary to comply with the MATS, but
16 may nevertheless be needed to operate in noncompliance with the MATS to
17 address concerns with electric reliability.... the EPA intends, where
18 necessary to avoid a serious risk to electric reliability, and provided the
19 criteria set forth herein are met, to issue an expeditious case-specific AO to
20 bring a source into compliance within one year.... Any such AOs would
21 be...limited to units that are required to run for reliability purposes that (A)
22 would otherwise be deactivated, or (B) due to factors beyond the control of
23 the owner/operator, have a delay in installation of controls or need to
24 operate because another unit has had such a delay. (Exhibit PC-F3 at 4)

25 **Q: Will EPA perform its own analysis of the reliability need for Flint Creek?**

26 **A:** No. The EPA has explained that it will rely on other organizations:

27 in light of the complexity of the electric system and the local nature of
28 many reliability issues, the EPA will...rely for identification and/or analy-
29 sis of reliability risks upon the advice and counsel of reliability experts,
30 including, but not limited to, the Federal Energy Regulatory Commission
31 ('FERC'), Regional Transmission Operators ('RTOs'), Independent
32 System Operators ('ISOs') and other Planning Authorities as identified
33 herein, the North American Electric Reliability Corporation ('NERC') and
34 affiliated regional entities, and state public service commissions (Exhibit
35 PC-F3 at 2)

36 the EPA intends to consult, as necessary or appropriate on a case-by-case
37 basis, with FERC and/or other entities with relevant reliability expertise.
38 (Exhibit PC-F3 at 7)

1 In order to demonstrate the need for an AO, Flint Creek would need to file
2 the following items by October 2015 (Exhibit PC-F3 at 7):

3 Written analysis of the reliability risk if the unit were not in operation,
4 which demonstrates that operation of the unit after the MATS Compliance
5 Date is critical to maintaining electric reliability, and that failure to operate
6 the unit would: (a) result in the violation of at least one of the reliability
7 criteria required to be filed with FERC,...or (b) cause reserves to fall below
8 the required system reserve margin.

9 Written concurrence with the analysis [above] by, or a separate and
10 equivalent analysis by, the Planning Authority for the area in which the
11 relevant EGU or EGUs are located,...and, where practicable, any related
12 system wide analysis by such entity.

13 ...a written demonstration of the plan to resolve the underlying reliability
14 problem and the steps and timeframe for implementing it, which
15 demonstrates that such resolution cannot be effected on or before the
16 MATS Compliance Date.

17 An identification of the level of operation of the unit that is required to
18 avoid the documented reliability risk...and, consistent with that level, a
19 proposal for operational limits and/or work practices to minimize or
20 mitigate any [hazardous air pollution] emissions to the extent practicable
21 during any operation not in full compliance with the MATS.

22 **Q: Would SWEPCo be able to make the showing needed to obtain an AO?**

23 **A:** Probably. The Company would need to demonstrate the following:

- 24 • the existence of one or more problems that require continued operation of
25 future costs of Flint Creek,
- 26 • concurrence of the regional planning authority,
- 27 • progress towards a solution to those problems to allow retirement, and
- 28 • the level of operation required to maintain reliability.

29 In its filings in this proceeding, SWEPCo has claimed that retirement of
30 Flint Creek prior to the completion of new transmission would “result in the
31 violation of at least one of the reliability criteria required to be filed with FERC”
32 and “cause reserves to fall below the required system reserve margin.” (See

1 Nickell Direct at 5, 8–9 for examples.) The remainder of the criteria to receive
2 an AO would require additional documentation, including identification of the
3 exact conditions under which Flint Creek would be required to operate. If the
4 reliability or reserve-margin issues are real, SWEPCo should be able to
5 document those problems over the next two-and-a-half years for the purposes of
6 obtaining an AO from the EPA.

7 **Q: Would SWEPCo have any difficulty obtaining the concurrence of the**
8 **planning authority for northwest Arkansas?**

9 A: No. The Southwest Power Pool is the Planning Authority for the SWEPCo
10 transmission area, including northwest Arkansas. Mr. Nickell, SPP’s Vice
11 President of Engineering, has already supported SWEPCo’s reliability claims
12 and added his own concerns about meeting reserve standards.

13 The Southwest Power Pool is also the Regional Transmission Operator and
14 the NERC-affiliated regional entity for the SWEPCo area, so it fills three of the
15 organizational roles that EPA says it would turn to for advice.

16 **Q: Would SWEPCo have any particular difficulty providing a plan to resolve**
17 **the underlying reliability problem and allow retirement of Flint Creek?**

18 A: I do not see why it would. Again, SWEPCo would have until October 2015 to
19 show progress on licensing and siting the transmission line, to describe the
20 remaining “steps and timeframe for implementing” the transmission solution,
21 and to explain why “such resolution cannot be effected on or before” April 15,
22 2016. These tasks are all within SWEPCo’s area of competence.

23 **Q: What are the other organizations to which EPA would turn for advice on**
24 **reliability issues?**

1 A: The additional identified organizations are FERC, NERC and the Arkansas
2 PSC.⁵ The FERC has indicated that it would apply a very lax standard,
3 examining “whether, based on the Commission’s review of the informational
4 filing, there *might* be a violation of a Commission-approved Reliability
5 Standard” (FERC policy, attached as Exhibit PC-F4, at 8, 10, emphasis added),
6 rather than whether a violation would be likely or inevitable.⁶ The FERC also
7 indicates it “may also identify issues within its jurisdiction other than a potential
8 violation of a Commission-approved Reliability Standard.” (Exhibit PC-F4, at .
9 10) It seems likely that FERC would support any plausible argument for the
10 existence of a reliability problem.

11 This Commission would be free to form its own conclusions in 2015 and
12 report them to the EPA.

13 **Q: Has SWEPCo demonstrated in this proceeding that Flint Creek would be**
14 **eligible for this further extension of the MATS compliance deadline?**

15 A: As I will discuss in Section V, below, SWEPCo has provided incomplete
16 descriptions of how Flint Creek’s retirement would affect the potential
17 reliability in northwest Arkansas. As a result, the current record might not be
18 sufficient to support a request for an AO for Flint Creek. If SWEPCo is correct
19 that operation of Flint Creek beyond April 2016 is necessary for reliability,
20 SWEPCo will have over two years to document the situation to EPA’s
21 satisfaction. If SWEPCo cannot produce a coherent demonstration that

⁵It is possible that other state commissions would want to comment on reliability, reserve margins, and the timing constraints.

⁶The policy document is “Policy Statement on the Commission’s Role Regarding the Environmental Protection Agency’s Mercury and Air Toxics Standards” issued May 17, 2012, in Docket No. PL12-1-000.

1 retirement of Flint Creek prior to completion of new transmission would pose a
2 serious reliability problem in northwest Arkansas, there probably is no such
3 problem, in which case the PSC need not worry excessively about the retirement
4 of Flint Creek in 2016.

5 **Q: Assuming that SWEPCo can provide a coherent explanation of the need for**
6 **Flint Creek until new transmission is constructed, produce a plan for**
7 **building the transmission and demonstrate the support of SPP, what other**
8 **conditions would SWEPCo need to justify an extension of Flint Creek’s**
9 **compliance deadline?**

10 A: The last requirement laid out by the EPA (Exhibit PC-F3 at 7) is that SWEPCo
11 would need to identify “the level of operation of the unit that is required to
12 avoid the documented reliability risk” and associated operational limits. In this
13 docket, SWEPCo assumed that Flint Creek would need to operate at its
14 minimum load level (about 330 MW or 63% of full load) for the summer and
15 winter months, or roughly a 35%–40% annual capacity factor (Weaver Rebuttal
16 at 8; SWEPCo Responses to Sierra Club Data Request 1-165b and to APSC
17 Data Request 5-4).⁷ The Company assumed that these reliability constraints
18 would be binding only if Flint Creek were converted to operate on gas.

19 On the other hand, the weekly data that SWEPCo provided on the loads in
20 northwest Arkansas indicate that load has been within 330 MW of peak in only
21 14 to 19 weeks of the year (SWEPCo Response to Sierra Club Data Request 7-
22 282). If 330 MW of Flint Creek output is sufficient to back up the existing
23 transmission system at peak, no Flint Creek capacity should be required when

⁷For the Commission’s convenience, I attach the non-confidential responses to data requests that I cite as Exhibit PC-F1. The two responses cited here are confidential and are not included in my exhibit.

1 loads are 330 MW below peak. Operating Flint Creek at 330 MW for 14–19
2 weeks would result in a capacity factor of 17%–23%. Since the high loads are
3 less likely on weekends, and not every weekday in a high-load week would be
4 expected to have a high load, Flint Creek could probably operate much less,
5 even if SWEPCo’s assumed need for 330 MW at peak is correct. An average of
6 four days of operation in the high-load weeks would result in a capacity factor
7 of 10%–13%.

8 The EPA would probably want to see an analysis of the load levels at
9 which Flint Creek operation would be required, so that specific operational
10 limits could be written into the AO, minimizing Flint Creek’s emissions of
11 mercury and other hazardous air pollutants, while providing SWEPCo with the
12 operational flexibility necessary to maintain reliable service. Again, SWEPCo
13 should be able to complete that analysis by October 2015.

14 **Q: Is SWEPCo aware of these provisions for extending the MATS compliance**
15 **date?**

16 **A:** Yes. On discovery, SWEPCo summarizes those provisions as follows:

17 U.S. EPA has stated that...it may be reasonable to grant the 1-year
18 extension if the permitting authority determines, based on information from
19 the regional transmission organization, that continued operation of a
20 particular unit slated for retirement for some or all of the additional year is
21 necessary because...transmission upgrades are needed in order to maintain
22 electric reliability after the unit is retired. (SWEPCo Response to Sierra
23 Club Data Request 7-244a)

24 U.S. EPA has issued a policy memorandum,...which describes its intended
25 enforcement policy with respect to sources that must operate in
26 noncompliance with the MATS for up to a year to address a specific and
27 documented reliability concerns. Under the enforcement policy, a source
28 that qualifies for a one year extension from the permitting authority may
29 also qualify for an additional year under an administrative order by U.S.
30 EPA, provided that the unit is critical for reliability purposes and otherwise
31 falls within the terms of the policy. (SWEPCo Response to Sierra Club
32 Data Request 7-244b)

1 These responses demonstrate that SWEPCo is aware that Flint Creek
2 would be available for dispatch for years past April 2015.

3 **Q: Is April 2017 then the final drop-dead date for the shut-down of Flint**
4 **Creek?**

5 A: No. The EPA recognizes that longer delays may be necessary, as follows:

6 This policy does not address situations where a reliability critical unit needs
7 more than one year to come into compliance after the MATS Compliance
8 Date....The EPA intends to handle such scenarios as it has in the past, by
9 assessing each situation on a case-by-case basis, at the appropriate time, to
10 determine the appropriate enforcement response and resolution. (Exhibit
11 PC-F3 at 2)

12 **Q: Please summarize the time frame for SWEPCo to implement transmission**
13 **and/or generation alternatives and shut down Flint Creek.**

14 A: The EPA has indicated that it does not intend to force the shutdown of
15 generators needed for reliability until reliability solutions can be implemented.
16 Under the guidance provided to date, there is a clear path to continue operating
17 Flint Creek until April 16, 2017, to the extent necessary to maintain reliable
18 power supply in northwest Arkansas.⁸ If the transmission and/or generation
19 solutions to the reliability issues identified in northwest Arkansas cannot be
20 fully implemented by April 2017, EPA has indicated that it will work out
21 solutions on a case-by-case basis. While SWEPCo should be acting promptly to
22 document the need for the delay and to prepare for construction of any
23 necessary transmission and initiation of procurement of new resources, there is
24 no reason to believe that the EPA will endanger reliability.

⁸Since SWEPCo has indicated that Flint Creek is not needed for reliability [REDACTED], (SWEPCo HSPI response to Sierra Club Data Request 1-165b), June 2017 would be the effective deadline for the reliability solutions with an Administrative Order extending operation past the winter 2017 period.

1 **III. Timeline for Replacement Generation**

2 **Q: What concerns does SWEPCo raise regarding the timeline for acquiring**
3 **generation to replace Flint Creek?**

4 A: While SWEPCo's original filing in this proceeding treated purchases of existing
5 resources as impractical or irrelevant (Weaver Direct at 54–55), the January
6 2013 filing accepts a purchase as the most likely replacement, but raises
7 concerns about delays due to the following three requirements:⁹

- 8 • The Market-Based Mechanism (MBM) required by the Louisiana PSC,
9 which could delay the acquisition of replacement resources by one year
10 (McCellon-Allen Direct at 21) or “a year or more” (9) or “approximately 7
11 to 12 months” (Bennett Rebuttal at 18).
- 12 • The SPP Transmission Service Study process which would require two
13 years (McCellon-Allen Direct at 21) or “more than one year, and can take
14 up to two years” (Nickell Direct at 9), or 12–18 months (Ross Rebuttal at
15 8).
- 16 • The need to “obtain the necessary firm transmission service from SPP” for
17 the replacement capacity, which might take between two and three years
18 (McCellon-Allen Direct at 20), exposing SWEPCo to “compliance risk”
19 (Nickell Direct at 9–10).

⁹While Ms. McCellon-Allen in her January testimony claims that only three combined-cycle plants are known to have capacity for sale (Direct at 19), she later adds Green Country to this list (Direct at 20). She does not claim that no capacity is available from the other plants listed in Table 4 of my direct testimony, only that “We do not have information on what capacity is available from these plants” (SWEPCo Response to Sierra Club Data Request 7-250, which also lists additional six plants that have bid into AEP RFPs since 2008).

1 **A. *The Louisiana Market-Based Mechanism***

2 **Q: What is SWEPCo's projection for how long the MBM would delay the**
3 **acquisition of generation resources?**

4 A: Ms. McCellon-Allen suggests (Direct at 12) that the schedule should be based
5 on the Company's experience and "When SWEPCo last implemented the
6 LPSC's MBM approval process for major new generation resources, the process
7 took 12 months to complete."

8 **Q: Is this a relevant comparison?**

9 A: No. Although the Sierra Club asked SWEPCo to provide details on past MBM
10 applications filed by SWEPCo and other utilities (including dates of filing, RFP
11 and decision, nature and date of need and the utility's proposed resources),
12 SWEPCo provided only a list of four of its filings, by date. (SWEPCo Response
13 to Sierra Club Data Request 7-242) SWEPCo should remain familiar with the
14 LPSC's implementation of its MBM order, given that SWEPCo is concerned
15 that the MBM would be a barrier to timely resource planning.

16 Ms. McCellon-Allen's 12-month estimate appears to be a reference to
17 some part of SWEPCo's complex filings related to the following projects:

- 18 • building the Mattison peakers,
- 19 • building the Stall combined-cycle plant,
- 20 • building the Turk coal plant,
- 21 • making short-term purchases,
- 22 • entering into long-term purchased-power agreements.

23 Self-build proposals, especially simultaneous proposals for multiple
24 facilities, would generally take longer to resolve than proposals for purchases.
25 Thus, the 12-month period reported by Ms. McCellon-Allen is not a good
26 predictor of the MBM process duration for a simpler purchase transaction.

1 Moreover, since that set of overlapping filings, the LPSC has shortened the
2 amount of notice the utility must give the Commission before filing a draft RFP
3 from 60 to 30 days.¹⁰

4 The Louisiana PSC has approved further modifications to the basic MBM
5 process to accommodate utility circumstances, including waiving the
6 requirement for Entergy to file a draft RFP in 2010, reducing notice and review
7 periods for Entergy in June 2012, and waiving the entire process for the
8 Dixieland co-op, which ran its own RFP process.¹¹ In 2008, the LPSC Staff
9 reported, “To date, no request for an MBM exemption has been rejected in a
10 Commission certification case” (LPSC Docket R-26172-C, October 7, 2008,
11 Staff Report, attached as Exhibit PC-F5, at 24).

12 A relatively recent MBM process, concerning a mid-term purchase by
13 CLECo, started with the filing of the Notice of Intent on August 8, 2011 and
14 ended less than nine months later with a settlement filed March 21, 2012 (LPSC
15 Docket No. U-32223). Much of that time was occupied by the RFP process that
16 would have been necessary for any efficient and orderly power acquisition.

17 Thus the evidence shows that the delay introduced by the MBM process is
18 likely to be closer to the low end of the seven-to-twelve-month range given by
19 Ms. Bennett (Sur-Surrebuttal at 20) than to the 12-month estimate preferred by
20 Ms. McCellon-Allen.

21 **Q: Could the MBM requirements preclude SWEPCo from purchasing**
22 **resources to fill any short-term capacity deficiency?**

¹⁰LPSC Docket R-26172, subdocket C, October 15, 2008 General Order, Appendix C ¶2.

¹¹Louisiana PSC Special Order No. 34-2010 (7/28/2010); Louisiana PSC Minutes from June 28, 2012 Open Session; Louisiana PSC Order No. U-32275 (Corrected) 11/15/12.

1 A: No. The MBM does not apply to a contract for less than three years with non-
2 affiliates.

3 **B. Firm Transmission Service**

4 **Q: What do the SWEPCo witnesses say about the process of procuring trans-
5 mission service for newly purchased generation entitlements?**

6 A: They testify that there would likely be multi-year delays in obtaining firm trans-
7 mission service:

8 However, the timing for the transmission upgrades required is a critical
9 issue. Typically, transmission upgrades require two to three years to com-
10 plete after a transmission service study, which may also take one to two
11 years to complete. This timeframe does not match the need, as Flint Creek
12 would no longer be available for dispatch past April, 2015, and reliability
13 risks would exist until upgrades were completed. (McCellon-Allen Direct
14 at 20)

15 SPP's transmission service administration process...usually takes more
16 than one year, and can take up to two years, from the time transmission
17 service request is submitted to obtain a transmission service agreement for
18 the requested service...is likely that transmission upgrades would have to
19 be constructed as a condition to receiving the service which could add an
20 additional 3-5 years before delivery of the capacity is actually achievable.
21 (Nickell Direct at 9-10)

22 Mr. Nickell also warns that the reduction in AEP's reserve margin due to a
23 delay in procuring transmission rights for purchases to replace Flint Creek

24 puts SWEPCo in an untenable situation of not only incurring risks of non-
25 compliance with SPP Criteria, but also introducing unacceptable reliability
26 risk to the region. (Direct at 9)

27 He then states that "SWEPCo and the region would be subject to unavoidable
28 compliance and reliability risks" (Direct at 10).

29 **Q: Their descriptions of the problem with obtaining firm transmission service
30 certainly sound dire. Would SPP refuse to dispatch generation to serve**

1 **SWEP Co or northwest Arkansas if the firm transmission rights from**
2 **resource purchases were not yet secure?**

3 A: No. Even if SWEP Co does not hold all the transmission rights that would be
4 required under the SPP process, SPP will continue to serve SWEP Co load
5 (SWEP Co Response to Sierra Club Data Request 7-252).¹² Lack of contractual
6 transmission paths should not be a reliability problem for the AEP sub-region,
7 especially since the AEP sub-region has 2,169 MW of capacity with firm supply
8 contracts outside the region. (SWEP Co Response to Sierra Club Data Request 7-
9 279) Regardless of what happens on a contractual basis, the energy generated in
10 AEP's sub-region is available to support load in the region, while generation
11 owned by SWEP Co outside the AEP sub-region serves loads near those
12 generators. The electrons do not know who has purchased them.

13 **Q: What are the “risks of non-compliance” that concern Mr. Nickell?**

14 A: Mr. Nickell was unable to identify any specific penalties for non-compliance
15 related to the delay in obtaining transmission rights. He says that “SPP has not
16 directly issued penalties for non-compliance with SPP Criteria primarily
17 because SPP members take their responsibilities seriously and strive diligently
18 to meet those requirements” (SWEP Co Response to Sierra Club Data Request 7-
19 280). The reserve margin target is an SPP requirement (Nickell Direct at 8–9),
20 so SPP would be the obvious entity to assess any penalties. Nor does Mr.
21 Nickell offer any evidence that SWEP Co is not striving diligently to meet its
22 share of AEP's capacity requirement, or would not strive diligently to do so

¹²The only situation SWEP Co has identified in which that would not be possible were if Flint Creek were retired and the multiple transmission outages I describe in Section V.A occurred before the Fort Smith–Chambers Spring transmission line were complete. As I explain in Section II, Flint Creek will almost certainly continue operating until the new transmission line is built.

1 following an economic decision to retire Flint Creek. While he suggests that
2 NERC or FERC could assess penalties for having a low reserve margin, he does
3 not provide any evidence of either entity doing so, especially while the affected
4 utility is attempting to procure transmission rights.

5 **Q: What are the unacceptable reliability risks of which Mr. Nickell warns**
6 **(Direct at 9)?**

7 A: It is not clear whether he is warning about the reserve levels in SPP as a whole
8 or in the AEP sub-region. As for the SPP region, the 2012 SPP Form EIA-411
9 (at 73, excerpts attached as Exhibit PC-F6) reports capacity margins of over
10 20% (equivalent to reserve margins over 27%) through 2022. That is a supply
11 cushion of nearly 7,000 MW over the target 12% capacity margin (13.6%
12 reserve margin), not counting some 4,400 MW of “other” capacity, which
13 includes “Mothballed generation (that may be returned to service during peak
14 demand)” and generation that is curtailable or non-firm, regardless of the
15 probability of its availability when needed (Exhibit PC-F6 at 71).¹³ The
16 retirement of Flint Creek would have little effect on SPP’s capacity surplus.

17 For the AEP sub-region, Mr. Nickell reports (Direct at 8) that “it was
18 determined that capacity margin...would decrease from 11.8% to 9.6%
19 following the retirement of Flint Creek.” That would still be more than the 9.1%
20 capacity margin SPP reports for the AEP sub-region in 2014 (2012 SPP Form
21 EIA-411, p. 77); SWEPCo has not indicated that it has any urgent need for new
22 resources in 2014. Short-term deviations from sub-region target reserve margins
23 do not appear to pose any serious reliability problems.

¹³For example, a generator may not have firm transmission access when local load is low and generation is high, but it would not be needed for reliability at those times.

1 In addition, there are 2,169 MW of capacity in the AEP sub-region with
2 contracts to deliver power outside that region (SWEPCo Response to Sierra
3 Club Data Request 7-279), and extensive transmission interconnection between
4 the AEP sub-region and other SPP sub-regions, and between AEP and Entergy,
5 so there should be sufficient capacity available to serve loads in the AEP sub-
6 region.

7 **IV. Timeline for Constructing Transmission to Northwest Arkansas**

8 **Q: What is SWEPCo’s position regarding the time that would be required to**
9 **construct additional transmission into northwest Arkansas?**

10 A: Mr. Nickell notes,

11 a new 345 kV transmission facility would likely be a candidate solution to
12 resolve the issues [he identifies]. However, Flint Creek’s retirement would
13 need to be evaluated in further detail within the SPP ITP process to confirm
14 this assumption and select the most cost effective project for construction.
15 (Nickell Direct at 10)

16 He goes on to suggest that “the study could take 1-3 years depending on
17 the ITP process used,” which might be the annual ITP Near-Term Assessment
18 or the triennial ITP 10-Year Assessment.

19 Mr. Nickell estimates an additional four years for construction (Direct at
20 13).

21 **Q: Would SPP’s review of the proposed 345 kV transmission line from Fort**
22 **Smith to Chamber Springs have to start from scratch?**

23 A: No. The SPP has already reviewed the line and SPP staff recommended the
24 adoption of a plan that included the Fort Smith–Chamber Springs line. The SPP

1 has identified the proposed Fort Smith to Chamber Springs 345 kV trans-
2 mission line as a robust, long-term solution that addresses the delivery of
3 power to NW-AR as recognized in its 2010 ITP 20-year recommendation.
4 When the plan was received at the SPP Board on January 25, 2011, the line
5 was removed from the plan in the course of the meeting, since it was not
6 needed for the ten year forecast and would impose added cost to SPP rate
7 payers. (Hassink Rebuttal at 5)

8 **Q: Is there any reason to believe that SWEPCo would need to seek SPP**
9 **approval through the triennial long-term review process?**

10 A: No. Since SWEPCo expects to need the new line once Flint Creek retires, the
11 need would fall within the six-year horizon of the annual Near-Term
12 Assessment. Mr. Nickell acknowledges,

13 The ITP Near-Term Assessment could be used to identify a reliability need
14 and an associated transmission expansion project to serve as the solution as
15 long as the proper assumptions were contained in the evaluation at the time
16 of the assessment. In that case, there would be no need to delay evaluation
17 until the next ITP 10-Year Assessment. (SWEPCo Response to Sierra Club
18 Data Request 7-287)

19 **Q: Does Mr. Nickell provide any support for his estimate of four years for con-**
20 **struction of the new line?**

21 A: No. To the contrary, he describes a more complex project that was completed
22 more quickly, one that

23 consisted of about 90 miles of new 230 kV transmission line and associated
24 substations with the construction work shared by three utilities” in the
25 Acadiana Load Pocket “took approximately three years....Very little
26 construction work on this project could be performed during summer
27 months and other times of expected high consumer demand. Even during
28 times of milder conditions during construction of this project, customers
29 were put on energy conservation notices and load shedding plans were
30 developed and ready to be utilized by the parties. (Nickell Direct at 11–12)

31 In contrast, the Fort Smith–Chamber Springs Line would be about 70
32 miles, and as described by Mr. Hassink (Direct at 8–9) would not involve

1 construction of new substations or sharing of construction work among multiple
2 utilities.

3 Mr. Nickell suggests that problems similar to those in Acadiana would
4 arise for the Fort Smith–Chamber Springs line.

5 Implementation of new transmission upgrades in the load pocket can also
6 be challenging because of reliability risks imposed to the area during
7 construction and connection of new facilities. For example, if a transmis-
8 sion project required that an outage of one of the existing primary sources
9 of power for the area be taken in order to connect a new facility to the grid,
10 SPP’s Reliability Coordinator would be challenged to find a reliable way to
11 facilitate the event without having to direct interruption of customers in the
12 area. (Nickell Direct at 11)

13 **Q: Is the new transmission line into northwest Arkansas likely to be signifi-**
14 **cantly delayed by the construction limits imposed on the Acadiana project?**

15 A: No, for three reasons. First, because the Fort Smith–Chamber Springs Line
16 would require only two connections, one at each substation, the need to shut
17 down facilities during interconnection would be limited. The vast majority of
18 the construction work could be performed regardless of load level.

19 Second, the load data provided by SWEPCo show that in each of the last
20 seven years, northwest Arkansas loads have been below 1,000 MW for 38
21 weeks, consistently below 900 MW for 29 weeks, and below 800 MW for 14
22 weeks (SWEPCo Response to Sierra Club Data Request 7-282). So there are
23 considerable low-load periods in which interconnection work can be scheduled.

24 Mr. Nickell indicates that

25 Normally, multiple outages would need to occur over an extended period in
26 order for work to be completed so that the new transmission line can be
27 energized. Based on review of historical information over a two-year
28 period, an average of 8 weeks of cumulative outage time would need to
29 occur to tie in a new transmission line. (SWEPCo Response to Sierra Club
30 Data Request 7-283)

1 Spreading those eight weeks over the 28 low-load weeks of 2016 and 2017
2 (the weeks that were historically consistently under 800 MW, or about 67% of
3 peak), for example, would not appear to be very challenging.

4 Third, as discussed in Section II above, EPA has indicated that it will not
5 require the shutdown of generators vital to reliability during the period in which
6 replacement facilities are under construction. Flint Creek is almost certain to
7 remain in operation, at least as needed for reliability, until after the new line is
8 constructed.

9 **Q: Given the information provided by SWEPCo, how long should it take to**
10 **bring a new transmission line into service for northwest Arkansas?**

11 A: Assuming one year for the SPP review, simultaneous review by the Arkansas
12 PSC, and three years for construction, the line would be in service in 2017.
13 Considering SWEPCo's obvious concern that the PSC will not pre-approve the
14 retrofitting of Flint Creek, and SWEPCo's announced intention to retire the
15 plant if it does not receive that approval, it would be prudent for SWEPCo to
16 move forward with the SPP process and the initial design and routing of the line.

17 V. Operating Without Flint Creek and Major Replacements

18 A. *Transmission Issues*

19 **Q: Does Mr. Nickell's testimony adequately support the conclusion that**
20 **retirement of Flint Creek would result in serious reliability problems?**

21 A: No, for the following reasons.

- 22 • His testimony is very vague and conclusory, omitting most of the details
23 about the assumptions underlying his analysis.

- 1 • While he refers to “preemptive load shedding” due to the loss of a 345 kV
2 line (Nickell Direct at 17), he provides no analysis demonstrating the
3 conditions under which such load shedding would be required, nor does he
4 demonstrate that activating a special protection system following a first
5 contingency would not be sufficient.¹⁴
- 6 • Rather than answering Sierra Club’s questions about the inputs to his
7 analysis, Mr. Nickell provided 91 files that had unusual extension names,
8 which turned out to be text files. Without a guide to the files and their
9 meaning, it is difficult to understand what Mr. Nickell thought he found
10 (SWEPCo Response to Sierra Club Data Request 2-272).¹⁵
- 11 • The load assumptions that Mr. Nickell used were overstated by anywhere
12 from about 7% to 140% in the various model runs.
- 13 • The generation dispatch in the model runs does not appear to reflect the
14 way that operators would actually dispatch generation to minimize outage
15 risks for the modeled load and transmission conditions.
- 16 • The analysis does not appear to reflect realistic installation and operation
17 of reactive power control and other transmission protection options.

18 **Q: Please describe in more detail the documentation that Mr. Nickell provided.**

19 A: In response to several of Sierra Club’s data requests inquiring about specific
20 inputs, assumptions, and results of the model runs, SWEPCo provided
21 Attachment 7-272, which consisted of nearly 100 undocumented files with such

¹⁴Mr. Nickell also mentions a combined total of 47 days during which there was some period of outage on one of the two critical 345 kV lines that were experienced during 2012 (Direct at 17). He does not provide any information on how many of those outages were scheduled at low-load times for maintenance, nor whether any occurred at loads near peak.

¹⁵Mr. Nickell also provided a very large file in a specialized format that can only be read by transmission-modeling software.

1 impenetrable names as “Flint_Creek_2_branches_12.pvt” and
2 “Flint_Creek_2_branches-ovl_6.rpt.” In those files, the names of substations
3 and power plants are abbreviated in ways that make them difficult to match with
4 other sources. We received some clarification in an email from SPP counsel on
5 February 25, nearly four weeks after the responses were due. That email is
6 attached as Confidential Exhibit PC-F7.¹⁶

7 Mr. Nickell also refused to provide a map of the transmission lines and
8 generators referenced in his model, instead referring to an incomplete map
9 provided by SWEPCO in an earlier phase of discovery (SWEPCo Response to
10 Sierra Club Data Request 7-256). While SWEPCo staff members tried to help
11 me decode Mr. Nickell’s abbreviations and locate the substations (in a February
12 14, 2013, conference call), they were not able to identify them all.

13 **Q: Please explain why you say that the loads used in Mr. Nickell’s analysis are**
14 **overstated.**

15 A: The lowest northwest-Arkansas load that Mr. Nickell modeled was 1,345 MW,
16 and his other model runs used loads up to 3,045 MW. Mr. Nickell appears to
17 have modeled 100 MW increments of load, as well as 20 MW increments from
18 1,645 MW to 1,725 MW. (SWEPCo Response to Sierra Club Data Request 7-
19 272 Attachments and Exhibit PC-F7).


20 While Mr. Nickell claims that “The model utilized for this analysis reflects
21 2014 summer peak conditions” (Nickell Direct at 5), even the lowest load he
22 modeled is rather high for a 2014 load, and the other load levels are entirely
23 implausible. Mr. Nickell provides weekly peak load for each week of 2006–

¹⁶While that email did not indicate that its contents are confidential, I have marked Exhibit PC-F7 as confidential, since I cannot determine whether SWEPCo considers some of the information in the email to be confidential.

1 2011 (SWEP Co Response to Sierra Club Data Request 7-282, Attachment 1).
 2 Table 1 shows the maximum value for each year. Figure 1 compares the
 3 historical loads to the values that Mr. Nickell used.

4 **Table 1: Northwest Arkansas Peak Loads**

<u>Year</u>	<u>Maximum Load</u>
2006	1,152 MW
2007	1,190 MW
2008	1,219 MW
2009	1,117 MW
2010	1,207 MW
2011	1,276 MW
2012	1,233 MW



5 **Figure 1: Northwest Arkansas Load, Historical and as Modeled by Mr. Nickell**

6 The high load in 2011 was associated with an extremely hot summer. Even
 7 during the recovery from the recession, from 2010 to 2012, northwest Arkansas
 8 load grew only about 13 MW annually, or about 1%. At that rate, the northwest-
 9 Arkansas peak would not reach 1,345 MW until about 2020, by which time any

1 necessary additional transmission facilities could be in service. In addition, the
2 PSC's energy-efficiency proposed targets would require SWEPCo to reduce its
3 Arkansas load by 1% in 2013, rising to 1.5% annually by 2015, greater than the
4 recent historical load growth.¹⁷

5 **Q: What is the implication of Mr. Nickell's choice of load levels?**

6 A: His results are not useful to the Commission in determining what would happen
7 were Flint Creek retired a year or two before the construction of another trans-
8 mission line. Mr. Nickell claims,

9 The results of this analysis indicate that once Flint Creek is removed from
10 service, severe thermal overloads and voltage decreases occur due to
11 transfers into the load area. These thermal overloads and voltage reductions
12 increase the threat of cascading transmission outages within the area that
13 would result in voltage collapse and customer power outages. (Nickell
14 Direct at 5)

15 The analysis showed that the absence of Flint Creek generation causes
16 more flows into the area that result in voltage and thermal violations during
17 contingency conditions. These violations were present in the analysis even
18 before simulating power transfers into the area to meet increased consumer
19 demand beyond that which was modeled. (SWEPCo Response to Sierra
20 Club Data Request 7-271)¹⁸

21 In fact, his analyses do not show this mass of violations—voltage collapse,
22 low-voltage, and thermal overloads—at the 1,345 MW load level. The most dire
23 outcome, voltage collapse, occurs only for northwest-Arkansas loads at [REDACTED]

¹⁷The recent historical data also includes some effects of energy-efficiency programs. Assuming that the summer peak for each year reflects half the effect of efficiency measures installed in that year (plus all previous installations), and that SWEPCo achieved the PSC targets in northwest Arkansas, the cumulative energy-efficiency effect would be about 0.1% in 2010 (about 1 MW) and 1.1% in 2012 (about 13 MW).

¹⁸The “power transfers into the area” are the 100 MW to 1,700 MW that Mr. Nickell adds to the already-high 1,345 MW he asserts was the forecast for 2014.

1 MW and above (Exhibit PC-F7). This is approximately [REDACTED] higher than the
2 highest previous northwest-Arkansas load.

3 Nor do voltage reductions appear to be a problem. The Transmission
4 Planning Reliability Criteria for the AEP-SPP system specify the voltage limits
5 as follows:

6 Transmission voltage should not...fall below 90% of nominal voltage
7 shown above during emergencies. The low limit can be lower if voltage
8 regulating equipment maintains voltage to the customers within prescribed
9 limits at distribution substations involved without causing voltage problems
10 at nearby loads. (2012 American Electric Power AEP-SPP FERC Form 715
11 Part 4, excerpt attached as Exhibit PC-F8, at 4.3).

12 As for the voltage reductions, the lowest load at which any bus voltage fell
13 below 90% of normal under any of the 27 contingencies that Mr. Nickell
14 modeled was [REDACTED] MW, vastly higher than any load likely in this decade.

15 Finally, Mr. Nickell's analysis shows that, under certain dispatch
16 conditions, one line ([REDACTED]) experiences overloads at
17 [REDACTED] MW.¹⁹ This occurs under second contingency conditions, with the
18 concurrent loss at peak of both the largest 345-kV line from the west into
19 northwest Arkansas (Tonnece to Flint Creek) and either the second-largest 345-
20 kV line (Clarksville to Chamber Springs) or the very short line from the
21 [REDACTED] to the adjacent [REDACTED] substation.²⁰ Mr. Nickell also
22 finds a rather small overload for a low-capacity line (a [REDACTED] line from [REDACTED])

¹⁹This line appears to be only about [REDACTED] miles long, so reconductoring or reinforcing it may be relatively inexpensive and quick.

²⁰The SWEPCo FERC Form 1 lists this line as 0.23 miles in length. From Google maps, it appears that the line spans only four poles.

1 [REDACTED] if the lines from GRDA 1 to Tonnece and from Clarksville to Chamber
2 Springs fail.²¹

3 **Q: What is wrong with the generation dispatch in the model runs?**

4 A: I believe that there are three problems. First, “prior to any simulated power
5 transfer and load increase...The conditions assumed are those in the SPP base
6 model” (Erin Cullum e-mail, Exhibit PC-F7). Since the SPP base case includes
7 the operation of Flint Creek, the dispatch of generation in that case would not
8 reflect the post-Flint Creek transmission issues in northwest Arkansas. Specifi-
9 cally, when Flint Creek is operating, power tends to flow into northwest Arkan-
10 sas from the west and out of northwest Arkansas to the northeast and east. With
11 the retirement of Flint Creek (or even during outages at Flint Creek), SPP would
12 dispatch more generation to the northeast and east to reduce the stress on the
13 lines into northwest Arkansas from the west. There is no indication that Mr.
14 Nickell modified dispatch to accommodate the retirement of Flint Creek.

15 Second, when Mr. Nickell increases load in northwest Arkansas, he says
16 that he increases generation levels from

17 Entergy Services, CLECo Power, Oklahoma Gas and Electric Company,
18 American Electric Power West..., The Empire District Electric Company,
19 and City Utilities of Springfield.” (SWEPCo Response to Sierra Club Data
20 Request 7-277)

21 That would include resources on all sides of northwest Arkansas. But the tables
22 of generation for various load levels include only part of the region Mr. Nickell
23 lists. Specifically, the generation that adapts to northwest Arkansas load in-
24 cludes plants in Oklahoma, SWEPCo’s territory, Louisiana, and even some in
25 Mississippi, but not Empire District generation to the northwest or Entergy

²¹This line runs to a substation called “[REDACTED],” which is not on the map in SWEPCo Response to Sierra Club Data Request 1-184, or any other map I have been able to find.

1 Arkansas generation to the east. Again, Mr. Nickell's modeling appears to
2 increase flows from the west, exacerbating the transmission problems in north-
3 west Arkansas.

4 Third, Mr. Nickell does not appear to recognize that SPP would change
5 dispatch in response to the first transmission contingency, before the second
6 contingency would plausibly occur. The contingencies identified as possible
7 problems in Mr. Nickell's analysis are rare and independent events. While a
8 second line may fail before the first line is back in operation, the simultaneous
9 outage of both lines is vanishingly unlikely.²² In 15 to 30 minutes, SPP would
10 be able to ramp up operating generation and call on fast-start peakers to the east,
11 and ramp down generation to the west. Mr. Nickell's modeling does not appear
12 reflect any such response to the first contingency. Indeed the files in SWEPCo
13 Response to Sierra Club Data Request 272 with the extension ".prg" show that
14 the program was instructed to "never" "adjust area interchanges," either before
15 contingencies or afterward.

16 **Q: Other than redispatching generation, do system operators have other**
17 **options for redistributing load on transmission lines at high loads or**
18 **following contingencies?**

19 A: Yes. Transmission systems have various combinations of control devices to
20 influence the flow of real and reactive power, to reduce line losses and avoid
21 overloads. Those options include load-tap transformers, phase-shifters, and
22 capacitors. Operators also arm Special Protection Systems when the system is
23 under stress, to limit the effect of an outage of particular system elements.

²²Extreme weather events (storms, tornadoes and the like) can knock out multiple transmission lines in short order, but those events also tend to knock out large parts of the distribution system, reducing load.

1 **Q: Did Mr. Nickell's model runs use these options to maintain the reliability of**
2 **the northwest-Arkansas system?**

3 A: No. Table 2 shows the settings Mr. Nickell applied in his model, from the prg
4 files in SWEPCo Response to Sierra Club Data Request 272. Mr. Nickell
5 allowed the operation of phase-shifters to control real power flow, but turned off
6 all other control equipment.

7 **Table 2: Settings for Transmission Equipment in Nickell Model**

Control Technique	Program Setting
Adjust ULTCs for MVar flow control	Never
Adjust phase-shifters for MW flow control	In Pre-Contingency
Adjust static tap-changers for voltage control	Never
Adjust static tap-changers for MVar control	Never
Adjust static phase-shifters for MW control	Never
Adjust static series compensators	Never
Adjust automatic Special Protection System	Never
Adjust manual Special Protection System	Never

8 **Q: Does Mr. Nickell include the capacitors and static compensator that Mr.**
9 **Hassink says SWEPCo would add if Flint Creek were retired (Hassink**
10 **Direct at 8)?**

11 A: There is no indication that Mr. Nickell added those devices to his model of the
12 SPP base case (which would not include the devices). The issues in siting these
13 devices at existing substations and installing them should be much simpler than
14 those related to the transmission line; getting them into service by 2017 should
15 not be particularly challenging.

16 **Q: Did SPP or SWEPCo develop a Special Protection System for northwest**
17 **Arkansas during past outages at Flint Creek?**

18 A: Apparently not. In response to a request for any such protection plans, Mr.
19 Nickell said:

1 Special plans or actions are identified and developed closer to real-time
2 (anywhere from day ahead to days ahead of the expected outage) to address
3 reliability studies that identify this resource as having an impact on any
4 planned transmission outage in the area. The operating guides would in-
5 clude the constraint issue as identified, the appropriate congestion manage-
6 ment action required and the entities that are responsible for taking the
7 required action. (SWEPCo Response to Sierra Club Data Request 7-278)

8 It would seem that had SPP and SWEPCo been worried enough about the
9 possibility of a summer outage at Flint Creek they would have prepared a
10 response plan. They will have several years prior to the retirement of Flint Creek
11 to prepare a Special Protection System for northwest Arkansas, covering “appro-
12 priate congestion management actions.”

13 **Q: Is there reason to believe that the transmission system in northwest Arkan-**
14 **sas would survive the loss of two lines at a 1,345 MW load, after appropri-**
15 **ately balancing load among transmission lines, changing generation dis-**
16 **patch before and after the first contingency, and utilizing protective**
17 **equipment and systems?**

18 **A:** Yes. Table 3 lists the summer contingency capacity of the northwest Arkansas
19 interfaces, from SWEPCo Response to Sierra Club Data Request 7-258. Even
20 taking out the two largest lines (from Tonnece and Clarksville), the sum of the
21 remaining capacities is 2,360 MW, 75% higher than the 1,345 MW load Mr.
22 Nickell assumed. The sum of the lines’ capacities is 1,983 MW, twice the 968
23 MW net flow into northwest Arkansas (1,345 MW load minus 377 MW of
24 generation). Flows on the lines could be within the contingency limits, even
25 with imperfect balancing of the flows.

1 **Table 3: Transmission and Generation Serving Northwest Arkansas**

Supply into NW Arkansas	Voltage	Summer Contingency Capacity
Tonnece-Flint Creek	345 kV	1,367 MW
Monett-Flint Creek	345 kV	1,130 MW
Clarksville-Chamber Springs	345 kV	1,176 MW
Siloam Springs City (GRDA)–Siloam Springs	161 kV	317 MW
Decatur-Flint Creek	161 kV	268 MW
VBI-VBI North	69 kV	48 MW
Beaver Dam-Avoca REC	161 kV	220 MW
Mattison generation		300 MW
Elkins generation		60 MW
Ellis generation		17 MW

2 **Q: Does Mr. Nickell raise any other concerns about operating the northwest-**
3 **Arkansas system without Flint Creek, before the completion of new**
4 **transmission?**

5 A: Yes. Mr. Nickell expresses the concern that locational marginal prices (LMPs)
6 in northwest Arkansas would rise in this period. (Nickell Direct at 14–16)

7 **Q: Should this be a matter of significant concern to the Commission?**

8 A: No. The higher prices paid in northwest Arkansas would be paid to the
9 generators in northwest Arkansas: primarily SWEPCo's Mattison and to a lesser
10 extent AECC's Ellis and the small Elkins hydropower plant. Hence, the vast
11 majority of any additional energy charges will flow back to Arkansas utilities
12 and their ratepayers.

13 **B. Short-term Local Alternatives**

14 **Q: Are there additional local resources that could be deployed in northwest**
15 **Arkansas to improve reliability?**

16 A: Yes. Those options would include

- 1 • targeted energy-efficiency programs, using higher incentives, increased
2 local marketing, and direct installation to accelerate participation in retrofit
3 programs in northwest Arkansas;
4 • increases in load management programs, which can include dimming of
5 lighting and resetting of thermostats in commercial building at times of
6 peak demand;
7 • increases in interruptible contracts;
8 • enrollment of emergency generation as a demand-response measure to
9 reduce load under extreme loads and contingency conditions; and
10 • encouraging installation of combined heat and power (CHP) for customers
11 with water-heating and other thermal loads.

12 **Q: Does this conclude your testimony?**

13 A: Yes.

CERTIFICATE OF SERVICE

I, Derek Nelson, do hereby certify that on the 14th of March, 2013, a true and correct copy of the foregoing Sierra Club's public Second Supplemental Rebuttal Testimony and Exhibits of Paul Chernick were electronically filed with the Arkansas Public Service Commission, and electronically served by EFS upon all parties on the service list for this docket. Confidential versions of these documents are being filed with the Commission and will served upon all parties by next-day mail.

Valerie Boyce
APSC General Staff
1000 Center Street
Little Rock, AR 72204
valerie_boyce@psc.state.ar.us

Stephen Williams
Arkansas Electric Cooperative Corp.
PO Box Little Rock, AR 72219
steve.williams@aecc.com

Emon O. Mahony
Assistant Attorney General
323 Center St., Ste. 200
Little Rock, AR 72201
emon.mahony@arkansasag.gov

M. Shawn McMurray
Senior Assistant Attorney General
323 Center St., Ste. 200
Little Rock, AR 72201
shawn.mcmurray@arkansasag.gov

Forrest Kessinger
1 Cooperative Way
Little Rock, AR 72218
fkessinger@aecc.com

Dave Slaton
APSC Commissioners' Staff
1000 Center Street
Little Rock, AR 72204
dslaton@psc.state.ar.us

Stephen Cuffman
Southwest Electric Power Company
425 West Capitol, Suite 3801
Little Rock, AR 72201
cuffman@gill-law.com

Hank Steele
Southwest Electric Power Company
1201 Elm Street, Suite 800
Dallas, TX 75270
hcsteele@aep.com

/s/ Derek Nelson

Derek Nelson
Program Assistant
Sierra Club Environmental Law Program
85 Second Street, Second floor
San Francisco, CA 94105
(415) 977-5595
derek.nelson@sierraclub.org