

**TESTIMONY OF ROBERT A. MCMURRY
DIRECTOR, INTEGRATED RESOURCE PLANNING
DUKE ENERGY BUSINESS SERVICES LLC
ON BEHALF OF DUKE ENERGY OF INDIANA, INC.
CAUSE NO. 44217 BEFORE THE
INDIANA UTILITY REGULATORY COMMISSION**

I. INTRODUCTION

1

2 **Q. PLEASE STATE YOUR NAME, BUSINESS ADDRESS, AND OCCUPATION.**

3 A. My name is Robert A. McMurry and my business address is 526 South Church Street,
4 Charlotte, North Carolina. I am Director, Integrated Resource Planning for Duke Energy
5 Business Services LLC, the service company subsidiary of Duke Energy Corporation
6 (collectively "Duke Energy") and an affiliate of Duke Energy Indiana, Inc ("Duke
7 Energy Indiana" or the "Company").

8 **Q. PLEASE DESCRIBE BRIEFLY YOUR EDUCATIONAL AND PROFESSIONAL
9 BACKGROUND.**

10 A. I am a civil engineer, having received a Bachelor of Science in Engineering from the
11 University of North Carolina at Charlotte. I am a registered professional engineer in
12 North Carolina and South Carolina. I am also a member of the Southeastern Electric
13 Exchange Integrated Resource Planning Task Force.

14 I began my career at Duke Power Company in 1982 and have had a variety of
15 responsibilities across Duke Energy in areas of structural design, environmental strategy,
16 emission allowance management and resource planning.

17 **Q. PLEASE DESCRIBE YOUR DUTIES AND RESPONSIBILITIES AS DIRECTOR,
18 INTEGRATED RESOURCE PLANNING.**

19 A. As Director, Integrated Resource Planning, I am responsible for planning for the long-
20 term capacity and energy needs of the Duke Energy operating utilities, including the

ROBERT A. MCMURRY

- 1 -

1 Duke Energy Indiana system. My responsibilities include supervising the preparation
2 and filing of integrated resource plans (“IRPs”) in accordance with state regulations.

3 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY IN THIS PROCEEDING?**

4 A. The purpose of my testimony is to provide results for analyses comparing the installation
5 of environmental controls at Cayuga, Gibson, Gallagher, and Wabash River coal-fired
6 generating stations versus retirement of these assets with natural gas-fired generation as
7 the replacement option. I explain how the Phase 2 environmental controls proposed by
8 Duke Energy Indiana in this proceeding, and the assumed plant retirements are in the best
9 interest of Duke Energy Indiana’s customers, even after accounting for potential
10 additional expenditures from preliminary Phase 3 environmental control projects.

11 **II. DESCRIPTION OF ANALYSES PERFORMED**

12 **Q. WHAT ROLE DID YOU AND YOUR TEAM HAVE IN THE EVALUATION OF**
13 **THE PROPOSED ENVIRONMENTAL CONTROL PROJECTS?**

14 A. My team analyzed the economics of installing environmental controls at the stations
15 versus retirement options. Our analyses are based upon the capital and operation and
16 maintenance information associated with the proposed Phase 2 environmental projects
17 and potential Phase 3 environmental projects provided by the Analytical Engineering
18 department, as outlined in the testimony of Mr. Miller. Using the latest load forecast,
19 energy efficiency and demand response projections, fundamental coal and gas prices and
20 allowance cost projections, my team evaluated the production and capital costs associated
21 with installation of the controls versus retirement of the unit(s) and replacement with
22 natural gas-fired generation over a range of sensitivities.

1 **Q. WHAT INPUTS HAVE CHANGED SINCE THE COMPANY FILED ITS 2011**
2 **IRP?**

3 A. We made the following changes to reflect updated information since the filing of the
4 2011 IRP on November 1, 2011:¹

5 (1) The load forecast was updated from the Spring 2011 to the Spring 2012 version of
6 the load forecast. The Spring 2012 forecast is discussed in greater detail in the testimony
7 of Mr. Merino.

8 (2) The energy efficiency requirements associated with the Commission's Generic DSM
9 Order were included in the load forecast, as discussed by Mr. Merino in his testimony.

10 Updated demand response projections were provided by the Market Analytics department
11 within Duke Energy using current participation information. The demand response
12 programs are input into the model as a dispatchable resource, using the constraints of the
13 DR programs.

14 (3) The reserve margin requirement was updated from 14.2% to 14.9% to correspond to
15 the Midwest Independent Transmission System Operator, Inc. ("MISO") Resource
16 Adequacy Requirement for Planning Year 2012/13, and adjusted for changes to the
17 Resource Adequacy construct beginning with Planning Year 2013/14, which was recently
18 approved by FERC.

19 (4) Prices for natural gas, MISO energy market, coal, and emission allowances
20 (including CO₂) were updated from the Spring 2011 Duke Fundamental Forecast price
21 curves to the Spring 2012 Duke Fundamental Forecast price curves.

¹ A revised version of the 2011 IRP was filed on May 29, 2012, to provide additional information requested by the Commission. The analyses contained in the IRP were not revised.

1 (5) For each environmental project evaluated, the associated capital, fixed and variable
2 O&M cost and heat rate impacts were incorporated into the analysis. To be conservative,
3 we assumed high range reagent consumption rates, and that the controls would be utilized
4 100% of the time that the units were in service. Detailed assumptions are provided in the
5 testimony of Mr. Miller.

6 (6) The capacity rating, capital cost and operating and maintenance costs were updated
7 for new combined cycle and combustion turbine generation options.

8 (7) Economic data, such as inflation and discount rates, allowance for funds used during
9 construction (“AFUDC”) factors, and levelized fixed charge rates were updated.

10 **Q. WHY DID DUKE ENERGY INDIANA PERFORM THESE ANALYSES?**

11 A. Duke Energy Indiana performs these analyses to assure that the Phase 2 environmental
12 projects proposed in this filing are in the best interest of customers, while also taking into
13 account potential costs associated with the preliminary Phase 3 environmental projects.
14 The Phase 2 environmental projects are primarily associated with the Mercury Air Toxics
15 Standard (“MATS”) Rule and the preliminary Phase 3 projects are primarily associated
16 with monitoring, waste water treatment, SO₂ National Ambient Air Quality Standards
17 (“NAAQS”) and coal combustion by-products projected requirements. A description of
18 the various projects evaluated for Cayuga, Gallagher and Gibson is provided in the
19 testimony of Mr. Miller.

20 **Q. WHAT OPTIONS DID DUKE ENERGY INDIANA ANALYZE FOR ITS**
21 **WABASH RIVER GENERATING UNITS?**

22 A. An analysis of anticipated environmental controls versus retirement for Wabash River
23 Units 2-6 was provided in the Duke Energy Indiana 2011 IRP. This analysis was updated

1 for this proceeding to reflect the current assumptions. Because Wabash River 6 is the
2 largest, newest, and most efficient unit at the station, two other options were evaluated in
3 lieu of retirement: 1) derating the unit to 200 MWs with low sulfur coal, and 2)
4 conversion to natural gas. An overview of the environmental control options considered
5 for Wabash River is discussed in the testimony of Mr. Miller.

6 **Q. WHAT OPTIONS DID DUKE ENERGY INDIANA ANALYZE FOR ITS GIBSON**
7 **5 GENERATING UNIT?**

8 A. Duke Energy Indiana analyzed three options for Gibson 5 because of the compliance
9 uncertainty associated with SO₂ NAAQS. The Phase 2 requirements are the same for
10 each option; however, the Phase 3 requirements differ depending on the final SO₂
11 NAAQS requirements, as discussed by Mr. Miller. An overview of the potential Phase 3
12 options for Gibson 5 is presented below:

- 13 1. The existing FGD can meet the new SO₂ NAAQS with structural repairs. A range of
14 costs were evaluated to represent the conditions if a new stack is required or if the
15 existing stack can be repaired.
- 16 2. A new FGD is required to meet the SO₂ NAAQS.
- 17 3. The Phase 2 controls are installed but Gibson 5 is retired at the end of 2017 and
18 replaced with combined cycle gas-fired generation. The purpose of analyzing this
19 option is to assure that installation of the Phase 2 controls is in the best interest of
20 customers regardless of whether Gibson Unit 5 ultimately installs Phase 3
21 environmental controls or is retired by the end of 2017.

22 A description of regulatory requirements associated with these controls is
23 included in the testimony of Mr. Miller.

1 **Q. WHAT SENSITIVITIES DID YOU INCLUDE IN THE EVALUATION OF**
2 **PROPOSED PHASE 2 PROJECTS AT CAYUGA, GIBSON, GALLAGHER AND**
3 **WABASH RIVER?**

4 A. A range of sensitivities was evaluated for environmental control options at Cayuga,
5 Gibson, Gallagher and Wabash River, as described below:

6 1. Capital Cost of Environmental Controls – a 20% increase and a 5% decrease of the
7 cost for major capital components. The basis for the range of capital costs is
8 addressed in the testimony of Mr. Renner.

9 2. Fuel Prices

10 a. High Fuel Cost –gas prices +35% and coal prices +20%. The base case
11 natural gas price projection is on the lower end of the range generated from
12 multiple vendor estimates. In general, we believe there is more upside risk
13 associated with natural gas because of the potential that suppliers could limit
14 new drilling until there is a higher supporting price. We are observing this in
15 today’s market where suppliers are limiting new gas well installations due to
16 the current low natural gas price. The +35% high gas sensitivity was based on
17 two standard deviations off the mean based on the multiple vendor estimates.

18 The Company examined the potential for increased coal prices
19 primarily because of the risk of increased international exports. If carbon
20 regulations are delayed from our current projection of 2020, this could also
21 increase demand and the resulting price for coal. The +20% coal price
22 sensitivity generally follows the upper range of vendor estimates.

1 The energy market prices were also updated to reflect this increase in
2 the projected fuel prices since market prices typically follow fuel prices.

- 3 b. Low Fuel Cost –gas prices -20% and coal prices -40%. As stated above, our
4 fundamental natural gas price projection is on the lower end of a range of
5 vendor estimates. Also, the current reduction in drilling and hedging by gas
6 suppliers limits our downside gas price forecast. The -20% low gas sensitivity
7 was based on two standard deviations off the mean based on the multiple
8 vendor estimates.

9 The Company believes it is reasonable to analyze the potential for
10 lower coal prices because of the significantly lower demand projection by the
11 coal industry driven by coal retirements in the 2015 timeframe, fundamentally
12 lower gas prices that offset coal generation, and additional longer-term
13 retirements based on pending environmental regulations. As the price for
14 natural gas decreases, the demand increases and this normally results in a
15 decrease in the demand for coal and therefore a decrease in coal prices. The
16 -40% coal price sensitivity generally follows the lower range of vendor
17 estimates.

18 The energy market prices were also updated to reflect this decrease in
19 the projected fuel prices.

- 20 3. No Carbon – While the Company continues to believe it is likely that there will be a
21 carbon constrained future, the timing and structure are very uncertain. The CO₂
22 projection used for base planning starts in 2020 in nominal dollars at \$17/ton CO₂,
23 increasing to \$44/ton by 2032. To gauge carbon’s impact on the Present Value of

1 Revenue Requirements (“PVRR”) of continuing to operate units with coal versus
2 retirement and replacement with natural gas, a no CO₂ sensitivity was performed.

3 This sensitivity is a proxy for a future with carbon legislation delayed beyond 2020 or
4 implemented in another way that does not explicitly incorporate a price on carbon
5 emissions.

6 4. Load Forecast – The High and Low load forecast sensitivities were limited to Cayuga
7 Units 1 and 2 and Gibson Unit 5 to limit the number of expansion plans. For these
8 units, changes in the load forecast can impact the cost-effectiveness of the choice
9 between installing environmental controls vs. retirement and replacement with natural
10 gas generation. The basis for these sensitivities, which represent a 95% confidence
11 interval, is addressed in the testimony of Mr. Merino. These sensitivities can also be
12 considered proxies for lower or higher levels of EE and/or renewables.

13 5. Capital Cost of New Combined Cycle Units – Because the cost of replacement
14 capacity is an integral part of the economic decision regarding whether to invest in
15 environmental controls, sensitivities were performed using a 30% increase and a 5%
16 decrease of the cost of new Combined Cycle (“CC”) units. The basis for the range of
17 capital costs is addressed in the testimony of Mr. Miller.

18 **Q. WHAT PROCESS DID YOU FOLLOW TO PERFORM THE EVALUATION OF**
19 **THE PHASE 2 AND PRELIMINARY PHASE 3 PROJECTS?**

20 A. The evaluation of the Phase 2 and preliminary Phase 3 environmental projects at Cayuga,
21 Gibson, and Gallagher, along with the update to the environmental analysis of Wabash
22 River, was performed with the latest 2012 assumptions. An overview of the steps taken
23 to perform the analysis is shown below:

1 1. The data inputs to the production cost model and economic analysis
2 spreadsheets were updated as described above.

3 2. Economic Analysis

4 a. Expansion plans were developed for two cases: 1) continuing to
5 operate each unit under evaluation with environmental controls, and 2)
6 retiring the unit and replacing it with natural gas generation. Based on
7 the historical operation of the units evaluated for this analysis, it was
8 assumed that Cayuga and Gibson Stations were replaced with
9 combined cycle generation and Wabash River and Gallagher Stations
10 were replaced with combustion turbine generation. A supply/demand
11 balance spreadsheet analysis was used to develop the expansion plans
12 needed to meet the reserve margin criteria. To verify that the proper
13 replacement technology was selected, sensitivities were performed
14 replacing the combined cycle generation with combustion turbine
15 generation for the Cayuga and Gibson Stations, and replacing the
16 combustion turbine generation with combined cycle generation at the
17 Wabash River and Gallagher Stations. The results of the Cayuga and
18 Gibson sensitivities demonstrated that the combined cycle replacement
19 generation option was lower cost than replacement with a combustion
20 turbine. For Wabash River and Gallagher, the replacement option with
21 a combustion turbine or combined cycle was approximately
22 breakeven. Based on the projected low capacity factors of the Wabash

1 River and Gallagher units, a combustion turbine was selected as the
2 replacement option.

3 b. The Ventyx Prosym model was used to develop the production costs
4 for each of the compliance equipment and retire/replace cases, as well
5 as the sensitivity cases.

6 c. The total PVRR was determined for Cayuga, Gibson, Gallagher, and
7 Wabash River by incorporating both production and capital costs
8 associated with environmental controls in a spreadsheet. This revenue
9 requirement was then compared to the PVRR assuming the unit was
10 retired and replaced with natural gas-fired generation.

11 **Q. DID DUKE ENERGY INDIANA EXPLICITLY CONSIDER RENEWABLE**
12 **ENERGY RESOURCES IN ITS ANALYSES OF THE PHASE 2 COMPLIANCE**
13 **PLAN?**

14 A. Yes. Consistent with the 2011 IRP, an assumption was made that 10% of retail sales
15 would be met with renewable energy sources by 2025, starting in 2016 at 1.0% and
16 increasing 1.0% per year through 2025 to be met primarily with wind, solar, biomass and
17 landfill gas.

18 **Q. DID DUKE ENERGY INDIANA CONSIDER THE PURCHASE OF POWER IN**
19 **ITS ANALYSES?**

20 A. Yes. While we did not explicitly consider purchased power as an option for replacement
21 of coal-fired generation in this analysis, the new build natural gas replacement options are
22 proxies for purchases.

1 **Q. PLEASE DISCUSS THE STATUS OF THE REQUEST FOR PROPOSALS**
2 **(“RFP”) THAT DUKE ENERGY INDIANA ISSUED IN FEBRUARY 2012.**

3 A. The Company issued an RFP for purchased power for a period of one to three years,
4 starting with Planning Year 2014/15, as a stop-gap measure until longer-term capacity
5 could be built or acquired. The RFP was issued primarily due the expected retirement of
6 Wabash River Units 2-6 in April 2015, as a result of the MATS rule, which was
7 discussed in Duke Energy Indiana’s 2011 IRP. The expected retirements were projected
8 to result in a need for 300-400 MW of additional capacity to meet the MISO Resource
9 Adequacy requirement. Five bids were received, three of which have been short-listed as
10 candidates for further analysis and discussion. We are continuing to evaluate our need
11 for short-term capacity and expect to make a decision regarding these bids later this year.

12 We are also evaluating multiple options to meet the longer-term need, including
13 self build options, purchase of existing assets, natural gas conversion, and purchased
14 power agreements.

15 **III. ANALYSES RESULTS**

16 **Q. WHAT WERE THE RESULTS OF YOUR ANALYSES?**

17 A. The results of the Phase 2 and preliminary Phase 3 environmental analysis incorporating
18 the range of sensitivities and the corresponding changes in the expansion plans are
19 summarized in the following Exhibits attached to my testimony:

- 20 • Cayuga
 - 21 ○ Exhibit F-1 – Cayuga Unit 1
 - 22 ○ Exhibit F-2 – Cayuga Unit 2
 - 23 ○ Exhibit F-3 – Cayuga Units 1 and 2 Total

- 1 ○ Exhibit F-4 – Cayuga 1-2 Expansion Plans
- 2 ○ Exhibit F-5 – Cayuga 1-2 High Load Expansion Plans
- 3 ○ Exhibit F-6 – Cayuga 1-2 Low Load Expansion Plans
- 4 ● Gibson Units 1-4
 - 5 ○ Exhibit F-7 – Gibson Unit 1
 - 6 ○ Exhibit F-8 – Gibson Unit 2
 - 7 ○ Exhibit F-9 – Gibson Unit 3
 - 8 ○ Exhibit F-10 – Gibson Unit 4
 - 9 ○ Exhibit F-11 – Gibson 1-4 Expansion Plans
- 10 ● Gibson Unit 5
 - 11 ○ Exhibit F-12 – Gibson Unit 5 New FGD
 - 12 ○ Exhibit F-13 – Gibson Unit 5 Existing FGD (New Stack)
 - 13 ○ Exhibit F-14 – Gibson Unit 5 Existing FGD and Stack
 - 14 ○ Exhibit F-15 – Gibson Unit 5 Phase 2 Controls, Retire 2017
 - 15 ○ Exhibit F-16 – Gibson 5 Expansion Plans
 - 16 ○ Exhibit F-17 – Gibson 5 High Load Expansion Plans
 - 17 ○ Exhibit F-18 – Gibson 5 Low Load Expansion Plans
- 18 ● Gallagher Units 2 and 4
 - 19 ○ Exhibit F-19 – Gallagher Unit 2
 - 20 ○ Exhibit F-20 – Gallagher Unit 4
 - 21 ○ Exhibit F-21 – Gallagher 2 and 4 Expansion Plans


1 The results of the Wabash River Units 2-6 retirement analysis and the option to
2 convert Wabash River 6 to natural gas are shown in the following Exhibits, which are
3 attached to my testimony:

- 4 • Wabash River
 - 5 ○ Exhibit F-22 – Wabash River Unit 2-5
 - 6 ○ Exhibit F-23 – Wabash River Unit 6
 - 7 ○ Exhibit F-24 – Wabash River Unit 6 Natural Gas Conversion
 - 8 ○ Exhibit F-25 – Wabash River Unit 6 Derate 3 Year Life
 - 9 ○ Exhibit F-26 – Wabash River Unit 6 Derate 14 Year Life
 - 10 ○ Exhibit F-27 – Wabash River Expansion Plans

11 The results for each station will be discussed in more detail below.

12 **Q. PLEASE DISCUSS THE RESULTS OF YOUR ANALYSES FOR CAYUGA.**


13 A. The Cayuga Phase 2 and preliminary Phase 3 environmental projects were evaluated on
14 an individual unit basis and on a total basis. The capital cost associated with Cayuga
15 Unit 1 is expected to be higher than Cayuga Unit 2 primarily due to incorporating the
16 engineering cost and shared system cost of both units for several of the environmental
17 projects into Unit 1's cost. The project cost separation for each unit is provided in the
18 testimony of Mr. Miller. An overview over the range of sensitivities is shown in Figure 1
19 below:



2 Although I have shown the economics for the Cayuga units separately, the
3 combined Cayuga Units 1 and 2 analysis is the proper way to view the economics due to
4 the shared cost allocations. The modeling shows that installation of Phase 2 and
5 currently expected Phase 3 controls on Cayuga Units 1 and 2 is cost effective by 0.45%
6 versus retirement and replacement with combined cycle generation on a total system
7 PVRR basis. The installation of Phase 2 and currently expected Phase 3 environmental
8 controls on Cayuga is also the most cost effective option versus retirement in all of the
9 sensitivities, ranging from 0.21 % in the High Environmental Capital cost scenario to
10 2.64% when excluding the impacts of CO₂.

11 **Q. PLEASE DISCUSS THE RESULTS OF YOUR ANALYSES FOR GIBSON 1-4.**


1 A. Gibson Units 1, 2, 3 and 4 already have advanced FGDs for SO₂ control and SCRs for
 2 NO_x control that position them well for future environmental regulatory requirements.
 3 The Phase 2 and preliminary Phase 3 control options for these units focused mainly on
 4 upgrades to existing equipment, reagent injection equipment, monitoring and ash
 5 collection and disposal. Each unit was evaluated separately. An overview over the range
 6 of sensitivities is shown in Figure 2 below:
 7



8 In the base case and over the range of sensitivities, installation of Phase 2 and
 9 preliminary Phase 3 controls is more cost effective than retirement and replacement with
 10 combined cycle generation by more than 0.73% based on total system PVRR.

11 **Q. PLEASE DISCUSS THE RESULTS OF YOUR ANALYSES FOR GIBSON 5.**

1 A. Gibson Unit 5 has an older vintage FGD for SO₂ control that was installed in 1982 and a
 2 SCR for NO_x control installed to meet the NO_x SIP call requirements. Depending on the
 3 final environmental requirements discussed by Mr. Geers and Mr. Miller, the existing
 4 FGD could be refurbished or a new FGD may be required for compliance. An overview
 5 for each option evaluated for Gibson 5 over the range of sensitivities is shown in Figure 3
 6 below:
 7



8 A range of options for the control of SO₂ was considered for Gibson 5 in addition to the
 9 other Phase 2 and preliminary Phase 3 requirements including:

- 10 1. Gibson Unit 5 New FGD for SO₂ Control - The results of the analysis including a
 11 new FGD for SO₂ control for Gibson Unit 5 is shown in Petitioner’s Exhibit F-12.

1 In the base case, the option to retire and replace the unit with combined cycle is
2 0.48% better than the installation of Phase 2 and preliminary Phase 3
3 environmental controls with a new FGD on a system PVRR basis. The only
4 sensitivity where the installation was better than retirement and replacement with
5 a CC was the no CO₂ sensitivity. In this case, the environmental control option
6 was better than retirement and replacement with a CC by 0.17%.

7 2. Gibson Unit 5 Refurbishment of the Existing FGD with a New Stack - In the base
8 case, the retirement and replacement of Gibson 5 with CC generation is 0.11%
9 more cost effective than the refurbishment of the existing FGD with a new stack,
10 based on the system PVRR. However, in the high and low fuel cost, no CO₂, and
11 higher CC capital cost sensitivities, the refurbishment of the existing FGD is
12 better than retirement and replacing with a CC.

13 3. Gibson Unit 5 Refurbishment of Both the Existing FGD and Stack - In the base
14 case, the retirement and replacement of Gibson 5 with CC generation is 0.03%
15 more cost effective than the refurbishment of the existing FGD on a system
16 revenue requirement basis. However, in the high and low fuel cost, no CO₂, and
17 higher CC capital cost sensitivities, the refurbishment of the existing FGD is
18 better than retirement and replacing with a CC. In both refurbishment options, the
19 difference in system PVRR is about breakeven with retirement and replacement
20 with combined cycle generation.

21 Due to the uncertainty of the final environmental requirements and the resulting
22 range of outcomes for Gibson 5, an additional analysis was performed to determine if it
23 remains cost effective to install the Phase 2 environmental controls on Gibson Unit 5 if

1 the Phase 3 analyses show that the unit should be retired by the end of 2017. This option
2 was compared to retirement in 2015 and replacement with CC generation without the
3 Phase 2 environmental controls. In the base case, the installation of Phase 2
4 environmental controls is 0.10% more cost effective than retirement and replacing with a
5 CC in 2015 on a system PVRR basis. Over the range of sensitivities, the installation of
6 Phase 2 environmental controls was better than retirement and replacement with a CC in
7 2015 ranging from 0.08% in the low CC capital cost sensitivity to 0.16% in the low fuel
8 price sensitivity. In other words, even if it turns out that Gibson 5 needs to be retired by
9 2017, the environmental controls that Duke Energy Indiana is proposing in its Phase 2
10 plan in this proceeding are still more economic than retiring Gibson 5 earlier in 2015
11 (which would be required if we did not add the proposed environmental controls).

12 The bids received from the RFP were also considered as a replacement for Gibson
13 5 if only Phase 2 environmental controls are installed and the unit is then retired by the
14 end of 2017. Only one of the bids was comparable in operability and size to Gibson 5.
15 The projected fixed O&M and Phase 2 environmental control capital for Gibson 5 to
16 continue to operate through 2017 was less than the capacity charge of the comparable
17 bid. Gibson 5 also has a lower projected operating cost including the Phase 2
18 environmental controls in the 2015 to 2017 timeframe than the comparable bid. Based on
19 this review, capacity options received from this RFP are not lower cost than continuing to
20 operate Gibson 5 with Phase 2 controls through 2017.


21 In summary, the decision to upgrade the existing scrubber at Gibson Unit 5 or
22 install a new FGD does not need to be made until 2013. The Company's analysis also
23 shows the Phase 2 controls are cost effective even if the unit is retired at the end of 2017

1 and replaced with a CC. Installation of these Phase 2 controls preserves the option of
2 continuing to operate the unit longer-term while we await the outcome of the NAAQS
3 and other regulatory uncertainties.

4 **Q. PLEASE DISCUSS THE RESULTS OF YOUR ANALYSES FOR GALLAGHER 2**
5 **& 4.**

6 A. Gallagher Units 2 and 4 already have baghouses and dry ash handling systems installed
7 that allow for some level of SO₂ and mercury control that position them well for future
8 environmental regulatory requirements. The Phase 2 and preliminary Phase 3
9 environmental control options for these units focused mainly on activated carbon
10 injection, monitoring, waste water treatment, bottom ash collection and disposal and the
11 potential for additional NO_x reduction.

12 An overview over the range of sensitivities is shown in Figure 4 below:



1

2

3

4

5

6

Q. PLEASE DISCUSS THE RESULTS OF YOUR ANALYSES FOR WABASH RIVER.

7

8

A. Wabash River Units 2-6 do not have any advanced environmental controls and have significant risk of incurring additional costs associated with the MATS rule in 2015 and, longer-term, the new SO₂ NAAQS, and emerging water and coal combustion by-product regulations if they continue to operate on coal. The control options considered for Wabash River 2-5 and for Wabash River 6 are discussed in Mr. Miller's testimony.

9


10

11

12

1 An overview over the range of sensitivities is shown in Figure 5 below:

2



3 The retirement of Wabash River 2-5 and replacement with Combustion Turbine
4 generation is more cost effective by 1.23% than the installation of environmental
5 controls. The results were similar for the Wabash River 6 retirement option, which is
6 more cost effective by 1.12% than the installation of environmental controls.

7 Two other options were considered in lieu of retirement for Wabash River Unit 6:

- 8 1. Conversion to Natural Gas
- 9 2. Switch to low sulfur coal and derate to 200 MWs.

10 In the Natural Gas Conversion case, Wabash Unit 6 converted to natural gas was
11 compared to replacement with a combustion turbine. Based on a projected 10-year life

1 for the converted unit, the conversion to natural gas was more cost effective than
2 retirement and replacement with a combustion turbine by 0.09% on a system PVRR
3 basis. A reduced life of 10 years was used because there is a risk of additional
4 expenditures due to the age of the unit and potential environmental regulations that could
5 impact the unit. Detailed engineering and cost estimates have not yet been developed for
6 this option; however, this initial analysis demonstrates this could be a viable alternative
7 for meeting the capacity need in the 2016 timeframe. Once we have completed
8 additional detailed engineering and analyses and made decisions concerning Wabash
9 River 6, we will come back to this Commission for the appropriate approvals (whether
10 for retirement or conversion).

11 Derating Wabash River Unit 6 to 200 MWs and switching coal types was also
12 evaluated as a low capital cost option to retirement. It was evaluated for a three-year life,
13 which assumes retirement before significant water and coal combustion by-product
14 modifications are expected to be required and over a fourteen year life incorporating
15 these costs. The analysis of the three-year life of the converted unit, demonstrated that
16 the retirement in 2015 and replacement with a combustion turbine was more cost
17 effective than derating Wabash River Unit 6 and then retiring it at the end of 2017 by
18 0.10% on a system PVRR basis. The analysis of the 14-year life, incorporating the water
19 and coal combustion by-product costs, demonstrated that the retirement in 2015 and
20 replacement with a combustion turbine was more cost effective than derating Wabash
21 River Unit 6 by 0.38% on a system PVRR basis. In addition, a preliminary assessment of
22 this option does not show conclusively that the derate option would meet the MATS
23 requirements in 2015.

1 **IV. CONCLUSIONS**

2 **Q. BASED ON YOUR ANALYSES, DO YOU BELIEVE THAT INCURRING THE**
3 **PHASE 2 ENVIRONMENTAL COSTS IS THE MOST REASONABLE OPTION**
4 **FOR SERVING THE CAPACITY AND ENERGY NEEDS OF DUKE ENERGY**
5 **INDIANA’S CUSTOMERS?**

6 A. Yes, my team’s analyses demonstrate that proposed Phase 2 environmental projects at
7 Cayuga Units 1-2, Gibson Units 1-4, and Gallagher Units 2 and 4 are cost effective, even
8 after taking into account the projected costs of the preliminary Phase 3 environmental
9 projects.

10 In addition, the Phase 2 projects for Gibson 5 are in the best interest of Duke
11 Energy Indiana customers over a variety of analyses. Multiple options were considered
12 for Gibson 5 including structural upgrades to the existing FGD, replacement of the
13 existing FGD with a new FGD, and the installation of Phase 2 environmental projects and
14 retirement at the end of 2017. Again, I want to emphasize that the decision to upgrade
15 the existing FGD, install a new FGD, or retire and replace with natural gas combined
16 cycle generation will not be made until there is clarity with regard to the compliance
17 requirements associated with the SO₂ NAAQS. However, our analysis shows that the
18 Phase 2 cost is justified under any of the potential outcomes reviewed.

19 These analyses confirm the findings in the 2011 IRP that retirement of Wabash
20 River 2-6 and replacement with combustion turbine generation is more cost effective than
21 installing controls and continuing to operate on coal. However, these analyses
22 demonstrate that the conversion Wabash River 6 to natural gas could be a cost effective

1 alternative to retirement. Again, no final decision on this has yet been made, detailed
2 engineering has not yet been performed and the results of this analysis were provided in
3 this proceeding for informational purposes.

4 In conclusion, our analyses support the Company's proposed Phase 2 projects for
5 Cayuga 1 and 2, Gallagher 2 and 4, and Gibson 1 – 5.

6 **Q. WERE PETITIONER'S EXHIBITS F-1 THROUGH F-27 PREPARED BY YOU**
7 **OR AT YOUR DIRECTION?**

8 A. Yes.

9 **Q. DOES THIS CONCLUDE YOUR TESTIMONY?**

10 A. Yes.

Petitioner's Exhibit F-1
Cayuga Unit 1
(Phase 2 and Preliminary Phase 3 Compliance Plans)

Summary of Total System Costs (PVRR 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Control Cayuga 1 Retire Cayuga 1, Replace with Combined Cycle			0.10%
1a	High Fuel, Market Prices	Control Cayuga 1 Retire Cayuga 1, Replace with Combined Cycle			0.68%
1b	Low Fuel, Market Prices	Control Cayuga 1 Retire Cayuga 1, Replace with Combined Cycle			0.40%
1c	High Env. Capital	Control Cayuga 1 Retire Cayuga 1, Replace with Combined Cycle			-0.03%
1d	Low Env. Capital	Control Cayuga 1 Retire Cayuga 1, Replace with Combined Cycle			0.15%
1e	No CO2	Control Cayuga 1 Retire Cayuga 1, Replace with Combined Cycle			1.09%
1f	High CC Capital	Control Cayuga 1 Retire Cayuga 1, Replace with Combined Cycle			0.58%
1g	Low CC Capital	Control Cayuga 1 Retire Cayuga 1, Replace with Combined Cycle			0.01%
1h	High Load	Control Cayuga 1 Retire Cayuga 1, Replace with Combined Cycle			0.11%
1i	Low Load	Control Cayuga 1 Retire Cayuga 1, Replace with Combined Cycle			-0.08%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-2
Cayuga Unit 2
(Phase 2 and Preliminary Phase 3 Compliance Plans)

Summary of Total System Costs (PVRR 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Control Cayuga 2 Retire Cayuga 2, Replace with Combined Cycle			0.28%
1a	High Fuel, Market Prices	Control Cayuga 2 Retire Cayuga 2, Replace with Combined Cycle			0.83%
1b	Low Fuel, Market Prices	Control Cayuga 2 Retire Cayuga 2, Replace with Combined Cycle			0.64%
1c	High Env. Capital	Control Cayuga 2 Retire Cayuga 2, Replace with Combined Cycle			0.17%
1d	Low Env. Capital	Control Cayuga 2 Retire Cayuga 2, Replace with Combined Cycle			0.33%
1e	No CO2	Control Cayuga 2 Retire Cayuga 2, Replace with Combined Cycle			1.32%
1f	High CC Capital	Control Cayuga 2 Retire Cayuga 2, Replace with Combined Cycle			0.76%
1g	Low CC Capital	Control Cayuga 2 Retire Cayuga 2, Replace with Combined Cycle			0.20%
1h	High Load	Control Cayuga 2 Retire Cayuga 2, Replace with Combined Cycle			0.31%
1i	Low Load	Control Cayuga 2 Retire Cayuga 2, Replace with Combined Cycle			0.13%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-3
Cayuga Unit 1 and 2 Combined
(Phase 2 and Preliminary Phase 3 Compliance Plans)

Summary of Total System Costs (PVRR 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Control Cayuga 1&2 Retire Cayuga 1&2, Replace with Combined Cycle			0.45%
1a	High Fuel, Market Prices	Control Cayuga 1&2 Retire Cayuga 1&2, Replace with Combined Cycle			1.66%
1b	Low Fuel, Market Prices	Control Cayuga 1&2 Retire Cayuga 1&2, Replace with Combined Cycle			1.14%
1c	High Env. Capital	Control Cayuga 1&2 Retire Cayuga 1&2, Replace with Combined Cycle			0.21%
1d	Low Env. Capital	Control Cayuga 1&2 Retire Cayuga 1&2, Replace with Combined Cycle			0.55%
1e	No CO2	Control Cayuga 1&2 Retire Cayuga 1&2, Replace with Combined Cycle			2.64%
1f	High CC Capital	Control Cayuga 1&2 Retire Cayuga 1&2, Replace with Combined Cycle			1.41%
1g	Low CC Capital	Control Cayuga 1&2 Retire Cayuga 1&2, Replace with Combined Cycle			0.29%
1h	High Load	Control Cayuga 1&2 Retire Cayuga 1&2, Replace with Combined Cycle			0.46%
1i	Low Load	Control Cayuga 1&2 Retire Cayuga 1&2, Replace with Combined Cycle			0.26%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-4

Cayuga Unit 1 and 2 Phase 2 and Preliminary Phase 3 Compliance - Expansion Plans

Control Cayuga 1 & 2

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,114	-280			-668						-166											
New CC	700										350						350					
New CT	673					201								201						201		70
Reserve Margin		18.5%	27.2%	26.1%	15.2%	16.5%	16.9%	17.0%	16.9%	17.4%	19.2%	17.2%	16.1%	17.5%	16.6%	15.7%	19.5%	16.9%	15.6%	16.4%	15.6%	15.8%

Retire Cayuga 1, Replace with Combined Cycle and Control Cayuga 2

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,604	-280			-1158						-166											
New CC	1,190				490						350						350					
New CT	668					201								201						201		65
Reserve Margin		18.5%	27.2%	26.1%	15.2%	16.5%	16.9%	17.1%	16.9%	17.5%	19.2%	17.3%	16.2%	17.6%	16.7%	15.7%	19.5%	16.9%	15.6%	16.4%	15.7%	15.8%

Retire Cayuga 2, Replace with Combined Cycle and Control Cayuga 1

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,599	-280			-1153						-166											
New CC	1,185				485						350						350					
New CT	668					201								201						201		65
Reserve Margin		18.5%	27.2%	26.1%	15.2%	16.5%	16.9%	17.1%	16.9%	17.5%	19.2%	17.3%	16.2%	17.6%	16.7%	15.7%	19.5%	16.9%	15.6%	16.4%	15.7%	15.8%

Retire Cayuga 1 and 2 and Replace with Combined Cycle

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,604	-280			-1,643						-166											
New CC	1,675				975						350						350					
New CT	668					201								201						201		65
Reserve Margin		18.5%	27.2%	26.1%	15.2%	16.5%	16.9%	17.1%	16.9%	17.5%	19.2%	17.3%	16.2%	17.6%	16.7%	15.7%	19.5%	16.9%	15.6%	16.4%	15.7%	15.8%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-5

Cayuga Unit 1 and 2 Phase 2 and Preliminary Phase 3 Compliance - Expansion Plans (High Load)

Control Cayuga 1 & 2

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,114	-280			-668						-166											
New CC	1,400					700							350									
New CT	663										402									201		60
Reserve Margin		15.1%	18.1%	17.0%	15.1%	15.6%	15.9%	15.9%	15.7%	16.1%	18.5%	15.3%	19.3%	17.5%	16.5%	15.6%	18.9%	16.5%	15.2%	15.8%	15.1%	14.9%

Retire Cayuga 1, Replace with Combined Cycle and Control Cayuga 2

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,604	-280			-1158						-166											
New CC	1,890					1,190							350									
New CT	663										402									201		60
Reserve Margin		15.1%	18.1%	17.0%	15.1%	15.6%	15.9%	15.9%	15.7%	16.1%	18.5%	15.3%	19.3%	17.5%	16.5%	15.6%	18.9%	16.5%	15.2%	15.8%	15.1%	14.9%

Retire Cayuga 2, Replace with Combined Cycle and Control Cayuga 1

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,599	-280			-1153						-166											
New CC	1,885					1,185							350									
New CT	663										402									201		60
Reserve Margin		15.1%	18.1%	17.0%	15.1%	15.6%	15.9%	15.9%	15.7%	16.1%	18.5%	15.3%	19.3%	17.5%	16.5%	15.6%	18.9%	16.5%	15.2%	15.8%	15.1%	14.9%

Retire Cayuga 1 and 2 and Replace with Combined Cycle

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-2,089	-280			-1,643						-166											
New CC	2,375					1,675							350									
New CT	663										402									201		60
Reserve Margin		15.1%	18.1%	17.0%	14.9%	15.61%	15.9%	15.9%	15.70%	16.1%	18.5%	15.3%	19.3%	17.5%	16.5%	15.6%	18.9%	16.5%	15.2%	15.8%	15.1%	14.9%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-6

Cayuga Unit 1 and 2 Phase 2 and Preliminary Phase 3 Compliance - Expansion Plans (Low Load)

Control Cayuga 1 & 2

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,114	-280			-668						-166											
New CC	0																					
New CT	603																402			201		
Reserve Margin		26.8%	37.8%	36.7%	25.0%	22.9%	23.4%	23.7%	23.6%	24.3%	20.0%	19.6%	18.5%	16.6%	15.8%	14.9%	20.1%	17.3%	16.0%	17.0%	16.3%	15.7%

Retire Cayuga 1, Replace with Combined Cycle and Control Cayuga 2

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,604	-280			-1158						-166											
New CC	490					490																
New CT	603																402			201		
Reserve Margin		26.8%	37.8%	36.7%	16.0%	22.9%	23.5%	23.7%	23.7%	24.3%	20.1%	19.6%	18.6%	16.7%	15.9%	15.0%	20.2%	17.3%	16.1%	17.1%	16.4%	15.8%

Retire Cayuga 2, Replace with Combined Cycle and Control Cayuga 1

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,599	-280			-1153						-166											
New CC	485					485																
New CT	603																402			201		
Reserve Margin		26.8%	37.8%	36.7%	16.0%	22.8%	23.4%	23.6%	23.6%	24.3%	20.0%	19.5%	18.5%	16.6%	15.8%	14.9%	20.1%	17.3%	16.0%	17.0%	16.3%	15.7%

Retire Cayuga 1 and 2 and Replace with Combined Cycle

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-2,089	-280			-1,643						-166											
New CC	975				975																	
New CT	603																402			201		
Reserve Margin		26.8%	37.8%	36.7%	25.1%	22.91%	23.5%	23.7%	23.70%	24.3%	20.1%	19.6%	18.6%	16.7%	15.9%	15.0%	20.2%	17.3%	16.1%	17.1%	16.4%	15.8%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-7
Gibson Unit 1
(Phase 2 and Preliminary Phase 3 Compliance Plans)

Summary of Total System Costs (PVRR 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Control Gibson 1 Retire Gibson 1, Replace with Combined Cycle			1.13%
1a	High Fuel, Market Prices	Control Gibson 1 Retire Gibson 1, Replace with Combined Cycle			1.93%
1b	Low Fuel, Market Prices	Control Gibson 1 Retire Gibson 1, Replace with Combined Cycle			1.86%
1c	High Env. Capital	Control Gibson 1 Retire Gibson 1, Replace with Combined Cycle			1.12%
1d	Low Env. Capital	Control Gibson 1 Retire Gibson 1, Replace with Combined Cycle			1.13%
1e	No CO2	Control Gibson 1 Retire Gibson 1, Replace with Combined Cycle			3.01%
1f	High CC Capital	Control Gibson 1 Retire Gibson 1, Replace with Combined Cycle			1.82%
1g	Low CC Capital	Control Gibson 1 Retire Gibson 1, Replace with Combined Cycle			1.01%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-8
Gibson Unit 2
(Phase 2 and Preliminary Phase 3 Compliance Plans)

Summary of Total System Costs (PVRR 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Control Gibson 2 Retire Gibson 2, Replace with Combined Cycle			0.95%
1a	High Fuel, Market Prices	Control Gibson 2 Retire Gibson 2, Replace with Combined Cycle			1.75%
1b	Low Fuel, Market Prices	Control Gibson 2 Retire Gibson 2, Replace with Combined Cycle			1.67%
1c	High Env. Capital	Control Gibson 2 Retire Gibson 2, Replace with Combined Cycle			0.94%
1d	Low Env. Capital	Control Gibson 2 Retire Gibson 2, Replace with Combined Cycle			0.96%
1e	No CO2	Control Gibson 2 Retire Gibson 2, Replace with Combined Cycle			2.83%
1f	High CC Capital	Control Gibson 2 Retire Gibson 2, Replace with Combined Cycle			1.65%
1g	Low CC Capital	Control Gibson 2 Retire Gibson 2, Replace with Combined Cycle			0.84%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-9
Gibson Unit 3
(Phase 2 and Preliminary Phase 3 Compliance Plans)

Summary of Total System Costs (PVRR 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Control Gibson 3 Retire Gibson 3, Replace with Combined Cycle			0.95%
1a	High Fuel, Market Prices	Control Gibson 3 Retire Gibson 3, Replace with Combined Cycle			1.72%
1b	Low Fuel, Market Prices	Control Gibson 3 Retire Gibson 3, Replace with Combined Cycle			1.65%
1c	High Env. Capital	Control Gibson 3 Retire Gibson 3, Replace with Combined Cycle			0.93%
1d	Low Env. Capital	Control Gibson 3 Retire Gibson 3, Replace with Combined Cycle			0.95%
1e	No CO2	Control Gibson 3 Retire Gibson 3, Replace with Combined Cycle			2.78%
1f	High CC Capital	Control Gibson 3 Retire Gibson 3, Replace with Combined Cycle			1.63%
1g	Low CC Capital	Control Gibson 3 Retire Gibson 3, Replace with Combined Cycle			0.83%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-10
Gibson Unit 4
Phase 2 and Preliminary Phase 3 Compliance Plans

Summary of Total System Costs (PVRR 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Control Gibson 4 Retire Gibson 4, Replace with Combined Cycle			0.84%
1a	High Fuel, Market Prices	Control Gibson 4 Retire Gibson 4, Replace with Combined Cycle			1.59%
1b	Low Fuel, Market Prices	Control Gibson 4 Retire Gibson 4, Replace with Combined Cycle			1.50%
1c	High Env. Capital	Control Gibson 4 Retire Gibson 4, Replace with Combined Cycle			0.82%
1d	Low Env. Capital	Control Gibson 4 Retire Gibson 4, Replace with Combined Cycle			0.84%
1e	No CO2	Control Gibson 4 Retire Gibson 4, Replace with Combined Cycle			2.54%
1f	High CC Capital	Control Gibson 4 Retire Gibson 4, Replace with Combined Cycle			1.52%
1g	Low CC Capital	Control Gibson 4 Retire Gibson 4, Replace with Combined Cycle			0.73%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-11

Gibson Unit 1 - 4 Phase 2 and Preliminary Phase 3 Compliance - Expansion Plans

Control Gibson 1 - 4

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,114	-280			-668						-166						350					
New CC	700										350											
New CT	673					201								201						201		70
Reserve Margin		18.5%	27.2%	26.1%	15.2%	16.5%	16.9%	17.0%	16.9%	17.4%	19.2%	17.2%	16.1%	17.5%	16.6%	15.7%	19.5%	16.9%	15.6%	16.4%	15.6%	15.8%

Gibson 1 Retirement, Replace with Combined Cycle and Control Gibson 2 - 4

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,114	-280			-1,298						-166						350					
New CC	1,400				700						350											
New CT	603					201									201					201		
Reserve Margin		18.5%	27.2%	26.1%	16.4%	17.6%	18.1%	18.2%	18.0%	18.6%	20.3%	18.3%	17.3%	15.5%	17.7%	16.8%	20.5%	17.9%	16.6%	17.3%	16.6%	15.8%

Gibson 2 Retirement, Replace with Combined Cycle and Control Gibson 1, 3, & 4

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,114	-280			-1,298						-166						350					
New CC	1,400				700						350											
New CT	603					201									201					201		
Reserve Margin		18.5%	27.2%	26.1%	16.4%	17.6%	18.1%	18.2%	18.0%	18.6%	20.3%	18.3%	17.3%	15.5%	17.7%	16.8%	20.5%	17.9%	16.6%	17.3%	16.6%	15.8%

Gibson 3 Retirement, Replace with Combined Cycle and Control Gibson 1, 2, & 4

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,114	-280			-1,298						-166						350					
New CC	1,400				700						350											
New CT	603					201									201					201		
Reserve Margin		18.5%	27.2%	26.1%	16.4%	17.6%	18.1%	18.2%	18.0%	18.6%	20.3%	18.3%	17.3%	15.5%	17.7%	16.8%	20.5%	17.9%	16.6%	17.4%	16.6%	15.8%

Gibson 4 Retirement, Replace with Combined Cycle and Control Gibson 1 - 3

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,114	-280			-1,290						-166						350					
New CC	1,400				700						350											
New CT	603					201									201					190		
Reserve Margin		18.5%	27.2%	26.1%	16.5%	17.8%	18.2%	18.3%	18.2%	18.7%	20.4%	18.5%	17.4%	15.6%	17.8%	16.9%	20.6%	18.0%	16.7%	17.3%	16.6%	15.8%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-12
Gibson Unit 5 (New FGD)
(Phase 2 and Preliminary Phase 3 Compliance Plans)

Summary of Total System Costs (PVRR 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Control Gibson 5 (New FGD) Retire Gibson 5, Replace with Combined Cycle			-0.48%
1a	High Fuel, Market Prices	Control Gibson 5 (New FGD) Retire Gibson 5, Replace with Combined Cycle			-0.08%
1b	Low Fuel, Market Prices	Control Gibson 5 (New FGD) Retire Gibson 5, Replace with Combined Cycle			-0.27%
1c	High Env. Capital	Control Gibson 5 (New FGD) Retire Gibson 5, Replace with Combined Cycle			-0.61%
1d	Low Env. Capital	Control Gibson 5 (New FGD) Retire Gibson 5, Replace with Combined Cycle			-0.45%
1e	No CO2	Control Gibson 5 (New FGD) Retire Gibson 5, Replace with Combined Cycle			0.17%
1f	High CC Capital	Control Gibson 5 (New FGD) Retire Gibson 5, Replace with Combined Cycle			-0.14%
1g	Low CC Capital	Control Gibson 5 (New FGD) Retire Gibson 5, Replace with Combined Cycle			-0.54%
1f	High Load	Control Gibson 5 (New FGD) Retire Gibson 5, Replace with Combined Cycle			-0.33%
1f	Low Load	Control Gibson 5 (New FGD) Retire Gibson 5, Replace with Combined Cycle			-0.61%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-13
Gibson Unit 5 (Existing FGD New Stack)
(Phase 2 and Preliminary Phase 3 Compliance Plans)

Summary of Total System Costs (PVRP 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Control Gibson 5 (New Stack) Retire Gibson 5, Replace with Combined Cycle			-0.11%
1a	High Fuel, Market Prices	Control Gibson 5 (New Stack) Retire Gibson 5, Replace with Combined Cycle			0.23%
1b	Low Fuel, Market Prices	Control Gibson 5 (New Stack) Retire Gibson 5, Replace with Combined Cycle			0.16%
1c	High Env. Capital	Control Gibson 5 (New Stack) Retire Gibson 5, Replace with Combined Cycle			-0.15%
1d	Low Env. Capital	Control Gibson 5 (New Stack) Retire Gibson 5, Replace with Combined Cycle			-0.10%
1e	No CO2	Control Gibson 5 (New Stack) Retire Gibson 5, Replace with Combined Cycle			0.57%
1f	High CC Capital	Control Gibson 5 (New Stack) Retire Gibson 5, Replace with Combined Cycle			0.23%
1g	Low CC Capital	Control Gibson 5 (New Stack) Retire Gibson 5, Replace with Combined Cycle			-0.17%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-14
Gibson Unit 5 (Existing FGD and Stack)
Phase 2 and Preliminary Phase 3 Compliance Plans

Summary of Total System Costs (PVR 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Control Gibson 5 (Refurbish Stack) Retire Gibson 5 Struct Refurb, Replace with Combined Cycle			-0.03%
1a	High Fuel, Market Prices	Control Gibson 5 (Refurbish Stack) Retire Gibson 5 Struct Refurb, Replace with Combined Cycle			0.30%
1b	Low Fuel, Market Prices	Control Gibson 5 (Refurbish Stack) Retire Gibson 5 Struct Refurb, Replace with Combined Cycle			0.25%
1c	High Env. Capital	Control Gibson 5 (Refurbish Stack) Retire Gibson 5 Struct Refurb, Replace with Combined Cycle			-0.06%
1d	Low Env. Capital	Control Gibson 5 (Refurbish Stack) Retire Gibson 5 Struct Refurb, Replace with Combined Cycle			-0.03%
1e	No CO2	Control Gibson 5 (Refurbish Stack) Retire Gibson 5 Struct Refurb, Replace with Combined Cycle			0.67%
1f	High CC Capital	Control Gibson 5 (Refurbish Stack) Retire Gibson 5 Struct Refurb, Replace with Combined Cycle			0.31%
1g	Low CC Capital	Control Gibson 5 (Refurbish Stack) Retire Gibson 5 Struct Refurb, Replace with Combined Cycle			-0.09%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-15
Gibson Unit 5 (Controls in 2015, Retire 2017)
Phase 2 and Preliminary Phase 3 Compliance Plans

Summary of Total System Costs (PVRP 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Controls in 2015, Retire Gibson 5 2017 Retire Gibson 5 2015, Replace with Combined Cycle			0.10%
1a	High Fuel, Market Prices	Controls in 2015, Retire Gibson 5 2017 Retire Gibson 5 2015, Replace with Combined Cycle			0.12%
1b	Low Fuel, Market Prices	Controls in 2015, Retire Gibson 5 2017 Retire Gibson 5 2015, Replace with Combined Cycle			0.16%
1c	High Env. Capital	Controls in 2015, Retire Gibson 5 2017 Retire Gibson 5 2015, Replace with Combined Cycle			0.10%
1d	Low Env. Capital	Controls in 2015, Retire Gibson 5 2017 Retire Gibson 5 2015, Replace with Combined Cycle			0.10%
1e	No CO2	Controls in 2015, Retire Gibson 5 2017 Retire Gibson 5 2015, Replace with Combined Cycle			0.11%
1f	High CC Capital	Controls in 2015, Retire Gibson 5 2017 Retire Gibson 5 2015, Replace with Combined Cycle			0.17%
1g	Low CC Capital	Controls in 2015, Retire Gibson 5 2017 Retire Gibson 5 2015, Replace with Combined Cycle			0.08%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-16

Gibson Unit 5 Phase 2 and Preliminary Phase 3 Compliance - Expansion Plans

Control Gibson 5 - New FGD / Existing FGD with New Stack / Existing FGD and Stack

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,114	-280			-668						-166											
New CC	700				350						350						350					
New CT	673					201								201						201		70
Reserve Margin		18.5%	27.2%	26.1%	15.2%	16.5%	16.9%	17.0%	16.9%	17.4%	19.2%	17.2%	16.1%	17.5%	16.6%	15.7%	19.5%	16.9%	15.6%	16.4%	15.6%	15.8%

Gibson 5 2015 Retirement, Replace with Combined Cycle

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,424	-280			-978						-166											
New CC	1,050				350						350						350					
New CT	633					201								201						201		30
Reserve Margin		18.5%	27.2%	26.1%	15.9%	17.1%	17.6%	17.7%	17.5%	18.1%	19.8%	17.9%	16.8%	18.2%	17.2%	16.3%	20.1%	17.4%	16.2%	16.9%	16.2%	15.8%

Gibson 5 Controls, Retire 2017, Replace with Combined Cycle

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,424	-280			-668			-310			-166											
New CC	1,050							350			350						350					
New CT	633					201								201						201		30
Reserve Margin		18.5%	27.2%	26.1%	15.2%	16.5%	16.9%	17.7%	17.5%	18.1%	19.8%	17.9%	16.8%	18.2%	17.2%	16.3%	20.1%	17.4%	16.2%	16.9%	16.2%	15.8%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-17

Gibson Unit 5 Phase 2 and Preliminary Phase 3 Compliance - Expansion Plans (High Load)

Control Gibson 5 - New FGD

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,114	-280			-668	700					-166		350				350					
New CC	1,400										402									201		60
New CT	663																					
Reserve Margin		15.1%	18.1%	17.0%	15.1%	15.6%	15.9%	15.9%	15.7%	16.1%	18.5%	15.3%	19.3%	17.5%	16.5%	15.6%	18.9%	16.5%	15.2%	15.8%	15.1%	14.9%

Gibson 5 2015 Retirement, Replace with Combined Cycle

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,424	-280			-978	1,050					-166		350				350					
New CC	1,750										402									201		20
New CT	623																					
Reserve Margin		15.1%	18.1%	17.0%	20.0%	16.2%	16.5%	16.6%	16.3%	16.8%	19.1%	15.9%	19.9%	18.1%	17.1%	16.2%	19.5%	17.0%	15.8%	16.3%	15.6%	14.9%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-18

Gibson Unit 5 Phase 2 and Preliminary Phase 3 Compliance - Expansion Plans (Low Load)

Control Gibson 5 - New FGD

	Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,114	-280			-668						-166											
New CC	0																402					
New CT	603																			201		
Reserve Margin		26.8%	37.8%	36.7%	25.0%	22.9%	23.4%	23.7%	23.6%	24.3%	20.0%	19.6%	18.5%	16.6%	15.8%	14.9%	20.1%	17.3%	16.0%	17.0%	16.3%	15.7%

Gibson 5 2015 Retirement, Replace with Combined Cycle

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,424	-280			-978						-166											
New CC	350					350																
New CT	562																402				160	
Reserve Margin		26.8%	37.8%	36.7%	19.3%	23.58%	24.2%	24.4%	24.37%	25.0%	20.7%	20.3%	19.2%	17.3%	16.5%	15.6%	20.8%	17.9%	16.7%	17.0%	16.3%	15.7%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-19
Gallagher Unit 2
(Phase 2 and Preliminary Phase 3 Compliance Plans)

Summary of Total System Costs (PVRR 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Control Gallagher 2 Retire Gallagher 2, Replace with CT			0.43%
1a	High Fuel, Market Prices	Control Gallagher 2 Retire Gallagher 2, Replace with CT			0.37%
1b	Low Fuel, Market Prices	Control Gallagher 2 Retire Gallagher 2, Replace with CT			0.54%
1c	High Env. Capital	Control Gallagher 2 Retire Gallagher 2, Replace with CT			0.42%
1d	Low Env. Capital	Control Gallagher 2 Retire Gallagher 2, Replace with CT			0.44%
1e	No CO2	Control Gallagher 2 Retire Gallagher 2, Replace with CT			0.50%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-20
Gallagher Unit 4
(Phase 2 and Preliminary Phase 3 Compliance Plans)

Summary of Total System Costs (PVRR 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Control Gallagher 4 Retire Gallagher 4, Replace with CT			0.44%
1a	High Fuel, Market Prices	Control Gallagher 4 Retire Gallagher 4, Replace with CT			0.37%
1b	Low Fuel, Market Prices	Control Gallagher 4 Retire Gallagher 4, Replace with CT			0.54%
1c	High Env. Capital	Control Gallagher 4 Retire Gallagher 4, Replace with CT			0.42%
1d	Low Env. Capital	Control Gallagher 4 Retire Gallagher 4, Replace with CT			0.44%
1e	No CO2	Control Gallagher 4 Retire Gallagher 4, Replace with CT			0.51%

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-21

Gallagher Unit 2 and 4 Phase 2 and Preliminary Phase 3 Compliance - Expansion Plans

Control Gallagher 2 and 4

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	
Capacity Retirements	-1,114	-280			-668						-166												
New CC	350																350						
New CT	1,020				201	201					201	201		201						201			15
Reserve Margin		18.5%	27.2%	26.1%	15.2%	16.5%	16.9%	17.0%	16.9%	17.4%	16.7%	18.1%	17.0%	18.4%	17.4%	16.5%	20.2%	17.6%	16.4%	17.1%	16.4%	15.8%	

Gallagher 2 Retirement - Replace with Combustion Turbine and Control Gallagher 4

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	
Capacity Retirements	-1,254	-280			-808						-166												
New CC	350																350						
New CT	1,160				201	201					201		201		201					155			
Reserve Margin		18.5%	27.2%	26.1%	16.2%	17.5%	17.9%	18.0%	17.9%	18.4%	17.7%	15.8%	17.9%	16.2%	18.4%	17.4%	21.2%	18.5%	17.2%	17.3%	16.6%	15.8%	

Gallagher 4 Retirement - Replace with Combustion Turbine and Control Gallagher 2

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	
Capacity Retirements	-1,254	-280			-808						-166												
New CC	350																350						
New CT	1,160				201	201					201		201		201					155			
Reserve Margin		18.5%	27.2%	26.1%	16.2%	17.5%	17.9%	18.0%	17.9%	18.4%	17.7%	15.8%	17.9%	16.2%	18.4%	17.4%	21.2%	18.5%	17.2%	17.3%	16.6%	15.8%	

Note: Plans assume retirement of Wabash River 2-6 in 2015 per the 2011 IRP

Petitioner's Exhibit F-22
Wabash River Unit 2, 3, 4, 5
(Phase 2 and Preliminary Phase 3 Compliance Plans)

Summary of Total System Costs (PVRR 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Control Wabash River 2-5 Retire Wabash River 2-5, Replace with CT			-1.23%
1a	High Fuel, Market Prices	Control Wabash River 2-5 Retire Wabash River 2-5, Replace with CT			-1.12%
1b	Low Fuel, Market Prices	Control Wabash River 2-5 Retire Wabash River 2-5, Replace with CT			-1.39%
1c	High Env. Capital	Control Wabash River 2-5 Retire Wabash River 2-5, Replace with CT			-1.41%
1d	Low Env. Capital	Control Wabash River 2-5 Retire Wabash River 2-5, Replace with CT			-1.19%
1e	No CO2	Control Wabash River 2-5 Retire Wabash River 2-5, Replace with CT			-1.48%

Note: Plans assume retirement of Wabash River 6 in 2015

Petitioner's Exhibit F-23
Wabash River Unit 6
(Phase 2 and Preliminary Phase 3 Compliance Plans)

Summary of Total System Costs (PVRR 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Control Wabash River 6 Retire Wabash River 6, Replace with CT			-1.12%
1a	High Fuel, Market Prices	Control Wabash River 6 Retire Wabash River 6, Replace with CT			-1.02%
1b	Low Fuel, Market Prices	Control Wabash River 6 Retire Wabash River 6, Replace with CT			-1.26%
1c	High Env. Capital	Control Wabash River 6 Retire Wabash River 6, Replace with CT			-1.28%
1d	Low Env. Capital	Control Wabash River 6 Retire Wabash River 6, Replace with CT			-1.08%
1e	No CO2	Control Wabash River 6 Retire Wabash River 6, Replace with CT			-1.33%

Note: Plans assume retirement of Wabash River 2-5 in 2015

Petitioner's Exhibit F-24
Wabash River Unit 6 Natural Gas Conversion
(Phase 2 and Preliminary Phase 3 Compliance Plans)

Summary of Total System Costs (PVRR 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Wabash River 6 Natural Gas Conversion 10 year life Retire Wabash River 6, Replace with CT			0.09%
1a	High Fuel, Market Prices	Wabash River 6 Natural Gas Conversion 10 year life Retire Wabash River 6, Replace with CT			0.08%
1b	Low Fuel, Market Prices	Wabash River 6 Natural Gas Conversion 10 year life Retire Wabash River 6, Replace with CT			0.14%
1c	High Env. Capital	Wabash River 6 Natural Gas Conversion 10 year life Retire Wabash River 6, Replace with CT			0.05%
1d	Low Env. Capital	Wabash River 6 Natural Gas Conversion 10 year life Retire Wabash River 6, Replace with CT			0.10%
1e	No CO2	Wabash River 6 Natural Gas Conversion 10 year life Retire Wabash River 6, Replace with CT			0.11%

Note: Plans assume retirement of Wabash River 2-5 in 2015

Petitioner's Exhibit F-25
Wabash River Unit 6 Low Sulfur Coal Derated to 200 MWs (3 year life)
(Phase 2 and Preliminary Phase 3 Compliance Plans)

Summary of Total Costs (NPV 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Wabash River 6 Low Sulfur Coal 200 MW 3 year life Retire Wabash River 6, Replace with CT			-0.10%
1a	High Fuel, Market Prices	Wabash River 6 Low Sulfur Coal 200 MW 3 year life Retire Wabash River 6, Replace with CT			-0.09%
1b	Low Fuel, Market Prices	Wabash River 6 Low Sulfur Coal 200 MW 3 year life Retire Wabash River 6, Replace with CT			-0.10%
1c	High Env. Capital	Wabash River 6 Low Sulfur Coal 200 MW 3 year life Retire Wabash River 6, Replace with CT			-0.10%
1d	Low Env. Capital	Wabash River 6 Low Sulfur Coal 200 MW 3 year life Retire Wabash River 6, Replace with CT			-0.10%
1e	No CO2	Wabash River 6 Low Sulfur Coal 200 MW 3 year life Retire Wabash River 6, Replace with CT			-0.13%

Note: Plans assume retirement of Wabash River 2-5 in 2015

Petitioner's Exhibit F-26
Wabash River Unit 6 Low Sulfur Coal Derated to 200 MWs (14 year life)
(Phase 2 and Preliminary Phase 3 Compliance Plans)

Summary of Total Costs (NPV 2012-2034)					
			Total Cost (\$Billion)	Delta (\$Million)	Delta
1	Base Case	Wabash River 6 Low Sulfur Coal 200 MW 14yr life Retire Wabash River 6, Replace with CT			-0.38%
1a	High Fuel, Market Prices	Wabash River 6 Low Sulfur Coal 200 MW 14yr life Retire Wabash River 6, Replace with CT			-0.36%
1b	Low Fuel, Market Prices	Wabash River 6 Low Sulfur Coal 200 MW 14yr life Retire Wabash River 6, Replace with CT			-0.40%
1c	High Env. Capital	Wabash River 6 Low Sulfur Coal 200 MW 14yr life Retire Wabash River 6, Replace with CT			-0.44%
1d	Low Env. Capital	Wabash River 6 Low Sulfur Coal 200 MW 14yr life Retire Wabash River 6, Replace with CT			-0.36%
1e	No CO2	Wabash River 6 Low Sulfur Coal 200 MW 14yr life Retire Wabash River 6, Replace with CT			-0.46%

Note: Plans assume retirement of Wabash River 2-5 in 2015

Petitioner's Exhibit F-27

Wabash River Phase 2 and Preliminary Phase 3 Compliance - Expansion Plans

Retire Wabash River 2-6, Replace with a Combustion Turbine

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,114	-280			-668						-166											
New CC	350																350					
New CT	1,020					201					201	201		201						201		15
Reserve Margin		18.5%	27.2%	26.1%	15.2%	16.5%	16.9%	17.0%	16.9%	17.4%	16.7%	18.1%	17.0%	18.4%	17.4%	16.5%	20.2%	17.6%	16.4%	17.1%	16.4%	15.8%

Control Wabash River 2-5 Retire Wabash River 6, Replace with Combustion Turbine

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-764	-280			-318						-166											
New CC	350																350					
New CT	673											201		201		201					70	
Reserve Margin		18.5%	27.2%	26.1%	21.2%	18.94%	19.4%	19.5%	19.35%	19.9%	15.9%	17.2%	16.1%	17.5%	16.6%	18.8%	22.5%	19.8%	18.5%	16.4%	16.6%	15.8%

Control Wabash River 6, Retire WR 2-5, Replace with Combustion Turbine

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-796	-280			-350						-166											
New CC	350																350					
New CT	703										201			201	201					100		
Reserve Margin		18.5%	27.2%	26.1%	20.6%	18.41%	18.8%	19.0%	18.81%	19.4%	18.6%	16.7%	15.6%	17.0%	19.2%	18.3%	22.0%	19.3%	18.1%	17.3%	16.6%	15.8%

Wabash River 6 Gas Conversion, 10 Year Life, Retire WR 2-5, Replace with Combustion Turbine

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-814	-280			-368						-166				-300							
New CC	350																350					
New CT	1,005											201		201	402					201		15
Reserve Margin		18.5%	27.2%	26.1%	20.3%	18.11%	18.5%	18.7%	18.51%	19.1%	15.1%	16.4%	15.4%	16.8%	17.4%	16.5%	20.2%	17.6%	16.4%	17.1%	16.4%	15.8%

Wabash River 6 Derated to 200 MWs 3 year life, Retire Wabash River 2-5, Replace with Combustion Turbine


	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,114	-280			-468			-200			-166											
New CC																	350					
New CT								201			201	201		201						201		15
Reserve Margin		18.5%	27.2%	26.1%	18.6%	16.4%	16.9%	17.0%	16.9%	17.4%	16.7%	18.1%	17.0%	18.4%	17.4%	16.5%	20.2%	17.6%	16.4%	17.1%	16.4%	15.8%

Wabash River 6 Derated to 200 MWs 14 year life, Retire Wabash River 2-5, Replace with Combustion Turbine

	Unit Totals	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032
Capacity Retirements	-1,114	-280			-468						-166								-200			
New CC																	350					
New CT											201	201		201					201	201		15
Reserve Margin		18.5%	27.2%	26.1%	18.6%	16.4%	16.9%	17.0%	16.9%	17.4%	16.7%	18.1%	17.0%	18.4%	17.4%	16.5%	20.2%	17.6%	16.4%	17.1%	16.4%	15.8%

VERIFICATION

I hereby verify under the penalties of perjury that the foregoing representations are true to the best of my knowledge, information and belief.

Signed: 
Robert A. McMurry

Dated: June 21st, 2012