

**BEFORE THE  
PUBLIC SERVICE COMMISSION  
OF MARYLAND**

**IN THE MATTER OF THE APPLICATION OF  
ONEENERGY DORCHESTER, LLC FOR A  
CERTIFICATE OF PUBLIC CONVENIENCE  
AND NECESSITY TO CONSTRUCT A 15.5  
MW SOLAR PHOTOVOLTAIC  
GENERATING FACILITY IN DORCHESTER  
COUNTY, MARYLAND.**

\*  
\*  
\*  
\*

**CASE NO: 9370**

**DIRECT TESTIMONY AND EXHIBITS**

**OF**

**RALPH DE GEETER**

**ON BEHALF OF THE STAFF**

**OF THE**

**PUBLIC SERVICE COMMISSION OF MARYLAND**

**PUBLIC VERSION**

**APRIL 3, 2015**

**TABLE OF CONTENTS**

INTRODUCTION .....1  
SUMMARY CONCLUSIONS AND RECOMMENDATIONS .....2  
TESTIMONY .....3  
CONCLUSIONS .....11

1 **INTRODUCTION**

2 **Q. Please state your name and business address.**

3 A. My name is Ralph De Geeter. My business address is 6 St. Paul Street,  
4 Baltimore, Maryland 21202.

5 **Q. What is your occupation?**

6 A. I am employed by the Public Service Commission of Maryland (“Commission”)  
7 as PSC Generation & Transmission Engineer.

8 **Q. Please describe your educational background and professional experience.**

9 A. My educational background includes a Bachelor of Science Degree in Civil  
10 Engineering from the University of Oklahoma, Norman, Oklahoma, a Master’s  
11 Degree in Business Administration from Loyola University, Chicago, Illinois, and  
12 a post-graduate certificate in corporate finance from the University of Hartford,  
13 West Hartford, Connecticut. I worked in various managerial and senior  
14 management positions for Connecticut Natural Gas Corporation for fifteen years,  
15 during which time I was responsible for planning, acquisition, and operational  
16 control of the Company’s natural gas supply portfolio. My responsibilities  
17 included testifying before state regulatory commissions, and I participated in over  
18 two hundred natural gas and electric dockets before the Federal Energy  
19 Commission in Washington, D.C. From 1989 until 2009 I was Managing  
20 Director of an energy consulting firm providing services to clients on regulatory  
21 issues, management audits of regulated utilities, project development and finance  
22 of natural gas and electric generation projects. I joined the Commission in  
23 December 2009.

24 **Q. Have you previously testified before the Commission?**

1 A. Yes. I have testified and been subject to cross examination before this  
2 Commission and regulatory commissions in the states of Connecticut,  
3 Massachusetts and New York.

4 **Q. What is the purpose of your testimony?**

5 A. The purpose of this testimony is to make a recommendation regarding the effect  
6 that the proposed project will have on the reliability and stability of the electric  
7 system in the State of Maryland. Reliability and stability are two factors the  
8 Commission is required to consider prior to issuing a Certificate of Public  
9 Convenience and Necessity (“CPCN”) pursuant to §§ 7-207 and 7-208 of the  
10 Public Utilities Article of the Annotated Code of Maryland.

## 11 **CONCLUSIONS AND RECOMMENDATIONS**

12 **Q. Please summarize your conclusions and recommendations in this proceeding.**

13 A. After reading the testimony of the Company’s witnesses and performing my own  
14 analysis, I am recommending:<sup>1</sup>

15 (i) The Commission issue the requested CPCN to OneEnergy  
16 Dorchester, LLC for a 15.5 MW solar generating facility and that  
17 any generation capacity in excess of 15.5 MW require the filing of  
18 a new CPCN application with the Commission;

19 (ii) The CPCN require filing with the Commission the signed  
20 Interconnection Service Agreement and Construction Service  
21 Agreement; and

22 (iii) The Commission includes any proposed conditions presented by  
23 the other State agencies having jurisdiction in this proceeding.

---

<sup>1</sup> The Responses of OneEnergy Dorchester, LLC to Staff Data Request No. 1 are attached to this testimony as Exhibit RDG-1 and incorporated by reference.

1 **TESTIMONY**

2 **Q. Please describe the Maryland process for approval of a generation project.**

3 A. The Code of Maryland Regulations (“COMAR”) 20.79 describes the filing  
4 requirements for the interconnection of generation to the grid. The application is  
5 reviewed by several State agencies, each of which presents its findings during  
6 hearings. After the conclusion of the hearing process, the Hearing Examiner will  
7 issue a proposed order granting or denying a CPCN. If granted, the CPCN may  
8 be conditioned on certain requirements. If no one files an appeal within the  
9 appeal period, the proposed order automatically becomes a final Commission  
10 order.

11 **Q. Who is the applicant in this case?**

12 A. OneEnergy Dorchester, LLC (“OED” or “the Project”) is the applicant requesting  
13 issuance of a CPCN in this proceeding and is a wholly-owned subsidiary of  
14 OneEnergy, Inc. d/b/a OneEnergy Renewables (“OneEnergy Renewables” with  
15 offices located in Seattle, Washington and Portland, Oregon. OneEnergy  
16 Renewables is engaged in the development of utility-scale renewable energy  
17 projects.

18 **Q. Please describe the Project identified in the application.**

19 A. OED has proposed a 15.5 MW solar powered generating facility to be located in  
20 Dorchester County, Maryland. The proposed generation facility would provide  
21 approximately 5.89<sup>2</sup> MW of peak capacity for inclusion in PJM Interconnection,  
22 LLC’s (“PJM”) annual Base Residual Auction.

---

<sup>2</sup> PJM’s planning criteria recognizes 38% of the equipment nameplate as the peak hour capacity generation capability of solar facilities. In this case, 15.5 MW times 38% provides approximately 5.89 MW of peak capacity to the PJM system.

1 PJM studied the interconnection request as a 19.5 MW injection into the  
2 Delmarva Power and Light Company (“DPL”) system and evaluated it for  
3 compliance with reliability criteria for summer peak conditions in 2015. The  
4 estimated in-service date of the Project is currently May 2016.

5 The requested interconnection capacity of 19.5 MW into the PJM transmission  
6 system exceeds the CPCN requested project capacity of 15.5 MW identified in  
7 this proceeding. This difference in capacity of approximately 4 MW may provide  
8 an incentive to increase the size of the proposed solar generating facility after  
9 issuance of any CPCN. For this reason, I recommend that a condition be included  
10 in any CPCN issued in this proceeding to require a new CPCN application be  
11 filed for any generating capacity in excess of 15.5 MW.

12 The Project would be located on approximately one-hundred sixteen (116) acres  
13 of agricultural farm land in Dorchester County, Maryland. The Project would  
14 lease the necessary acreage pursuant to a long-term lease with the property owner.

15 **Q. Please describe the process by which generators are connected to the regional**  
16 **transmission system.**

17 A. The Regional Transmission Organization responsible for assessing transmission  
18 system reliability and stability in Maryland is PJM. A potential interconnection  
19 customer, such as the Project, must comply with the PJM Open Access  
20 Transmission Tariff (“OATT”), as approved by the Federal Energy Regulatory  
21 Commission (“FERC”), and must become a PJM member.

22 PJM organizes generation interconnection requests into clusters, or queues, for the  
23 purpose of identifying required transmission system improvements. Upon the  
24 receipt of an interconnection request, PJM conducts sequential studies, provided  
25 the potential customer meets certain requirements to retain its queue position. The  
26 studies are dependent on other projects within the geographical area. The studies  
27 performed by PJM are the Feasibility Study, the Impact Study, and the Facilities  
28 Study. The studies are intended to determine what system enhancements are

1 necessary to accommodate the interconnecting generator and maintain the  
2 reliability and stability of the transmission system.

3 **Q. Please describe the Feasibility study.**

4 A. Computer modeling of the electric system is used by PJM to evaluate the  
5 feasibility of new generation with respect to compliance with the Regional  
6 Reliability Council, Reliability First, of the North American Electric Reliability  
7 Council (“NERC”) reliability and stability criteria. Short circuit calculations are  
8 performed to ensure that circuit breaker capacities are not exceeded. This report  
9 identifies direct connection requirements and network impacts. Once the  
10 Feasibility Study is completed, a Feasibility Report is issued. In order to maintain  
11 its queue position, the applicant must then execute an Impact Study Agreement.

12 **Q. Please describe the Impact study.**

13 A. The Impact Study is a continuation of the Feasibility Study with the inclusion of  
14 more detailed analysis. Capacity Resources are evaluated for load deliverability  
15 and generation deliverability. Load deliverability is a measure of the ability to  
16 transfer power to the load in a particular sub-area. Generator deliverability is a  
17 measure of the ability to export generation from a sub-area. Stability is evaluated  
18 for critical contingencies. Short circuit calculations are performed, taking into  
19 consideration all elements of the regional plan, to ensure that circuit breaker  
20 capacities are not exceeded. In order to maintain the queue position, the applicant  
21 then must execute a Facilities Study Agreement. By executing the Facilities Study  
22 Agreement the potential interconnection customer retains the assigned priority in  
23 the PJM queues.

24 **Q. Are any other studies or agreements required?**

25 A. In general any generator seeking to interconnect to the PJM transmission system  
26 would be required to complete three additional studies and execute additional  
27 study agreements. These agreements are the Facilities Study, Interconnection

1 Service, and Construction Service Agreements. The Facilities Study Agreement  
2 further defines the construction details and responsibilities of the Project, PJM,  
3 and the transmission owner, in this case, DPL.

4 Upon completion of the Facilities Study a project is tendered an Interconnection  
5 Service Agreement (“ISA”) between the project, PJM, and the transmission owner  
6 that is filed with the FERC. The ISA describes the requirements for the physical  
7 and operational interconnection of the Project to the grid, direct connection  
8 requirements, and network upgrades and their cost. The document may also  
9 specify requirements related to the operation and maintenance of the system  
10 enhancements. The specifications are dependent upon the standards of the local  
11 transmission owner. However, most of the system enhancements have already  
12 been identified during the course of the PJM studies, since the local transmission  
13 owner participates in the PJM studies. It is important for the generation owner and  
14 the transmission owner to agree on how the interface should operate. This greatly  
15 reduces the risk of failure and, thereby, improves safety and reliability for the  
16 local area.

17 The Construction Service Agreement (“CSA”) identifies terms and conditions,  
18 and coordinates construction activities for completion of identified attachment  
19 facilities and network transmission upgrades with the transmission owner, which  
20 in this instance is DPL. The cost of the attachment facilities and transmission  
21 system network upgrades are the responsibility of the project requesting to  
22 interconnect. This agreement completes the interconnection process for a new  
23 generator to participate in the PJM market.

24 Capacity Injection Rights (“CIRs”) are awarded to a project based on satisfactory  
25 completion of milestones and requirements contained in the various agreements.  
26 CIRs quantify the power that a project is permitted to deliver into PJM at a  
27 specified location, enabling a project to participate in PJM’s capacity market.  
28 CIRs are unit-specific and granted in a quantity commensurate with the megawatt  
29 (“MW”) size identified in a generator’s interconnection request and



1 Interconnection Service Agreement. CIRs allow the project to participate in PJM  
2 as a capacity resource.

3 **Q. Can you explain what is meant by a capacity resource?**

4 A. A capacity resource has the right to schedule both capacity and energy deliveries  
5 at a point of interconnection into PJM markets, pursuant to a bilateral contract or  
6 through participation in the PJM capacity market. A capacity resource can provide  
7 both capacity and energy to load serving entities to meet their load obligation,  
8 pursuant to the PJM Reliability Assurance Agreement that is binding on all PJM  
9 members.

10 **Q. What is the current status and queue position of the Project?**

11 A. OED has a generator interconnection queue number of Y3-015 having submitted  
12 an interconnection request to PJM on August 22, 2011. PJM's website indicates  
13 the initial proposed in-service date of December 31, 2012 from information  
14 contained in the interconnection request. However, OED now estimates a  
15 commercial in-service date of May 2016 assuming approval of this CPCN  
16 application to permit construction by early summer 2015. After the close of the  
17 X3 interconnection request queue, PJM initiated the interconnection study process  
18 and completed a Generation Interconnection Combined Feasibility and System  
19 Impact Study to permit interconnection to the transmission system. Based on  
20 information provided by the Project, the Feasibility and System Impact Studies  
21 were completed by July 2012 with the Facilities Study completed in September  
22 2014.

23 As of the date of this testimony both the ISA and CSA are still in the process of  
24 being negotiated. OED has also elected to exercise the "Option to Build"  
25 pursuant to the provisions of PJM's approved OATT. The Option to Build will  
26 allow OED to incorporate a greater scope of work in order to expedite the timing  
27 of construction activities currently proposed by DPL. Negotiations on the exact  
28 scope of work, schedule, and cost are currently in discussion between OED and

1 DPL. Upon completion of the negotiations DPL will release a revised Facilities  
2 Study and sign an ISA to reflect the agreed upon scope of work.

3 Upon receipt of the ISA, the Project will have sixty days (60) to review and sign  
4 the agreement. Absent the Project's signature of the ISA within the sixty-day  
5 period, the interconnection request would lose its queue position and would be  
6 required to re-enter the generation interconnection queue and repeat the process as  
7 a new request, should it wish to re-apply. Assuming the Project signs the tendered  
8 ISA, the transmission owner (DPL) would sign the agreement and return it to PJM  
9 for its signature. At this point, the ISA would be binding on all parties and be filed  
10 at FERC.

11 **Q. How will the Project be connected to the PJM transmission system?**

12 A. The Project would interconnect to the PJM system through DPL transmission  
13 facilities. The point of interconnection into the DPL transmission system would  
14 be the West Cambridge-Vienna 69 kV substation. A new, on-site attachment  
15 facility containing a three-breaker ring bus substation will be constructed and new  
16 relay, protection and communications equipment will be installed at both the  
17 Vienna and West Cambridge substations to accommodate the proposed generation  
18 and to mitigate potential adverse impact on the stability and reliability of the  
19 electric system.

20 The design and construction of all facilities to complete the interconnection would  
21 be the responsibility of DPL with the cost borne by the Project. In addition, the  
22 Project will be required to install telemetering and telemetry equipment to provide  
23 revenue metering and real-time data to PJM in accordance with the OATT, and to  
24 design and install relaying and metering to comply with DPL transmission  
25 standards.

26 The CPCN application indicates that the proposed solar project would  
27 interconnect with the DPL transmission system through a "50%" tap of the West  
28 Cambridge-Vienna 69 kV circuit. New facilities and equipment to operate the

1 proposed “50% tap” will be constructed at the generation site to support the  
2 OED’s generation facilities.<sup>3</sup> This substation will be built to the specifications of  
3 DPL and ultimately owned and operated by DPL. The substation will consist of a  
4 three-breaker ring bus and associated relaying, communications equipment, and a  
5 control house. OED shall supply adequate, build able high land with access for  
6 roads for the installation of the substation at no cost to DPL. OED will work with  
7 DPL to the extent required to secure all applicable permitting for the proposed  
8 substation.

9 **Q. What are the interconnection and transmission network upgrade facilities**  
10 **and costs identified in the Facilities Interconnection Study?**

11 A. The Feasibility, System Impact and Facilities studies did not identify a need for  
12 any new transmission system reinforcements or transmission network upgrades.  
13 The estimated cost of facilities required for attachment of the Project to the DPL  
14 system is approximately \$4.2 million with construction contingencies<sup>4</sup> all of  
15 which will be paid by the Project.

16 **Q. Why is the stability analysis important for new projects seeking to**  
17 **interconnect in PJM?**

18 A. Stability is a measure of the transmission system’s ability to recover from changes  
19 to its normal operation. Large or sudden changes in load or generation can have  
20 significant impacts on transmission system operations resulting in voltage  
21 collapse or cascading outages. Stability Analysis takes into consideration the

---

<sup>3</sup> A “50% tap” of the West Cambridge-Vienna 69kV circuit is the aggregated upper capacity limit allowed to be injected onto the system from distributed generation installation and would accommodate up to 20 MW of generation for injection into the transmission system. The application in this proceeding has proposed a 15.5 MW solar generation project which is less than the 20 injection limit.

<sup>4</sup> Facilities Study Report for PJM Generation Interconnection Request Queue Position X3-015, September 2014, page 5.

1 response of the generator to requests for changes in real (MWs) and reactive  
2 power (MVARs) output.<sup>5</sup>

3 **Q. Have the effects of the Project on the reliability and stability of the electric**  
4 **system in Maryland been determined?**

5 A. Prior to operation, the Project will be required to comply with DPL's and PJM's  
6 interconnection requirements and complete the requisite facility upgrades and  
7 milestones specified in the ISA and CSA. The Project's compliance with these  
8 agreements would assure no adverse impact to the reliability and stability of the  
9 electric transmission system. The additional generation capability of the Project  
10 would be of benefit to Maryland and the PJM system.

11 **Q. Why are you recommending CPCN conditions regarding reliability and**  
12 **transmission system stability?**

13 A. The ISA and CSA are crucial documents for maintaining the safety, reliability,  
14 and stability of the electric transmission system. PJM posts every ISA and CSA as  
15 a matter of public record on its website with the ISA filed with FERC. In this  
16 situation filing of the ISA and the CSA should be required as a condition of any  
17 issuance of a CPCN.

18 Verification that the required facilities have been completed provides a level of  
19 assurance to the Commission, and to the public, that the identified facilities were  
20 necessary and in place prior to operation of the Project. Certification of installed  
21 facilities and any upgrades at the time of generator start-up is requested because  
22 the requirements are subject to change, and some upgrades may not be required  
23 until after the generation becomes operational. Compliance with the conditions

---

<sup>5</sup> Reactive power (MVARs) is energy lost in an alternating current circuit when the voltage and current are not in phase. This energy loss can be recovered by supplying reactive power to the circuit. Reactive power is lost to loads such as motors, transformers, and long transmission lines. Reactive power losses reduce the ability of a transmission system to deliver power. Extreme losses in reactive power can lead to voltage collapse or blackouts.

1 also serves to notify the Commission when the Project begins commercial  
2 operation.

3 **CONCLUSIONS**

4 **Q. What are your conclusions regarding this project?**

5 A. Renewable energy projects, such as solar and wind farms, have been promoted  
6 and mandated by many states. State Renewable Portfolio Standards (“RPS”)  
7 requires suppliers to utilize renewable resources to serve an increasing percentage  
8 of total demand or pay an alternative compliance fee. Maryland’s RPS target is  
9 20% by 2022, with 2% being supplied by solar generation. The Project would  
10 contribute toward meeting this goal.

11 Compliance with the ISA and CSA are critical for maintaining the reliability and  
12 stability of the electric system. Therefore, it has also been referenced in the  
13 proposed CPCN conditions for approval of the Project.

14 **Q. What is your recommendation in this matter?**

15 A. Staff recommends that the Commission issue a CPCN for the Project consistent  
16 with its recommendations and any proposed conditions presented by the other  
17 state agencies having jurisdiction in this proceeding.

18 **Q. Does this conclude your testimony?**

19 A. Yes.

**CONFIDENTIAL**

**EXHIBIT RDG - 1**

**Case Number 9370**