

***Generation Interconnection
System Impact Study Report***

For

***TP Generation Interconnection Request Queue
Position Z1-086***

Carson – Heritage 500kV

November 2014

Introduction

This System Impact Study (SIS) has been prepared in accordance with the TP Open Access Transmission Tariff, Section 205, as well as the System Impact Study Agreement between Virginia Electric and Power Company (Interconnection Customer (IC)) and TP Interconnection, LLC (Transmission Provider (TP)). The Interconnected Transmission Owner (ITO) is Virginia Electric and Power Company.

Preface

The intent of the System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the TP network at a location specified by the IC. As a requirement for interconnection, the IC may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the TP system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on TP web site) for the appropriate transmission owner.

In some instances an IC may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation will be deferred until the System Impact Study is performed.

The System Impact Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

General

Virginia Electric and Power Company, the IC, has proposed a natural gas generating facility located at Greensville County, Virginia. The installed facilities will have a total capability of 1681 MW with 1630 MW of this output being recognized by TP as capacity. The proposed in-service date for this project is December 1, 2018. **This study does not imply an ITO commitment to this in-service date.**

Point of Interconnection

Z1-086 will interconnect with the ITO system via a new three breaker ring bus switching station that connects to the Carson – Heritage 500kV line.

Cost Summary

The Z1-086 project will be responsible for the following costs:

| Description | Total Cost |
|---|---------------------|
| Attachment Facilities | \$2,600,000 |
| Direct Connection Network Upgrades | \$6,000,000 |
| Non Direct Connection Network Upgrades | \$22,000,000 |
| Allocation for New System Upgrades | \$0 |
| Contribution for Previously Identified Upgrades | \$TBD |
| Total Costs | \$30,600,000 |

Attachment Facilities

Generation Substation: Install metering and associated Protection Equipment. Estimated Cost \$600,000.

Transmission Line: Construct approximately one span of 500 kV Attachment line between the generation substation and Z1086 Switching Substation. The estimated cost for this work is \$2,000,000.

The estimated total cost of the Attachment Facilities is \$2,600,000. It is estimated to take 18-24 months to complete this work after execution of Interconnection Service Agreement (ISA) and Interconnection Construction Service Agreement (ICSA). These preliminary cost estimates are based on typical engineering costs. A more detailed engineering cost estimates are normally done when the IC provides an exact site plan location for the generation substation during the Facility Study phase. The single line is shown below in Attachment 1.

Direct Connection Cost Estimate

Substation: TP network upgrade # n4300 to establish the new 500 kV Z1086 Switching Substation (interconnection substation). The arrangement in the substation will be as shown below on Attachment 1: One-Line Diagram. The estimated cost of this facility is \$6,000,000. It is estimated to take 24-36 months to complete this work after execution of ISA and ICSA.

Non-Direct Connection Cost Estimate

TP network upgrade # n4258 to uprate the Carson to Rawlings 500 kV line to approximately 4300 MVA. The estimated cost is \$22,000,000. It is estimated to take 20 months to complete. The time line to complete is based on being able to obtain outages to uprate line.

Interconnection Customer Requirements

VEPCO Facility Connection Requirements as posted on TP's website
<http://www.TP.com/~media/planning/plan-standards/private-dominion/facility-connection-requirements1.ashx>

Revenue Metering and SCADA Requirements

PJM Requirements

The IC will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See TP Manuals M-01 and M-14D, and TP Tariff Sections 24.1 and 24.2.

Network Impacts

The Queue Project Z1-086 was studied as a 1630.0 MW (Capacity 1630.0 MW) injection tapping the Carson – Brunswick 500 kV line in the ITO area. Project Z1-086 was evaluated for compliance with applicable reliability planning criteria (TP, NERC, NERC Regional Reliability Councils, and Transmission Owners) for summer peak conditions in 2017. The stability analysis used a 2019 model and 1681MW injection. Queue project Z1-086 was studied with a commercial probability of 100%. Potential network impacts were as follows:

Contingency Descriptions

The following contingencies resulted in overloads:

| Contingency Name | Description |
|-------------------------------|--|
| 1127_B2_A | CONTINGENCY '1127_B2_A' OPEN BRANCH FROM BUS 314902 TO BUS 916370 CKT 1 / 314902 8CARSON 500 916370 Z1-086 500 1 END |
| 8MORRSVL _8NO ANNA _033 | CONTINGENCY '8MORRSVL _8NO ANNA _033' DISCONNECT BRANCH FROM BUS 314916 TO BUS 314918 CKT 1 /* 500/500KV, AREA 345/345. END |

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

| Overload Number | Contingency Type | Contingency Name | Affected Area | Facility Description | Bus | | Circuit | Power Flow | Loading % | | Rating Type | Rating MVA | MW Contribution | Flowgate Appendix |
|-----------------|------------------|------------------|---------------|-----------------------------------|--------|--------|---------|------------|-----------|--------|-------------|------------|-----------------|-------------------|
| | | | | | From | To | | | Initial | Final | | | | |
| 1 | N-1 | 1127_B2_A | CPL - DVP | 6PERSON230 T-6HALIFAX 230 kV line | 304070 | 314697 | 1 | DC | 97.42 | 131.8 | ER | 712 | 244.79 | 1 |
| 2 | N-1 | 1127_B2_A | DVP - DVP | 6HALIFAX-6CLOVER 230 kV line | 314697 | 314686 | 1 | AC | 82.18 | 112.47 | ER | 749 | 226.93 | 2 |

TP network upgrades n3289, n3290, and n3292 to build a 14 mile Heritage to Rawlings 500kV Line to approximately 3402 MVA. Work includes the Rawlings switching substation and re-arrangement at Carson substation. Included in this is a portion of the network upgrade n3287 to connect the new line into Heritage. These network upgrades were previously identified in TP Queue X2-076 due to the violations identified in Duke Progress. The cost allocation for \$85,000,000 between the X2-076 project and the Z1-086 project will be determined during the facility study while performing a joint study with Duke Progress.

- Install three breaker ring bus substation (Rawlings) on line 556 (n3289). The estimated cost is \$8,626,657.
- Construct new 500 kV 591 line between line 570 and 556 (n3290.2). The estimated cost is \$31,382,028.
- Rearrange the Carson 500 kV substation configuration to separate line 556 and 570 from the same breaker bay (n3292). The estimated cost is \$4,832,288.
- Construct one bay of the four bay switching substation (Heritage) for the new 591 line (assume one quarter of n3287). The estimated cost is one quarter of \$13,315,148.

With the network upgrades above added to the study an additional thermal violation was identified.

| Overload Number | Contingency Type | Contingency Name | Affected Area | Facility Description | Bus | | Circuit | Power Flow | Loading % | | Rating Type | Rating MVA | MW Contribution |
|-----------------|------------------|------------------|---------------|-------------------------------|--------|--------|---------|------------|-----------|--------|-------------|------------|-----------------|
| | | | | | From | To | | | Initial | Final | | | |
| 3 | N-1 | 1127_B2_A | DVP - DVP | 556BKRSTA-8CARSON 500 kV line | 314995 | 314902 | 1 | AC | 75.69 | 102.55 | ER | 3402 | 923.75 |

TP network upgrade n4258 to uprate the Carson to Rawlings 500 kV Line to approximately 4300 MVA. The estimated cost is \$22,000,000. It is estimated to take 20 months to complete. The time line to complete is based on being able to obtain outages to uprate line.

| Queue | MW contribution | Percentage of Cost | Cost(\$M) |
|--------|-----------------|--------------------|-----------|
| Z1-086 | 86.75 | 100.00% | 22.0000 |

Multiple Facility Contingency

(Double Circuit Tower Line contingencies were studied for the full energy output. The contingencies of Line with Failed Breaker and Bus Fault will be performed for the Impact Study.)

None

Short Circuit

(Summary of impacted circuit breakers)

New circuit breakers found to be over-duty:

None

Contributions to previously identified circuit breakers found to be over-duty:

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the TP Queue)

| Overload | | Contingency | | | Bus | | | | Loading % | | Rating | | MW | Flowgate |
|----------|------|-----------------------|---------------|-------------------------------|--------|--------|---------|------------|-----------|--------|--------|------|--------------|----------|
| Number | Type | Name | Affected Area | Facility Description | From | To | Circuit | Power Flow | Initial | Final | Type | MVA | Contribution | Appendix |
| 4 | N-1 | 8MORRSVL_8NO ANNA_033 | DVP - DVP | 8NO ANNA-8LDYSMTH 500 kV line | 314918 | 314911 | 1 | DC | 103.7 | 112.61 | ER | 3219 | 291.53 | 4 |

TP network upgrade n0718.1 to build a 15-mile long North Anna – Lady Smith 2nd 500 kV line and install 500 kV breakers at North Anna and Ladysmith Stations. The estimated cost is \$44,000,000. It is estimated to take 30 months to complete. Previously identified in PJM Queue Q65.

| Queue | MW contribution | Percentage of Cost | Cost(\$44M) |
|--------|-----------------|--------------------|-------------|
| Q65 | 400.00 | 43.57% | 19.1697 |
| X2-076 | 226.59 | 24.68% | 10.8590 |
| Z1-086 | 291.53 | 31.75% | 13.9713 |

Steady-State Voltage Requirements

(Summary of the VAR requirements based upon the results of the steady-state voltage studies)

None

Stability and Reactive Power Requirement for Low Voltage Ride Through

(Summary of the VAR requirements based upon the results of the dynamic studies)

Requirements

The following actions are required for Z1-086:

1. **Operating Restrictions:** There are N-1-1 operating conditions (such as maintenance outage) that result in transient instability with the addition of the Greenville units (Z1-086). Specifically, the following N-1 system conditions (pre-contingency) result in transient instability and/or poorly damped oscillations for the next contingency:
 - Brunswick-Rawlings 500kV line O/S
 - Z1-086-Carson 500kV line O/S
 - Rawlings-Carson 500kV line O/S

To mitigate this instability, immediate operating restrictions must be enforced following an N-1 (planned or forced). For any of the system conditions defined above, without further study, generation at this location (Brunswick/Greenville) must be limited to:

Operating Restriction Recommendation Table

| Online Generation | Brunswick Max Output [MW] | Z1-086 Max Output [MW] |
|-------------------------------|---------------------------|------------------------|
| If Brunswick is Offline... | N/A | <1200 |
| If Z1-086 is Offline... | 1376 (max) | N/A |
| If both Plants are Online...* | 1376 (max)* | 0* |

*This assumes Brunswick is dispatched to full capacity. Z1-086 must be restricted to below its Pmin output of 862 MW. This assumes that the unit is normally operated with all combustion turbines running and the steam running at Pmin quantity.

It is noted that Z1-086 is less stable than the Brunswick plant based on the parameters provided. Therefore, it must be restricted to a lower MW limit than Brunswick. These operating restrictions likely will require additional studies and possible further restriction on the units' output. This also is studied under 2019 light load and summer peak

conditions, and does not cover all possible system conditions. Therefore, system conditions could arise in the operational timeframe that could further limit the units' output.

2. **Installation of out-of-step protection:** This study was made using a certain set of operating conditions. There may be other operating conditions, although less probable, that can create stability problems either during high transfer or high voltage conditions. It is the Customer's responsibility to protect their own equipment from damage due to disturbances on the transmission system by installing out-of-step protection on their generators.

Recommendations

The following actions are recommended for Z1-086:

1. **Additional PSS Tuning Studies:** It is strongly recommended that additional PSS tuning studies be performed to ensure that the power system stabilizer is sufficiently damping out the oscillations of interest. The model provided uses the PSS2B model in PSS/e, whereas similar plants such as Warren County Power Station use the PSS2A model. Parameters are slightly modified between the two and should be investigated further. This could help lessen the restrictions identified above.
2. **Construction of Z1-086-Carson #2 500kV line:** For N-1-1 operating conditions (such as maintenance outage), the combination of Z1-086 and the existing Brunswick generating facility results in transient instability for a number of contingencies. These operating conditions can occur during times of maintenance and forced outage. Specifically, generation remaining connected to the grid solely through Brunswick-Wake 500kV line results in insufficient synchronizing torque to maintain stability. To mitigate this potentially unstable condition, and also to maintain voltage stability in the Clover area, the addition of Z1-086-Carson #2 500kV line provides a sufficiently strong connection to the grid at a low cost relative to other transmission infrastructure solutions.
3. **Coordinated Study with Duke / Progress Energy:** It is recommended that TP coordinate with Progress to ensure there are no negative impacts by the proposed Z1-086 project on their network. A study comprising both ITO and Duke / Progress Energy systems to develop comprehensive Operating Restrictions may be warranted.

For more details see Attachment 2.

Light Load Analysis

(Study to determine that the Transmission System is capable of delivering the system generating capacity at light load)

Not required

Potential Congestion due to Local Energy Deliverability

TP also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The IC can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

Not applicable

ITO Analysis

ITO assessed the impact of the proposed Queue Project #Z1-086 interconnection as 1681MW of energy (Capacity 1630.0 MW) for compliance with reliability criteria on ITO's Transmission System. The system was assessed using the summer 2017 RTEP case provided to ITO by TP. When performing a generation analysis, ITO's main analysis will be load flow study results under single contingency (both normal and stressed system conditions). ITO's Criteria considers a transmission facility overloaded if it exceeds 94% of its emergency rating under normal and stressed system conditions. A full listing of ITO's Planning Criteria and interconnection requirements can be found in the ITO's Facility Connection Requirements which are publicly available at: <http://www.dom.com>.

The results of these studies evaluate the system under a limited set of operating conditions and do not guarantee the full delivery of the capacity and associated energy of this proposed generation facility under all operating conditions. NERC Planning and Operating Reliability Criteria allow for the re-dispatch of generating units to resolve projected and actual deficiencies in real time and planning studies. Specifically NERC Category C Contingency Conditions (Bus Fault, Tower Line, N-1-1, and Stuck Breaker scenarios) allow for re-dispatch of generating units to resolve potential reliability deficiencies. For ITO's Planning Criteria the re-dispatch of generating units for these contingency conditions is allowed as long as the projected loading does not exceed 100% of a facility Load Dump Rating.

As part of its generation impact analysis ITO routinely evaluates the impact that a proposed new generation resource will have under maximum generation conditions, stress system conditions and import/export system conditions. The results of these studies are discussed in more detail below.

A. Category B Analysis (Single Contingency):

1. System Normal – No deficiencies identified
2. Critical System Condition (No Surry 230 kV Unit) – No deficiencies identified.

B. Category C Analysis: (Multiple Facility Analysis)

1. Bus Fault - No deficiencies identified
2. Line Stuck Breaker - No deficiencies identified
3. Tower Line – No deficiencies identified

C. The import and export conditions into and out of the ITO System are evaluated with any new interconnection greater than 20 MW, any new facility that is interconnected with the ITO System should not significantly decrement First Contingency Incremental Transfer Capacity between utilities. The results of these studies can be found in Tables A and B for both with and without Z1-086.

Table A: Import Study Results

| Import Study Results | | | |
|-----------------------------|--------------------|--------------------------------|-------------------------|
| Area | Summer 2017 | Summer 2017 with Z1-086 | Limiting Element |
| AEP | 2000+ | 2000+ | None |
| APS | 2000+ | 2000+ | None |
| CPL | 2000+ | -411 | None |
| TP | 2000+ | 2000+ | None |


Table B: Export Study Results

| Export Study Results | | | |
|-----------------------------|--------------------|--------------------------------|-------------------------|
| Area | Summer 2017 | Summer 2017 with Z1-036 | Limiting Element |
| AEP | 2000+ | 2000+ | None |
| APS | 2000+ | 2000+ | None |
| CPL | 2000+ | 2000+ | None |
| TP | 2000+ | 2000+ | None |

ITO's Planning Criteria indicates a need to have approximately 2000 MW of import and export capability. The results of these import and export studies indicate that the proposed generation facility will impact ITO's import or export capability. Upgrades required to reliably interconnect the proposed generating facility with ITO's Transmission Facilities will resolve the identified deficiencies.

Attachment 1. Z1-086

Single Line



3-28-14

Attachment 2.

Z1-086 Stability Study Report

Introduction

This study evaluates the stability and dynamics for TP queue project Z1-086 on the ITO transmission system facilities only. The Z1-086 project is a combined cycle comprising of one steam turbine generator (ST) and three combustion turbine generators (C1, C2, C3) connecting to a new facility located approximately 0.5 miles from the new Brunswick 500kV switching station along the new Brunswick-Carson 500kV line. This new Brunswick 500kV substation is a new switching station added to the existing Carson-Wake 500kV line approximately 30 miles from Carson and 90 miles from Wake. Z1-086 queue project requests 1630 MW capacity / 1681 MW energy at the point of interconnection.

For this stability study, the Z1-086 project was studied with total net generating output of 1681 MW delivered to the grid (combustion and steam units modeled with 12.5 MW and 5.0 MW stations service, respectively).

Note: This study by ITO does not evaluate the stability and dynamic impacts for the above mentioned queue project for faults on the Duke / Progress Energy system.

Analysis

The stability study for Z1-086 was performed using the 2019 heavy summer base case and 2019 light load base case conditions. The most severe contingencies were studied for this particular generating resource to ensure transient stability during and immediately after faults on the transmission system. Three phase faults with normal clearing and single-line-to-ground faults with delayed clearing were studied. For the purposes of this study, fault clearing time is:

- 500kV normal clearing: 3 cycle and 4 cycle for near and far side, respectively.
- 500kV delayed clearing: 12 cycle near side (delayed clearing with backup) and 4 cycle far side.

Queue project Z1-086 was modeled as one 23 kV steam generator and three 20 kV combustion generators (see Appendix 4). The generators were dispatched into leading power factor region as required by ITO Planning criteria. In general, the units were dispatched at approximately 50% under-excitation (about 50% of Q_{min}) for each N-0 base case condition studied. The generators have the following MW and MVAR output characteristics.

Table 1. Generator Output Characteristics

| | ST | C1 | C2 | C3 |
|--------------|-----|------|------|------|
| Pmax [MW] | 629 | 365 | 365 | 365 |
| Station Load | 5 | 12.5 | 12.5 | 12.5 |

| | | | | |
|-----------------|------|------|------|------|
| [MW] | | | | |
| Qmax [MVAR] | 368 | 169 | 169 | 169 |
| Qmin [MVAR] | -262 | -160 | -160 | -160 |
| 50% Qmin [MVAR] | -131 | -80 | -80 | -80 |

Note: N-1-1 transient stability analysis did not consider redispatch of the units' MW output prior to applying the next N-1 contingency in dynamics (time step integration); however, the units were set with 50% under-excitation in all cases (unless terminal voltage below 0.95 pu). The terminal voltage in each of the cases is shown in the table below:

Table 2. Base Case Conditions

| Root Case | Operating Cond | Condition | 500kV | C1/C2/C3 | ST |
|-----------|------------------------|-----------------|--------|----------|--------|
| 2019SLL | | N-0 Base | 1.0349 | 0.9539 | 0.9626 |
| | | BRUNS-RAWL O/S | 1.0341 | 0.9531 | 0.9618 |
| | | Z1-086-CARS O/S | 1.0360 | 0.9550 | 0.9637 |
| | | RAWL-CARS O/S | 1.0348 | 0.9538 | 0.9625 |
| | | Z1-086-CARS O/S | 1.0349 | 0.9539 | 0.9626 |
| | CARS #2 Add | N-0 Base | 1.0349 | 0.9539 | 0.9626 |
| | CARS #2 Add | BRUNS-RAWL O/S | 1.036 | 0.9550 | 0.9637 |
| 2019SUM | | N-0 Base | 1.0341 | 0.9531 | 0.9618 |
| | BRUNS ONLY – No Z1-086 | N-0 Base | | | |
| | BRUNS ONLY – No Z1-086 | BRUNS-RAWL O/S | | | |
| | BRUNS ONLY – No Z1-086 | RAWL-CARS O/S | | | |

| | | | | | |
|--|------------------------|-----------------|--------|---------|-----------|
| | Z1-086 ONLY – No BRUNS | N-0 Base | 1.0254 | 0.9509 | 0.9566 |
| | | | | -60MVAR | -110 MVAR |
| | | BRUNS-RAWL O/S | 1.0327 | 0.9517 | 0.9604 |
| | | BRUNS-WAKE O/S | 1.0339 | 0.9529 | 0.9617 |
| | | RAWL-CLOV O/S | 1.0908 | 0.9498 | 0.9586 |
| | | Z1-086-CARS O/S | 1.0339 | 0.9529 | 0.9617 |
| | CARS #2 Add | RAWL-CARS O/S | 1.0351 | 0.9541 | 0.9628 |
| | CARS #2 Add | BRUNS-RAWL O/S | 1.0401 | 0.9591 | 0.9678 |
| | CARS #2 Add | RAWL-CARS O/S | 1.0385 | 0.9575 | 0.9575 |
| | CARS #2 Add | Z1-086-CARS O/S | 1.0341 | 0.9531 | 0.9618 |

Results

Results – 2019 Heavy Summer and Light Load

Stability results in tabular form regarding transient swing angle are provided in Appendix 5. Absolute angle is shown, and very large absolute angle is indication of out-of-step conditions. Further analysis is performed for oscillation damping analysis of concern. Observations regarding transient stability performance for Z1-086 and the Brunswick generating facility are as follows:

1. Z1-086 (and Brunswick plant) maintains transient stability with acceptable swing angle for all N-1 three-phase (3P) fault conditions and breaker failure single-line-to-ground (SLG) fault conditions. Oscillation damping for these contingencies is acceptable according to ITO Planning criteria.
2. N-1 maintenance outages pose a stability restriction on safe and reliable operation of the Z1-086 project as well as Brunswick generating facility. Complete simulation results are included in the Appendix 5 and 6.

- Loss of Carson-Z1-086 500kV line with Rawlings-Brunswick 500kV line out-of-service (O/S) results in instability.
 - Loss of Rawlings-Brunswick 500kV line with Carson-Z1-086 line O/S is unstable.
 - Loss of Z1-086-Carson 500kV line with Rawlings-Carson 500kV O/S results in severe transient instability at Brunswick, Z1-086, and Clover generating plants.
3. Transient stability results demonstrate that if Brunswick generating facility is generating at full capacity, Z1-086 will be forced to shut down due to operating restriction and minimum output (Pmin) requirements (as modeled in the case).
 4. Stability results demonstrate a lower frequency oscillation in the 0.02-0.05 Hz range that is an indication that further PSS tuning studies should be performed to improve stability for these conditions.

Results – Operating Restrictions

To understand how generation in this area must be dispatched for an N-1 pre-contingency outage (forced or planned), three distinct conditions are considered:

1. Brunswick Generation Online Only – Z1-086 is offline.
2. Z1-086 Generation Online Only – Brunswick is offline.
3. Combined output of Brunswick & Z1-086 – Brunswick is assumed to have full capacity rights and priority is given to dispatching Brunswick for this analysis.

Results from this analysis in terms of maximum absolute angle are shown in Appendix 6.

Oscillation damping results for restricted output conditions are also considered by analyzing transient ringdown. Results for oscillation ringdown analysis are shown in the table below.

Table 3. Restricted Output Modal Analysis

| BRUNSWICK ONLY | | | | |
|--------------------------|-----------|-----------------|-----------|-----------|
| Window 1 | Freq [Hz] | 1.053 | 0.282 | 0.718 |
| | Real | -0.180646 | -1.3404 | -0.432645 |
| | Imaginary | 6.61367 | 1.77036 | 4.51225 |
| | Energy | 16.156 | 5.5723 | 3.0951 |
| | Damping % | 2.730385 | 60.363397 | 9.5444593 |
| Window 2 | Freq [Hz] | 1.05 | 0.862 | 0.688 |
| | Real | -0.220996 | -0.327488 | -1.05016 |
| | Imaginary | 6.59975 | 5.41622 | 4.32335 |
| | Energy | 9.7463 | 3.3758 | 3.093 |
| | Damping % | 3.3466753 | 6.0354084 | 23.604054 |
| 1376 MW Reduction | | | | |
| Window 1 | Freq [Hz] | 0.977 | 0.859 | 0.634 |
| | Real | -0.1129 | -0.121443 | -0.3231 |

| | | | | |
|----------|-----------|-----------|-----------|-----------|
| | Imaginary | 6.13923 | 5.39799 | 3.98401 |
| | Energy | 9.699 | 3.9317 | 2.0939 |
| | Damping % | 1.838682 | 2.2492127 | 8.0833805 |
| Window 2 | Freq [Hz] | 0.565 | 0.829 | 0.982 |
| | Real | -1.9465 | -1.59522 | -0.11907 |
| | Imaginary | 3.55038 | 5.20645 | 6.16739 |
| | Energy | 8.8779 | 8.385 | 7.2901 |
| | Damping % | 48.074098 | 29.295081 | 1.9302787 |

1207 MW Reduction

| | | | | |
|----------|-----------|-----------|----------|-----------|
| Window 1 | Freq [Hz] | 0.999 | 0.865 | 0.642 |
| | Real | -0.270063 | -0.17618 | -0.242455 |
| | Imaginary | 6.27381 | 5.43487 | 4.03451 |
| | Energy | 12.882 | 4.658 | 1.7077 |
| | Damping % | 4.3006265 | 3.239958 | 5.9987056 |

The following observations are made:

1. Brunswick Generation Only – Brunswick experiences relatively low damping ratio for the system conditions used. This is a separate issue that will need to be addressed. However, this is used as a baseline for this analysis in terms of oscillatory and transient stability.
2. Z1-086 Generation Only – At full output, Z1-086 is transient unstable for N-1-1 contingencies.
 - a. Therefore, MW output is restricted first to 1376 MW (to match Brunswick output) in the 2019SUM heavy summer case (which is more stable). Although the unit maintains synchronism, oscillation damping is insufficient.
 - b. Generating output is set to 1207, which is approximately 70% of maximum generating capability. The unit maintains synchronism with measured oscillation damping for the predominant mode of 0.999 Hz of 4.3% with a secondary mode of 0.865 Hz with 3.24% damping ration. This is considered sufficient for the purposes of this study, and the primary oscillation frequency is above the 4% criteria in the ITO Planning Manual.
3. Combined Brunswick & Z1-086 – For this analysis, Brunswick is dispatched at full output and Z1-086 is studied as variable scheduled generation. Results show that even with Z1-086 set to minimum output power, Pmin, oscillation damping remains negative. Therefore, it is determined that Z1-086 must remain offline when Brunswick is scheduled near full output for certain N-1 system conditions identified.




Figure 1. Undamped oscillation frequency for Brunswick + Z1-086 at Pmin.

Results – 2019 Heavy Summer with Modified PSS Settings

The tables below show oscillation ringdown analysis results for various perturbations of the PSS settings. These studies were performed on the base case with Brunswick-Rawlings 500 out of service pre-contingency and then the Z1-086-Carson contingency is applied, with the Brunswick unit offline and Z1-086 at 1376 MW output (to match maximum Brunswick output). Legend of case names is as follows:

- PSS0 – Data as Provided
- PSS1 – Change Washout Filters to 10 sec
- PSS2 – Change Gain to 10
- PSS3 – Change Gain to 2
- PSS4 – Change to PSS2A Model (Match Warren County Power Station)

The modal information contained below is generated from PSS/e modal analysis using Least Squares / Eigenvector Fit by Initial Points, and ensuring that small error ratio and high signal to noise ratio is achieved. Energy is ranked left to right in the table below.

Table 4. PSS Tuning Modal Analysis Results

| BRUNSWICK ONLY | | | | |
|----------------|-----------|-----------|-----------|-----------|
| Window 1 | Freq [Hz] | 1.053 | 0.282 | 0.718 |
| | Real | -0.180646 | -1.3404 | -0.432645 |
| | Imaginary | 6.61367 | 1.77036 | 4.51225 |
| | Energy | 16.156 | 5.5723 | 3.0951 |
| | Damping % | 2.730385 | 60.363397 | 9.5444593 |
| Window 2 | Freq [Hz] | 1.05 | 0.862 | 0.688 |
| | Real | -0.220996 | -0.327488 | -1.05016 |
| | Imaginary | 6.59975 | 5.41622 | 4.32335 |
| | Energy | 9.7463 | 3.3758 | 3.093 |
| | Damping % | 3.3466753 | 6.0354084 | 23.604054 |

PSS0

| | | | | |
|----------|-----------|-----------|-----------|-----------|
| Window 1 | Freq [Hz] | 0.953 | 0.925 | 0.563 |
| | Real | -0.161419 | -0.188842 | 0.0058838 |
| | Imaginary | 5.98723 | 5.80938 | 3.53445 |
| | Energy | 28.083 | 22.819 | 0.54607 |
| | Damping % | 2.6950755 | 3.2489234 | -0.166471 |
| Window 2 | Freq [Hz] | 0.981 | 0.873 | 0.68 |
| | Real | -0.114955 | -0.155767 | -1.32441 |
| | Imaginary | 6.1636 | 5.48389 | 4.27027 |
| | Energy | 6.4491 | 3.5218 | 2.1548 |
| | Damping % | 1.8647383 | 2.839302 | 29.622657 |

PSS1

| | | | | |
|----------|-----------|-----------|-----------|-----------|
| Window 1 | Freq [Hz] | 0.96 | 0.916 | 1.41 |
| | Real | -0.102707 | -0.281596 | -0.36387 |
| | Imaginary | 6.03318 | 5.758 | 8.8533 |
| | Energy | 15.41 | 14.566 | 0.2621 |
| | Damping % | 1.7021226 | 4.8846796 | 4.106526 |
| Window 2 | Freq [Hz] | 0.982 | 0.874 | 0.679 |
| | Real | -0.0993 | -0.143068 | -1.18524 |
| | Imaginary | 6.16873 | 5.48918 | 4.26742 |
| | Energy | 6.7119 | 3.2217 | 1.9723 |
| | Damping % | 1.6095231 | 2.605479 | 26.761149 |

PSS2

| | | | | |
|----------|-----------|-----------|-----------|-----------|
| Window 1 | Freq [Hz] | 0.898 | 0.947 | 1.325 |
| | Real | -0.392178 | -0.160423 | -1.10344 |
| | Imaginary | 5.6453 | 5.94978 | 8.32253 |
| | Energy | 15.196 | 11.004 | 0.25627 |
| | Damping % | 6.9302796 | 2.695305 | 13.143449 |
| Window 2 | Freq [Hz] | 0.976 | 0.866 | 0.646 |
| | Real | -0.221911 | -0.152419 | -0.98247 |
| | Imaginary | 6.13361 | 5.44092 | 4.05989 |
| | Energy | 3.8846 | 3.2778 | 1.0529 |
| | Damping % | 3.6155854 | 2.8002476 | 23.520527 |

PSS3

| | | | | |
|----------|-----------|-----------|-----------|----------|
| Window 1 | Freq [Hz] | 0.971 | 0.905 | 1.431 |
| | Real | -0.046875 | -0.286146 | -1.12292 |
| | Imaginary | 6.1014 | 5.68323 | 8.98932 |
| | Energy | 13.018 | 9.9402 | 0.40152 |

| | | | | |
|----------|-----------|-----------|-----------|-----------|
| | Damping % | 0.7682436 | 5.0285488 | 12.395376 |
| Window 2 | Freq [Hz] | 0.982 | 0.874 | 0.701 |
| | Real | -0.044479 | -0.123643 | -1.02159 |
| | Imaginary | 6.17307 | 5.49178 | 4.40707 |
| | Energy | 8.8839 | 3.0369 | 1.8017 |
| | Damping % | 0.7205142 | 2.250849 | 22.581931 |

PSS4

| | | | | |
|----------|-----------|-----------|-----------|-----------|
| Window 1 | Freq [Hz] | 0.763 | 0.828 | 0.954 |
| | Real | -1.06275 | -0.046525 | -0.103629 |
| | Imaginary | 4.79232 | 5.20437 | 5.99106 |
| | Energy | 5.0499 | 3.7681 | 1.8523 |
| | Damping % | 21.650141 | 0.8939188 | 1.7294686 |
| Window 2 | Freq [Hz] | 0.847 | 0.937 | 0.88 |
| | Real | -0.179459 | -0.393072 | -1.24357 |
| | Imaginary | 5.31872 | 5.88474 | 5.52795 |
| | Energy | 7.0207 | 4.7917 | 2.4065 |
| | Damping % | 3.3721823 | 6.6646625 | 21.947545 |

The results show no major improvement by increasing the washout filter time constants. Oscillation damping is moderately improved for an increase in PSS Gain from 5 to 10, and conversely negatively impacted by a reduction in PSS Gain from 5 to 2. Mirroring the Warren County Power Station units' PSS settings on the Z1-086 model does not produce sufficient damping, leading to the conclusion that it may not necessarily be an issue with the PSS. But further study is required.

Results – 2019 Heavy Summer and Light Load w/ Added Z1-086-Carson #2 500kV Line

Stability results in tabular form regarding transient swing angle are provided in Appendix 5. Observations regarding transient stability performance for Z1-086 and the Brunswick generating facility are as follows:

1. Z1-086 (and Brunswick plant) maintains transient stability with acceptable swing angle for all identified transient unstable conditions in the 2019SUM and 2019SLL discussed above. Oscillation damping is also improved for this addition.
2. In the N-1-1 conditions, all credible contingencies result in transient stability with the additional Z1-086-Carson #2 line.

Appendices

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact.

It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Appendix 1

CONTINGENCY '1127_B2_A'

OPEN BRANCH FROM BUS 314902 TO BUS 916370 CKT 1
500 916370 Z1-086 500 1

/ 314902 8CARSON

END

| Bus Number | Bus Name | Full Contribution |
|------------|-----------|-------------------|
| 242750 | 05PHILPO | 0.03 |
| 315131 | 1EDGECEMA | 0.14 |
| 315132 | 1EDGECEMB | 0.14 |
| LTF | W4-049 | 7.98 |
| LTF | X2-042 | 34.53 |
| 909841 | X2-076 C | 6.51 |
| LTF | X4-041 | 8.48 |
| LTF | Y1-002 | 33.95 |
| LTF | Y1-004 | 43.79 |
| LTF | Y1-007 | 30.42 |
| LTF | Y2-004 | 17.09 |
| LTF | Y2-005 | 6.84 |
| LTF | Y2-006 | 17.55 |
| LTF | Y2-033 | 6.19 |
| LTF | Y2-034 | 20.04 |
| LTF | Y2-035 | 22.9 |
| LTF | Y2-114 | 5.61 |
| LTF | Y2-115 | 6.16 |
| LTF | Y3-028 | 10.83 |
| LTF | Y3-069 | 17.06 |
| LTF | Y3-072 | 17.06 |
| LTF | Y3-094 | 27.46 |
| LTF | Z1-025 | 12.45 |
| LTF | Z1-027 | 7.22 |
| LTF | Z1-046 | 13.64 |
| LTF | Z1-067 | 5.36 |
| LTF | Z1-071 | 4.31 |
| 916371 | Z1-086 C | 244.79 |

Appendix 2

CONTINGENCY '1127_B2_A'

OPEN BRANCH FROM BUS 314902 TO BUS 916370 CKT 1

/ 314902 8CARSON

500 916370 Z1-086 500 1

END

| Bus Number | Bus Name | Full Contribution |
|------------|-----------|-------------------|
| 242701 | 05LEESVI | 0.17 |
| 242750 | 05PHILPO | 0.04 |
| 246843 | 05SMG1 | 0.2 |
| 246844 | 05SMG2 | 0.54 |
| 246845 | 05SMG3 | 0.31 |
| 246846 | 05SMG4 | 0.55 |
| 246847 | 05SMG5 | 0.21 |
| 315150 | 1BUGGS 1 | 0.51 |
| 315151 | 1BUGGS 2 | 0.51 |
| 315131 | 1EDGECSMA | 0.15 |
| 315132 | 1EDGECSMB | 0.15 |
| 315165 | 1HURT 1 | 0.18 |
| 315166 | 1HURT 2 | 0.18 |
| 315158 | 1KERR 1 | 0.08 |
| 315159 | 1KERR 2 | 0.23 |
| 315160 | 1KERR 3 | 0.23 |
| 315161 | 1KERR 4 | 0.23 |
| 315162 | 1KERR 5 | 0.23 |
| 315163 | 1KERR 6 | 0.23 |
| 315164 | 1KERR 7 | 0.23 |
| 244221 | INDDRVL | 0.08 |
| 315167 | O06_DP01 | 0.02 |
| 315419 | Q-070 | 0.03 |
| 242889 | REUSENS | 0.01 |
| 297087 | V2-040 | 0.05 |
| 902621 | W2-049 | 0.51 |
| LTF | W4-049 | 7.4 |
| 907491 | X1-084 | 0.54 |
| LTF | X2-042 | 34.7 |
| 909841 | X2-076 C | 6.03 |
| LTF | X4-041 | 8.49 |
| LTF | Y1-002 | 33.98 |
| LTF | Y1-004 | 43.91 |
| LTF | Y1-007 | 30.5 |
| LTF | Y2-004 | 17.12 |
| LTF | Y2-005 | 6.84 |

| | | |
|--------|----------|--------|
| LTF | Y2-006 | 17.55 |
| LTF | Y2-033 | 6.17 |
| LTF | Y2-034 | 19.96 |
| LTF | Y2-035 | 21.66 |
| LTF | Y2-114 | 5.61 |
| LTF | Y2-115 | 6.16 |
| LTF | Y3-028 | 10.92 |
| LTF | Y3-069 | 17.13 |
| LTF | Y3-072 | 17.13 |
| LTF | Y3-094 | 27.66 |
| 915731 | Y3-119 C | 0.44 |
| LTF | Z1-025 | 12.45 |
| LTF | Z1-027 | 7.25 |
| LTF | Z1-046 | 13.77 |
| LTF | Z1-067 | 5.11 |
| LTF | Z1-071 | 4.4 |
| 916371 | Z1-086 C | 226.93 |

Appendix 3

CONTINGENCY '8MORRSVL_8NO ANNA_033'

DISCONNECT BRANCH FROM BUS 314916 TO BUS 314918 CKT 1
AREA 345/345.

/* 500/500KV,

END

| Bus Number | Bus Name | Full Contribution |
|------------|-----------|-------------------|
| 315170 | 1BREMO 3 | 0.31 |
| 315171 | 1BREMO 4 | 0.68 |
| 315150 | 1BUGGS 1 | 0.3 |
| 315151 | 1BUGGS 2 | 0.3 |
| 315094 | 1CHESPK1 | 16.3 |
| 315095 | 1CHESPK2 | 16.3 |
| 315096 | 1CHESPK3 | 22.17 |
| 315097 | 1CHESPK4 | 31.71 |
| 315098 | 1CHESPKA | 0.07 |
| 315099 | 1CHESPKB | 0.18 |
| 315153 | 1CLOVER1 | 2.42 |
| 315154 | 1CLOVER2 | 2.45 |
| 315131 | 1EDGECSMA | 0.24 |
| 315132 | 1EDGECSMB | 0.24 |
| 315108 | 1ELIZAR1 | 0.57 |
| 315109 | 1ELIZAR2 | 0.5 |
| 315110 | 1ELIZAR3 | 0.53 |
| 315139 | 1GASTONA | 0.5 |
| 315141 | 1GASTONB | 0.5 |
| 315260 | 1GOSPRTA | 0.01 |
| 315261 | 1GOSPRTB | 0.02 |
| 315262 | 1GOSPRTC | 0.01 |
| 315158 | 1KERR 1 | 0.06 |
| 315159 | 1KERR 2 | 0.18 |
| 315160 | 1KERR 3 | 0.18 |
| 315161 | 1KERR 4 | 0.18 |
| 315162 | 1KERR 5 | 0.18 |
| 315163 | 1KERR 6 | 0.18 |
| 315164 | 1KERR 7 | 0.18 |
| 315111 | 1LKKINGA | 0.26 |
| 315112 | 1LKKINGB | 0.26 |
| 315172 | 1LOISA A | 0.89 |
| 315173 | 1LOISA B | 0.89 |
| 315174 | 1LOISA C | 0.89 |
| 315175 | 1LOISA D | 0.89 |
| 315176 | 1LOISA E | 1.82 |
| 315225 | 1N ANNA1 | 21.88 |

| | | |
|--------|--------------|--------|
| 315226 | 1N ANNA2 | 21.54 |
| 315126 | 1ROARAP2 | 0.23 |
| 315128 | 1ROARAP4 | 0.21 |
| 315134 | 1ROAVALA | 0.75 |
| 315135 | 1ROAVALB | 0.2 |
| 315136 | 1ROSEMG1 | 0.35 |
| 315138 | 1ROSEMG2 | 0.17 |
| 315137 | 1ROSEMS1 | 0.22 |
| 315177 | 1SANNAG1 | 0.84 |
| 315179 | 1SANNAG2 | 0.84 |
| 315178 | 1SANNAS1 | 0.43 |
| 315180 | 1SANNAS2 | 0.43 |
| 315115 | 1SHAMPT1 | 0.29 |
| 315083 | 1SPRUNCA | 0.24 |
| 315084 | 1SPRUNCB | 0.24 |
| 315085 | 1SPRUNCC | 0.18 |
| 315086 | 1SPRUNCD | 0.18 |
| 315073 | 1STONECA | 4.35 |
| 315090 | 1YORKTN1 | 18.66 |
| 315091 | 1YORKTN2 | 19.36 |
| 314643 | 3O INLET | 0.08 |
| 314539 | 3UNCAMP | 2.03 |
| 314621 | 3WEYERH | 0.13 |
| 315446 | Q-065 | 1096.9 |
| 315419 | Q-070 | 0.05 |
| 297087 | V2-040 | 0.02 |
| 900671 | V4-068 C | 0.01 |
| 901081 | W1-029 C | 5.7 |
| 902241 | W2-022 C OP1 | 1.3 |
| 902621 | W2-049 | 0.21 |
| 903530 | W3-066 C1OP1 | 2.87 |
| 903531 | W3-066 C2OP1 | 2.87 |
| LTF | W4-049 | 6.16 |
| 909841 | X2-076 C | 7.5 |
| 913391 | Y1-086 C | 0.03 |
| 914001 | Y2-001 C | < 0.01 |
| 914181 | Y2-066 | 0.04 |
| 914221 | Y2-076 | 0.08 |
| 916051 | Z1-036 C | 5.64 |
| 916241 | Z1-068 C | 0.22 |
| 916371 | Z1-086 C | 291.53 |

Appendix 4

Generator Model Parameters

Combustion Turbine Generator Models:

Generator Model: GENROU
 Excitation Model: EXST1
 Governor Model: GAST
 Power System Stabilizer Model: PSS2B

Steam Turbine Generator Models:

Generator Model: GENROU
 Excitation Model: EXST1
 Governor Model: N/A
 Power System Stabilizer Model: PSS2B

```

/***** Z1-086 *****/
916372 'GENROU' 1      7.8    0.045  0.87    0.074
          4.34  0.0    2.02   1.97   0.289
          0.468 0.226  0.158  0.16   0.7 /
916372 'GAST' 1      0.04   0.1    1      5.0
          1.0   3      1.0    0.05  0.1 /
916372 'EXST1' 1     0.008  999   -999   0.5
          1.90  171.5  0.029  4.52  -1.82
          0.11  0.0    1      /
916372 'PSS2B' 1     2      0      3      0      4      1
          2      2      0.0  2      1000  2
          0.22  1.0    0.4   0.1    5
          0.28  0.02  0.28  0.02   0.25
          1.5   999   -999  999   -999
          0.05 -0.05 /
916373 'GENROU' 1      7.8    0.045  0.87    0.074
          4.34  0.0    2.02   1.97   0.289
          0.468 0.226  0.158  0.16   0.7 /
916373 'GAST' 1      0.04   0.1    1      5.0
          1.0   3      1.0    0.05  0.1 /
916373 'EXST1' 1     0.008  999   -999   0.5
          1.90  171.5  0.029  4.52  -1.82
          0.11  0.0    1      /
916373 'PSS2B' 1     2      0      3      0      4      1
          2      2      0.0  2      1000  2
          0.22  1.0    0.4   0.1    5
          0.28  0.02  0.28  0.02   0.25
          1.5   999   -999  999   -999
          0.05 -0.05 /
  
```

```

916374 'GENROU' 1      7.8    0.045  0.87    0.074
          4.34  0.0    2.02   1.97   0.289
          0.468 0.226  0.158  0.16   0.7 /
916374 'GAST' 1      0.04   0.1    1      5.0
          1.0   3      1.0    0.05  0.1 /
916374 'EXST1' 1     0.008  999   -999   0.5
          1.90  171.5  0.029  4.52  -1.82
          0.11  0.0    1      /
916374 'PSS2B' 1     2      0      3      0      4      1
          2      2      0.0  2      1000  2
          0.22  1.0    0.4   0.1    5
          0.28  0.02  0.28  0.02   0.25
  
```

| | | | | | | | |
|--------|----------|---------|-------|-------|-------|-------|---|
| | 1.5 | 999 | -999 | 999 | -999 | | |
| | 0.05 | -0.05 / | | | | | |
| 916375 | 'GENROU' | 1 | 6.7 | 0.017 | 0.74 | 0.029 | |
| | 4.05 | 0.0 | 1.60 | 1.57 | 0.258 | | |
| | 0.422 | 0.226 | 0.161 | 0.16 | 0.68 | / | |
| 916375 | 'EXST1' | 1 | 0.008 | 999 | -999 | 0.48 | |
| | 1.72 | 137.8 | 0.029 | 5.21 | -1.93 | | |
| | 0.19 | 0.0 | 1 | / | | | |
| 916375 | 'PSS2B' | 1 | 2 | 0 | 3 | 0 | 4 |
| | 2 | 2 | 0.0 | 2 | 1000 | 2 | 1 |
| | 0.247 | 1.0 | 0.4 | 0.1 | 5 | | |
| | 0.30 | 0.03 | 0.30 | 0.03 | 0.3 | | |
| | 1.5 | 999 | -999 | 999 | -999 | | |
| | 0.05 | -0.05 / | | | | | |

Appendix 5

| Case Name | Stable? | Max Angle | Element |
|--|---------|-----------|---|
| (2019SLL_1207_NoBruns_BRUNS-RAWL_OS_(2019SLL_Z086)_ (N1_L585_GRNS_CRNS).txt | Yes | 87.08 | |
| (2019SLL_1207_NoBruns_RAWL-CARS_OS_(2019SLL_Z086)_ (N1_L585_GRNS_CRNS).txt | Yes | 80.9 | |
| (2019SLL_1207_NoBruns_Z086-CARS_OS_(2019SLL_Z086)_ (N1_L591_BRUN_RAWL).txt | Yes | 61.04 | |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086)_ (FB_BRUN1).txt | No | 1.47E+05 | ANGL315105[1BRUNSWICKS119.000]S1 0.1467E+06 |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086)_ (FB_BRUN2).txt | No | 8.74E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086)_ (FB_RAWL1).txt | Yes | 82.13 | |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086)_ (N1_L511_RAWL_CRNS).txt | Yes | 89.55 | |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086)_ (N1_L556_CLOV_RAWL).txt | Yes | 77.45 | |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086)_ (N1_L570_BRUN_WAKE).txt | Yes | 92.46 | |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086)_ (N1_L585_GRNS_CRNS).txt | Yes | 97.02 | |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086)_ (N1_L591_BRUN_RAWL).txt | Yes | 94.06 | |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086)_ (N1_L595_BRUN_GRNS).txt | Yes | 97.77 | |
| (2019SLL_2013Series_Z-086_BRUNS-RAWL_OS_(2019SLL_PSS2A)_ (N1_L585_GRNS_CRNS).txt | No | 5.18E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SLL_2013Series_Z-086_BRUNS-RAWL_OS_(2019SLL_Z086)_ (N1_L585_GRNS_CRNS).txt | No | 6.66E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SLL_2013Series_Z-086_Z086-CARS_OS_(2019SLL_Z086)_ (N1_L591_BRUN_RAWL).txt | No | 6.66E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SLL_N11_CARS2_BRUNS-RAWL_OS_(2019SLL_Z086)_ (N1_L585_GRNS_CRNS).txt | Yes | 92.11 | |
| (2019SLL_N11_CARS2_Z086-CARS_OS_(2019SLL_Z086)_ (N1_L591_BRUN_RAWL).txt | Yes | 91.31 | |
| (2019SLL_NoBruns_Z-086_BRUNS-RAWL_OS_(2019SLL_Z086)_ (N1_L585_GRNS_CRNS).txt | No | 1.48E+05 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SLL_NoBruns_Z-086_RAWL-CARS_OS_(2019SLL_Z086)_ (N1_L585_GRNS_CRNS).txt | Yes | 132.5 | |
| (2019SLL_NoBruns_Z-086_Z086-CARS_OS_(2019SLL_Z086)_ (N1_L591_BRUN_RAWL).txt | No | 7.90E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SLL_Z-086_PMIN_BRUNS-RAWL_OS_(2019SLL_Z086)_ (N1_L585_GRNS_CRNS).txt | Yes | 110.4 | |
| (2019SUM_1207_NoBruns_BRUNS-RAWL_OS_(19SUM_Z086)_ (N1_L585_GRNS_CRNS).txt | Yes | 58.52 | |
| (2019SUM_1376_NoBruns_BRUNS-RAWL_OS_(19SUM_Z086)_ (N1_L585_GRNS_CRNS).txt | Yes | 80.04 | |
| (2019SUM_1376_NoBruns_Z086-CARS_OS_(19SUM_Z086)_ (N1_L591_BRUN_RAWL).txt | Yes | 79.05 | |
| (2019SUM_1376_NoBruns_Z086-CARS_OS_(19SUM_Z086_Ed1)_ (N1_L591_BRUN_RAWL).txt | Yes | 79.05 | |
| (2019SUM_1376_PSS_BRUNS-RAWL_OS_(2019SUM_PSS0)_ (N1_L585_GRNS_CRNS).txt | Yes | 80.04 | |
| (2019SUM_1376_PSS_BRUNS-RAWL_OS_(2019SUM_PSS1)_ (N1_L585_GRNS_CRNS).txt | Yes | 80.04 | |
| (2019SUM_1376_PSS_BRUNS-RAWL_OS_(2019SUM_PSS2)_ (N1_L585_GRNS_CRNS).txt | Yes | 80.04 | |
| (2019SUM_1376_PSS_BRUNS-RAWL_OS_(2019SUM_PSS2A)_ (N1_L585_GRNS_CRNS).txt | Yes | 80.23 | |
| (2019SUM_1376_PSS_BRUNS-RAWL_OS_(2019SUM_PSS3)_ (N1_L585_GRNS_CRNS).txt | Yes | 80.04 | |

| | | | |
|---|-----|----------|---|
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(FB_BRUN1).txt | No | 1.47E+05 | ANGL315105[1BRUNSWICKS119.000]S1 0.1467E+06 |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(FB_BRUN2).txt | No | 8.74E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(FB_RAWL1).txt | Yes | 43.22 | |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(N1_L511_RAWL_CRSN).txt | Yes | 51.63 | |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(N1_L556_CLOV_RAWL).txt | Yes | 46.57 | |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(N1_L570_BRUN_WAKE).txt | Yes | 50.48 | |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(N1_L585_GRNS_CRSN).txt | Yes | 59.55 | |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(N1_L591_BRUN_RAWL).txt | Yes | 55.17 | |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(N1_L595_BRUN_GRNS).txt | Yes | 57.57 | |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(P2_BRUN_GNSVL_Sim).txt | No | 1.51E+05 | ANGL315105[1BRUNSWICKS119.000]S1 0.1506E+06 |
| (2019SUM_2013Series_Z-086_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L511_RAWL_CRSN).txt | Yes | 48.53 | |
| (2019SUM_2013Series_Z-086_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L556_CLOV_RAWL).txt | Yes | 47.23 | |
| (2019SUM_2013Series_Z-086_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L570_BRUN_WAKE).txt | Yes | 55.58 | |
| (2019SUM_2013Series_Z-086_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | No | 6.63E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SUM_2013Series_Z-086_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L595_BRUN_GRNS).txt | Yes | 53.31 | |
| (2019SUM_2013Series_Z-086_BRUNS-WAKE_OS)_(19SUM_Z086)_(N1_L511_RAWL_CRSN).txt | Yes | 58.34 | |
| (2019SUM_2013Series_Z-086_BRUNS-WAKE_OS)_(19SUM_Z086)_(N1_L556_CLOV_RAWL).txt | Yes | 45.89 | |
| (2019SUM_2013Series_Z-086_BRUNS-WAKE_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | Yes | 68.15 | |
| (2019SUM_2013Series_Z-086_BRUNS-WAKE_OS)_(19SUM_Z086)_(N1_L591_BRUN_RAWL).txt | Yes | 63.09 | |
| (2019SUM_2013Series_Z-086_BRUNS-WAKE_OS)_(19SUM_Z086)_(N1_L595_BRUN_GRNS).txt | Yes | 59.36 | |
| (2019SUM_2013Series_Z-086_RAWL-CARS_OS)_(19SUM_Z086)_(N1_L556_CLOV_RAWL).txt | Yes | 45.02 | |
| (2019SUM_2013Series_Z-086_RAWL-CARS_OS)_(19SUM_Z086)_(N1_L570_BRUN_WAKE).txt | Yes | 54.01 | |
| (2019SUM_2013Series_Z-086_RAWL-CARS_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | No | 6.30E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SUM_2013Series_Z-086_RAWL-CARS_OS)_(19SUM_Z086)_(N1_L591_BRUN_RAWL).txt | Yes | 49.49 | |
| (2019SUM_2013Series_Z-086_RAWL-CARS_OS)_(19SUM_Z086)_(N1_L595_BRUN_GRNS).txt | Yes | 51.76 | |
| (2019SUM_2013Series_Z-086_RAWL-CLOV_OS)_(19SUM_Z086)_(N1_L511_RAWL_CRSN).txt | Yes | 48.8 | |
| (2019SUM_2013Series_Z-086_RAWL-CLOV_OS)_(19SUM_Z086)_(N1_L570_BRUN_WAKE).txt | Yes | 46.4 | |
| (2019SUM_2013Series_Z-086_RAWL-CLOV_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | Yes | 56.65 | |
| (2019SUM_2013Series_Z-086_RAWL-CLOV_OS)_(19SUM_Z086)_(N1_L591_BRUN_RAWL).txt | Yes | 51.82 | |
| (2019SUM_2013Series_Z-086_RAWL-CLOV_OS)_(19SUM_Z086)_(N1_L595_BRUN_GRNS).txt | Yes | 54.49 | |
| (2019SUM_2013Series_Z-086_Z086-CARS_OS)_(19SUM_Z086)_(N1_L511_RAWL_CRSN).txt | Yes | 130.5 | |
| (2019SUM_2013Series_Z-086_Z086-CARS_OS)_(19SUM_Z086)_(N1_L556_CLOV_RAWL).txt | Yes | 46.02 | |
| (2019SUM_2013Series_Z-086_Z086-CARS_OS)_(19SUM_Z086)_(N1_L570_BRUN_WAKE).txt | Yes | 60.4 | |

| | | | |
|--|-----|----------|-------------------------------|
| (2019SUM_2013Series_Z-086_Z086-CARS_OS_(19SUM_Z086_(N1_L591_BRUN_RAWL).txt | No | 6.61E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SUM_2013Series_Z-086_Z086-CARS_OS_(19SUM_Z086_(N1_L595_BRUN_GRNS).txt | No | 8.89E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SUM_BrunsOn_BRUNS-CARS_OS_(19SUM_Z086_(N1_L591_BRUN_RAWL).txt | Yes | 57.01 | |
| (2019SUM_BrunsOn_BRUNS-RAWL_OS_(19SUM_Z086_(N1_L595_BRUN_CARS).txt | Yes | 55.98 | |
| (2019SUM_BrunsOn_RAWL-CARS_OS_(19SUM_Z086_(N1_L595_BRUN_CARS).txt | Yes | 53.21 | |
| (2019SUM_N11_CARS2_BRUNS-RAWL_OS_(19SUM_Z086_(N1_L585_GRNS_CRSN).txt | Yes | 55.47 | |
| (2019SUM_N11_CARS2_BRUNS-RAWL_OS_(19SUM_Z086_(N1_L595_BRUN_GRNS).txt | Yes | 47.04 | |
| (2019SUM_N11_CARS2_RAWL-CARS_OS_(19SUM_Z086_(N1_L585_GRNS_CRSN).txt | Yes | 54.98 | |
| (2019SUM_N11_CARS2_RAWL-CARS_OS_(19SUM_Z086_(N1_L595_BRUN_GRNS).txt | Yes | 55.34 | |
| (2019SUM_N11_CARS2_Z086-CARS_OS_(19SUM_Z086_(N1_L591_BRUN_RAWL).txt | Yes | 55.17 | |
| (2019SUM_PSS1_1376_BR_OS_(2019SUM_PSS_(N1_L585_GRNS_CRSN).txt | Yes | 80.04 | |
| (2019SUM_Z-086_NoBruns_BRUNS-RAWL_OS_(19SUM_Z086_(N1_L585_GRNS_CRSN).txt | No | 1.47E+05 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SUM_Z-086_NoBruns_RAWL-CARS_OS_(19SUM_Z086_(N1_L585_GRNS_CRSN).txt | Yes | 91.61 | |
| (2019SUM_Z-086_NoBruns_RAWL-CARS_OS_(19SUM_Z086_(N1_L595_BRUN_GRNS).txt | Yes | 43.83 | |
| (2019SUM_Z-086_NoBruns_Z086-CARS_OS_(19SUM_Z086_(N1_L591_BRUN_RAWL).txt | No | 1.47E+05 | ANGL916375[Z1-086_ST 23.000]1 |

Appendix 6

| Description | Case Name | Stable? | Max Angle | Element |
|---|--|---------|-----------|-------------------------------|
| SLL Case - Z1-086 & Brunswick @ Pmax | (2019SLL_2013Series_Z-086_BRUNS-RAWL_OS)_(2019SLL_PSS2A)_(N1_L585_GRNS_CRSN).txt | No | 5.18E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| | (2019SLL_2013Series_Z-086_BRUNS-RAWL_OS)_(2019SLL_Z086)_(N1_L585_GRNS_CRSN).txt | No | 6.66E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| | (2019SLL_2013Series_Z-086_Z086-CARS_OS)_(2019SLL_Z086)_(N1_L591_BRUN_RAWL).txt | No | 6.66E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| SLL Case - Z1-086 Dispatched to 1207 MW | (2019SLL_1207_NoBruns_BRUNS-RAWL_OS)_(2019SLL_Z086)_(N1_L585_GRNS_CRSN).txt | Yes | 87.08 | |
| | (2019SLL_1207_NoBruns_RAWL-CARS_OS)_(2019SLL_Z086)_(N1_L585_GRNS_CRSN).txt | Yes | 80.9 | |
| | (2019SLL_1207_NoBruns_Z086-CARS_OS)_(2019SLL_Z086)_(N1_L591_BRUN_RAWL).txt | Yes | 61.04 | |
| SUM Case - Z1-086 Dispatched to 1207 MW | (2019SUM_1207_NoBruns_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | Yes | 58.52 | |
| SUM Case - Z1-086 Dispatched to 1376 MW | (2019SUM_1376_NoBruns_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | Yes | 80.04 | |
| | (2019SUM_1376_NoBruns_Z086-CARS_OS)_(19SUM_Z086)_(N1_L591_BRUN_RAWL).txt | Yes | 79.05 | |
| | (2019SUM_1376_NoBruns_Z086-CARS_OS)_(19SUM_Z086_Ed1)_(N1_L591_BRUN_RAWL).txt | Yes | 79.05 | |
| SUM Case - Z1-086 Dispatched to Pmax | (2019SUM_Z-086_NoBruns_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | No | 1.47E+05 | ANGL916375[Z1-086_ST 23.000]1 |
| | (2019SUM_Z-086_NoBruns_RAWL-CARS_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | Yes | 91.61 | |
| | (2019SUM_Z-086_NoBruns_RAWL-CARS_OS)_(19SUM_Z086)_(N1_L595_BRUN_GRNS).txt | Yes | 43.83 | |
| | (2019SUM_Z-086_NoBruns_Z086-CARS_OS)_(19SUM_Z086)_(N1_L591_BRUN_RAWL).txt | No | 1.47E+05 | ANGL916375[Z1-086_ST 23.000]1 |

***Generation Interconnection
System Impact Study Report***

For

***TP Generation Interconnection Request Queue
Position Z1-086***

Carson – Heritage 500kV

October 2014

Introduction

This System Impact Study (SIS) has been prepared in accordance with the TP Open Access Transmission Tariff, Section 205, as well as the System Impact Study Agreement between Virginia Electric and Power Company (Interconnection Customer (IC)) and TP Interconnection, LLC (Transmission Provider (TP)). The Interconnected Transmission Owner (ITO) is Virginia Electric and Power Company.

Preface

The intent of the System Impact Study is to determine a plan, with approximate cost and construction time estimates, to connect the subject generation interconnection project to the TP network at a location specified by the IC. As a requirement for interconnection, the IC may be responsible for the cost of constructing: Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the TP system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications (on TP web site) for the appropriate transmission owner.

In some instances an IC may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the Feasibility Study, but the actual allocation will be deferred until the System Impact Study is performed.

The System Impact Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

General

Virginia Electric and Power Company, the IC, has proposed a natural gas generating facility located at Greensville County, Virginia. The installed facilities will have a total capability of 1681 MW with 1630 MW of this output being recognized by TP as capacity. The proposed in-service date for this project is December 1, 2018. **This study does not imply an ITO commitment to this in-service date.**

Point of Interconnection

Z1-086 will interconnect with the ITO system via a new three breaker ring bus switching station that connects to the Carson – Heritage 500kV line.

Cost Summary

The Z1-086 project will be responsible for the following costs:

| Description | Total Cost |
|---|---------------------|
| Attachment Facilities | \$2,600,000 |
| Direct Connection Network Upgrades | \$6,000,000 |
| Non Direct Connection Network Upgrades | \$22,000,000 |
| Allocation for New System Upgrades | \$0 |
| Contribution for Previously Identified Upgrades | \$TBD |
| Total Costs | \$30,600,000 |

Attachment Facilities

Generation Substation: Install metering and associated Protection Equipment. Estimated Cost \$600,000.

Transmission Line: Construct approximately one span of 500 kV Attachment line between the generation substation and Z1086 Switching Substation. The estimated cost for this work is \$2,000,000.

The estimated total cost of the Attachment Facilities is \$2,600,000. It is estimated to take 18-24 months to complete this work after execution of Interconnection Service Agreement (ISA) and Interconnection Construction Service Agreement (ICSA). These preliminary cost estimates are based on typical engineering costs. A more detailed engineering cost estimates are normally done when the IC provides an exact site plan location for the generation substation during the Facility Study phase. The single line is shown below in Attachment 1.

Direct Connection Cost Estimate

Substation: TP network upgrade # n4300 to establish the new 500 kV Z1086 Switching Substation (interconnection substation). The arrangement in the substation will be as shown below on Attachment 1: One-Line Diagram. The estimated cost of this facility is \$6,000,000. It is estimated to take 24-36 months to complete this work after execution of ISA and ICSA.

Non-Direct Connection Cost Estimate

TP network upgrade n4258 to uprate the Carson to Rawlings 500 kV line to approximately 4300 MVA. The estimated cost is \$22,000,000. It is estimated to take 20 months to complete. The time line to complete is based on being able to obtain outages to uprate line.

Interconnection Customer Requirements

VEPCO Facility Connection Requirements as posted on TP's website
<http://www.TP.com/~media/planning/plan-standards/private-dominion/facility-connection-requirements1.ashx>

Revenue Metering and SCADA Requirements

PJM Requirements

The IC will be required to install equipment necessary to provide Revenue Metering (KWH, KVARH) and real time data (KW, KVAR) for IC's generating Resource. See TP Manuals M-01 and M-14D, and TP Tariff Sections 24.1 and 24.2.

Network Impacts

The Queue Project Z1-086 was studied as a 1630.0 MW (Capacity 1630.0 MW) injection tapping the Carson – Brunswick 500 kV line in the ITO area. Project Z1-086 was evaluated for compliance with applicable reliability planning criteria (TP, NERC, NERC Regional Reliability Councils, and Transmission Owners) for summer peak conditions in 2017. The stability analysis used a 2019 model and 1681MW injection. Queue project Z1-086 was studied with a commercial probability of 100%. Potential network impacts were as follows:

Contingency Descriptions

The following contingencies resulted in overloads:

| Contingency Name | Description |
|-------------------------------|--|
| 1127_B2_A | CONTINGENCY '1127_B2_A' OPEN BRANCH FROM BUS 314902 TO BUS 916370 CKT 1 / 314902 8CARSON 500 916370 Z1-086 500 1 END |
| 8MORRSVL _8NO ANNA _033 | CONTINGENCY '8MORRSVL _8NO ANNA _033' DISCONNECT BRANCH FROM BUS 314916 TO BUS 314918 CKT 1 /* 500/500KV, AREA 345/345. END |

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

| Overload | | Contingency | | | Bus | | | | Loading % | | Rating | | MW | | Flowgate |
|----------|------|-------------|---------------|-----------------------------------|--------|--------|---------|------------|-----------|--------|--------|-----|--------------|----------|----------|
| Number | Type | Name | Affected Area | Facility Description | From | To | Circuit | Power Flow | Initial | Final | Type | MVA | Contribution | Appendix | |
| 1 | N-1 | 1127_B2_A | CPLD - DVP | 6PERSON230 T-6HALIFAX 230 kV line | 304070 | 314697 | 1 | DC | 97.42 | 131.8 | ER | 712 | 244.79 | 1 | |
| 2 | N-1 | 1127_B2_A | DVP - DVP | 6HALIFAX-6CLOVER 230 kV line | 314697 | 314686 | 1 | AC | 82.18 | 112.47 | ER | 749 | 226.93 | 2 | |

TP network upgrades n3289, n3290, and n3292 to build a 14 mile Heritage to Rawlings 500kV Line to approximately 3402 MVA. Work includes the Rawlings switching substation and re-arrangement at Carson substation. Included in this is a portion of the network upgrade n3287 to connect the new line into Heritage. These network upgrades were previously identified in TP Queue X2-076 due to the violations identified in Duke Progress. The cost allocation for \$85,000,000 between the X2-076 project and the Z1-086 project will be determined during the facility study while performing a joint study with Duke Progress.

- Install three breaker ring bus substation (Rawlings) on line 556 (n3289). The estimated cost is \$6,000,000.
- Construct new 500 kV 591 line between line 570 and 556 (n3290). The estimated cost is \$78,000,000.
- Rearrange the Carson 500 kV substation configuration to separate line 556 and 570 from the same breaker bay (n3292). The estimated cost is \$1,000,000.
- Construct one bay of the seven breaker switching substation (Heritage) for the new 591 line (portion of n3287).

With the network upgrades above added to the study an additional thermal violation was identified.

| Overload | | Contingency | | | Bus | | | | Loading % | | Rating | | MW | |
|----------|------|-------------|---------------|-------------------------------|--------|--------|---------|------------|-----------|--------|--------|------|--------------|--|
| Number | Type | Name | Affected Area | Facility Description | From | To | Circuit | Power Flow | Initial | Final | Type | MVA | Contribution | |
| 3 | N-1 | 1127_B2_A | DVP - DVP | 556BKRSTA-8CARSON 500 kV line | 314995 | 314902 | 1 | AC | 75.69 | 102.55 | ER | 3402 | 923.75 | |

TP network upgrade n4258 to uprate the Carson to Rawlings 500 kV Line to approximately 4300 MVA. The estimated cost is \$22,000,000. It is estimated to take 20 months to complete. The time line to complete is based on being able to obtain outages to uprate line.

| Queue | MW contribution | Percentage of Cost | Cost(\$M) |
|--------|-----------------|--------------------|-----------|
| Z1-086 | 86.75 | 100.00% | 22.0000 |

Multiple Facility Contingency

(Double Circuit Tower Line contingencies were studied for the full energy output. The contingencies of Line with Failed Breaker and Bus Fault will be performed for the Impact Study.)

None

Short Circuit

(Summary of impacted circuit breakers)

New circuit breakers found to be over-duty:

None

Contributions to previously identified circuit breakers found to be over-duty:

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the TP Queue)

| Overload Number | Contingency Type | Contingency Name | Affected Area | Facility Description | Bus | | Circuit | Power Flow | Loading % | | Rating Type | MVA | MW Contribution | Flowgate Appendix |
|-----------------|------------------|-----------------------|---------------|-------------------------------|--------|--------|---------|------------|-----------|--------|-------------|------|-----------------|-------------------|
| | | | | | From | To | | | Initial | Final | | | | |
| 4 | N-1 | 8MORRSVL_8NO ANNA_033 | DVP - DVP | 8NO ANNA-8LDYSMTH 500 kV line | 314918 | 314911 | 1 | DC | 103.7 | 112.61 | ER | 3219 | 291.53 | 4 |

TP network upgrade n0718.1 to build a 15-mile long North Anna – Lady Smith 2nd 500 kV line and install 500 kV breakers at North Anna and Ladysmith Stations. The estimated cost is \$44,000,000. It is estimated to take 30 months to complete. Previously identified in PJM Queue Q65.

| Queue | MW contribution | Percentage of Cost | Cost(\$44M) |
|--------|-----------------|--------------------|-------------|
| Q65 | 400.00 | 43.57% | 19.1697 |
| X2-076 | 226.59 | 24.68% | 10.8590 |
| Z1-086 | 291.53 | 31.75% | 13.9713 |

Steady-State Voltage Requirements

(Summary of the VAR requirements based upon the results of the steady-state voltage studies)

None

Stability and Reactive Power Requirement for Low Voltage Ride Through

(Summary of the VAR requirements based upon the results of the dynamic studies)

Requirements

The following actions are required for Z1-086:

1. **Operating Restrictions:** There are N-1-1 operating conditions (such as maintenance outage) that result in transient instability with the addition of the Greenville units (Z1-086). Specifically, the following N-1 system conditions (pre-contingency) result in transient instability and/or poorly damped oscillations for the next contingency:
 - Brunswick-Rawlings 500kV line O/S
 - Z1-086-Carson 500kV line O/S
 - Rawlings-Carson 500kV line O/S

To mitigate this instability, immediate operating restrictions must be enforced following an N-1 (planned or forced). For any of the system conditions defined above, without further study, generation at this location (Brunswick/Greenville) must be limited to:

Operating Restriction Recommendation Table

| Online Generation | Brunswick Max Output [MW] | Z1-086 Max Output [MW] |
|-------------------------------|---------------------------|------------------------|
| If Brunswick is Offline... | N/A | <1200 |
| If Z1-086 is Offline... | 1376 (max) | N/A |
| If both Plants are Online...* | 1376 (max)* | 0* |

*This assumes Brunswick is dispatched to full capacity. Z1-086 must be restricted to below its Pmin output of 862 MW. This assumes that the unit is normally operated with all combustion turbines running and the steam running at Pmin quantity.

It is noted that Z1-086 is less stable than the Brunswick plant based on the parameters provided. Therefore, it must be restricted to a lower MW limit than Brunswick. These operating restrictions likely will require additional studies and possible further restriction on the units' output. This also is studied under 2019 light load and summer peak

conditions, and does not cover all possible system conditions. Therefore, system conditions could arise in the operational timeframe that could further limit the units' output.

2. **Installation of out-of-step protection:** This study was made using a certain set of operating conditions. There may be other operating conditions, although less probable, that can create stability problems either during high transfer or high voltage conditions. It is the Customer's responsibility to protect their own equipment from damage due to disturbances on the transmission system by installing out-of-step protection on their generators.

Recommendations

The following actions are recommended for Z1-086:

1. **Additional PSS Tuning Studies:** It is strongly recommended that additional PSS tuning studies be performed to ensure that the power system stabilizer is sufficiently damping out the oscillations of interest. The model provided uses the PSS2B model in PSS/e, whereas similar plants such as Warren County Power Station use the PSS2A model. Parameters are slightly modified between the two and should be investigated further. This could help lessen the restrictions identified above.
2. **Construction of Z1-086-Carson #2 500kV line:** For N-1-1 operating conditions (such as maintenance outage), the combination of Z1-086 and the existing Brunswick generating facility results in transient instability for a number of contingencies. These operating conditions can occur during times of maintenance and forced outage. Specifically, generation remaining connected to the grid solely through Brunswick-Wake 500kV line results in insufficient synchronizing torque to maintain stability. To mitigate this potentially unstable condition, and also to maintain voltage stability in the Clover area, the addition of Z1-086-Carson #2 500kV line provides a sufficiently strong connection to the grid at a low cost relative to other transmission infrastructure solutions.
3. **Coordinated Study with Duke / Progress Energy:** It is recommended that TP coordinate with Progress to ensure there are no negative impacts by the proposed Z1-086 project on their network. A study comprising both ITO and Duke / Progress Energy systems to develop comprehensive Operating Restrictions may be warranted.

For more details see Attachment 2.

Light Load Analysis

(Study to determine that the Transmission System is capable of delivering the system generating capacity at light load)

Not required

Potential Congestion due to Local Energy Deliverability

TP also studied the delivery of the energy portion of this interconnection request. Any problems identified below are likely to result in operational restrictions to the project under study. The IC can proceed with network upgrades to eliminate the operational restriction at their discretion by submitting a Merchant Transmission Interconnection request.

Note: Only the most severely overloaded conditions are listed below. There is no guarantee of full delivery of energy for this project by fixing only the conditions listed in this section. With a Transmission Interconnection Request, a subsequent analysis will be performed which shall study all overload conditions associated with the overloaded element(s) identified.

Not applicable

ITO Analysis

ITO assessed the impact of the proposed Queue Project #Z1-086 interconnection as 1681MW of energy (Capacity 1630.0 MW) for compliance with reliability criteria on ITO's Transmission System. The system was assessed using the summer 2017 RTEP case provided to ITO by TP. When performing a generation analysis, ITO's main analysis will be load flow study results under single contingency (both normal and stressed system conditions). ITO's Criteria considers a transmission facility overloaded if it exceeds 94% of its emergency rating under normal and stressed system conditions. A full listing of ITO's Planning Criteria and interconnection requirements can be found in the ITO's Facility Connection Requirements which are publicly available at: <http://www.dom.com>.

The results of these studies evaluate the system under a limited set of operating conditions and do not guarantee the full delivery of the capacity and associated energy of this proposed generation facility under all operating conditions. NERC Planning and Operating Reliability Criteria allow for the re-dispatch of generating units to resolve projected and actual deficiencies in real time and planning studies. Specifically NERC Category C Contingency Conditions (Bus Fault, Tower Line, N-1-1, and Stuck Breaker scenarios) allow for re-dispatch of generating units to resolve potential reliability deficiencies. For ITO's Planning Criteria the re-dispatch of generating units for these contingency conditions is allowed as long as the projected loading does not exceed 100% of a facility Load Dump Rating.

As part of its generation impact analysis ITO routinely evaluates the impact that a proposed new generation resource will have under maximum generation conditions, stress system conditions and import/export system conditions. The results of these studies are discussed in more detail below.

A. Category B Analysis (Single Contingency):

1. System Normal – No deficiencies identified
2. Critical System Condition (No Surry 230 kV Unit) – No deficiencies identified.

B. Category C Analysis: (Multiple Facility Analysis)

1. Bus Fault - No deficiencies identified
2. Line Stuck Breaker - No deficiencies identified
3. Tower Line – No deficiencies identified

C. The import and export conditions into and out of the ITO System are evaluated with any new interconnection greater than 20 MW, any new facility that is interconnected with the ITO System should not significantly decrement First Contingency Incremental Transfer Capacity between utilities. The results of these studies can be found in Tables A and B for both with and without Z1-086.

Table A: Import Study Results

| Import Study Results | | | |
|-----------------------------|--------------------|--------------------------------|-------------------------|
| Area | Summer 2017 | Summer 2017 with Z1-086 | Limiting Element |
| AEP | 2000+ | 2000+ | None |
| APS | 2000+ | 2000+ | None |
| CPL | 2000+ | -411 | None |
| TP | 2000+ | 2000+ | None |


Table B: Export Study Results

| Export Study Results | | | |
|-----------------------------|--------------------|--------------------------------|-------------------------|
| Area | Summer 2017 | Summer 2017 with Z1-036 | Limiting Element |
| AEP | 2000+ | 2000+ | None |
| APS | 2000+ | 2000+ | None |
| CPL | 2000+ | 2000+ | None |
| TP | 2000+ | 2000+ | None |

ITO's Planning Criteria indicates a need to have approximately 2000 MW of import and export capability. The results of these import and export studies indicate that the proposed generation facility will impact ITO's import or export capability. Upgrades required to reliably interconnect the proposed generating facility with ITO's Transmission Facilities will resolve the identified deficiencies.

Attachment 1. Z1-086

Single Line



3-28-14

Attachment 2.

Z1-086 Stability Study Report

Introduction

This study evaluates the stability and dynamics for TP queue project Z1-086 on the ITO transmission system facilities only. The Z1-086 project is a combined cycle comprising of one steam turbine generator (ST) and three combustion turbine generators (C1, C2, C3) connecting to a new facility located approximately 0.5 miles from the new Brunswick 500kV switching station along the new Brunswick-Carson 500kV line. This new Brunswick 500kV substation is a new switching station added to the existing Carson-Wake 500kV line approximately 30 miles from Carson and 90 miles from Wake. Z1-086 queue project requests 1630 MW capacity / 1681 MW energy at the point of interconnection.

For this stability study, the Z1-086 project was studied with total net generating output of 1681 MW delivered to the grid (combustion and steam units modeled with 12.5 MW and 5.0 MW stations service, respectively).

Note: This study by ITO does not evaluate the stability and dynamic impacts for the above mentioned queue project for faults on the Duke / Progress Energy system.

Analysis

The stability study for Z1-086 was performed using the 2019 heavy summer base case and 2019 light load base case conditions. The most severe contingencies were studied for this particular generating resource to ensure transient stability during and immediately after faults on the transmission system. Three phase faults with normal clearing and single-line-to-ground faults with delayed clearing were studied. For the purposes of this study, fault clearing time is:

- 500kV normal clearing: 3 cycle and 4 cycle for near and far side, respectively.
- 500kV delayed clearing: 12 cycle near side (delayed clearing with backup) and 4 cycle far side.

Queue project Z1-086 was modeled as one 23 kV steam generator and three 20 kV combustion generators (see Appendix 4). The generators were dispatched into leading power factor region as required by ITO Planning criteria. In general, the units were dispatched at approximately 50% under-excitation (about 50% of Qmin) for each N-0 base case condition studied. The generators have the following MW and MVAR output characteristics.

Table 1. Generator Output Characteristics

| | ST | C1 | C2 | C3 |
|--------------|-----|------|------|------|
| Pmax [MW] | 629 | 365 | 365 | 365 |
| Station Load | 5 | 12.5 | 12.5 | 12.5 |

| | | | | |
|-----------------|------|------|------|------|
| [MW] | | | | |
| Qmax [MVAR] | 368 | 169 | 169 | 169 |
| Qmin [MVAR] | -262 | -160 | -160 | -160 |
| 50% Qmin [MVAR] | -131 | -80 | -80 | -80 |

Note: N-1-1 transient stability analysis did not consider redispatch of the units' MW output prior to applying the next N-1 contingency in dynamics (time step integration); however, the units were set with 50% under-excitation in all cases (unless terminal voltage below 0.95 pu). The terminal voltage in each of the cases is shown in the table below:

Table 2. Base Case Conditions

| Root Case | Operating Cond | Condition | 500kV | C1/C2/C3 | ST |
|-----------|------------------------|-----------------|--------|----------|--------|
| 2019SLL | | N-0 Base | 1.0349 | 0.9539 | 0.9626 |
| | | BRUNS-RAWL O/S | 1.0341 | 0.9531 | 0.9618 |
| | | Z1-086-CARS O/S | 1.0360 | 0.9550 | 0.9637 |
| | | RAWL-CARS O/S | 1.0348 | 0.9538 | 0.9625 |
| | | Z1-086-CARS O/S | 1.0349 | 0.9539 | 0.9626 |
| | CARS #2 Add | N-0 Base | 1.0349 | 0.9539 | 0.9626 |
| | CARS #2 Add | BRUNS-RAWL O/S | 1.036 | 0.9550 | 0.9637 |
| 2019SUM | | N-0 Base | 1.0341 | 0.9531 | 0.9618 |
| | BRUNS ONLY – No Z1-086 | N-0 Base | | | |
| | BRUNS ONLY – No Z1-086 | BRUNS-RAWL O/S | | | |
| | BRUNS ONLY – No Z1-086 | RAWL-CARS O/S | | | |

| | | | | | |
|--|------------------------|-----------------|--------|---------|-----------|
| | Z1-086 ONLY – No BRUNS | N-0 Base | 1.0254 | 0.9509 | 0.9566 |
| | | | | -60MVAR | -110 MVAR |
| | | BRUNS-RAWL O/S | 1.0327 | 0.9517 | 0.9604 |
| | | BRUNS-WAKE O/S | 1.0339 | 0.9529 | 0.9617 |
| | | RAWL-CLOV O/S | 1.0908 | 0.9498 | 0.9586 |
| | | Z1-086-CARS O/S | 1.0339 | 0.9529 | 0.9617 |
| | CARS #2 Add | RAWL-CARS O/S | 1.0351 | 0.9541 | 0.9628 |
| | CARS #2 Add | BRUNS-RAWL O/S | 1.0401 | 0.9591 | 0.9678 |
| | CARS #2 Add | RAWL-CARS O/S | 1.0385 | 0.9575 | 0.9575 |
| | CARS #2 Add | Z1-086-CARS O/S | 1.0341 | 0.9531 | 0.9618 |

Results

Results – 2019 Heavy Summer and Light Load

Stability results in tabular form regarding transient swing angle are provided in Appendix 5. Absolute angle is shown, and very large absolute angle is indication of out-of-step conditions. Further analysis is performed for oscillation damping analysis of concern. Observations regarding transient stability performance for Z1-086 and the Brunswick generating facility are as follows:

1. Z1-086 (and Brunswick plant) maintains transient stability with acceptable swing angle for all N-1 three-phase (3P) fault conditions and breaker failure single-line-to-ground (SLG) fault conditions. Oscillation damping for these contingencies is acceptable according to ITO Planning criteria.
2. N-1 maintenance outages pose a stability restriction on safe and reliable operation of the Z1-086 project as well as Brunswick generating facility. Complete simulation results are included in the Appendix 5 and 6.

- Loss of Carson-Z1-086 500kV line with Rawlings-Brunswick 500kV line out-of-service (O/S) results in instability.
 - Loss of Rawlings-Brunswick 500kV line with Carson-Z1-086 line O/S is unstable.
 - Loss of Z1-086-Carson 500kV line with Rawlings-Carson 500kV O/S results in severe transient instability at Brunswick, Z1-086, and Clover generating plants.
3. Transient stability results demonstrate that if Brunswick generating facility is generating at full capacity, Z1-086 will be forced to shut down due to operating restriction and minimum output (Pmin) requirements (as modeled in the case).
 4. Stability results demonstrate a lower frequency oscillation in the 0.02-0.05 Hz range that is an indication that further PSS tuning studies should be performed to improve stability for these conditions.

Results – Operating Restrictions

To understand how generation in this area must be dispatched for an N-1 pre-contingency outage (forced or planned), three distinct conditions are considered:

1. Brunswick Generation Online Only – Z1-086 is offline.
2. Z1-086 Generation Online Only – Brunswick is offline.
3. Combined output of Brunswick & Z1-086 – Brunswick is assumed to have full capacity rights and priority is given to dispatching Brunswick for this analysis.

Results from this analysis in terms of maximum absolute angle are shown in Appendix 6.

Oscillation damping results for restricted output conditions are also considered by analyzing transient ringdown. Results for oscillation ringdown analysis are shown in the table below.

Table 3. Restricted Output Modal Analysis

| BRUNSWICK ONLY | | | | |
|--------------------------|-----------|-----------------|-----------|-----------|
| Window 1 | Freq [Hz] | 1.053 | 0.282 | 0.718 |
| | Real | -0.180646 | -1.3404 | -0.432645 |
| | Imaginary | 6.61367 | 1.77036 | 4.51225 |
| | Energy | 16.156 | 5.5723 | 3.0951 |
| | Damping % | 2.730385 | 60.363397 | 9.5444593 |
| Window 2 | Freq [Hz] | 1.05 | 0.862 | 0.688 |
| | Real | -0.220996 | -0.327488 | -1.05016 |
| | Imaginary | 6.59975 | 5.41622 | 4.32335 |
| | Energy | 9.7463 | 3.3758 | 3.093 |
| | Damping % | 3.3466753 | 6.0354084 | 23.604054 |
| 1376 MW Reduction | | | | |
| Window 1 | Freq [Hz] | 0.977 | 0.859 | 0.634 |
| | Real | -0.1129 | -0.121443 | -0.3231 |

| | | | | |
|----------|-----------|-----------|-----------|-----------|
| | Imaginary | 6.13923 | 5.39799 | 3.98401 |
| | Energy | 9.699 | 3.9317 | 2.0939 |
| | Damping % | 1.838682 | 2.2492127 | 8.0833805 |
| Window 2 | Freq [Hz] | 0.565 | 0.829 | 0.982 |
| | Real | -1.9465 | -1.59522 | -0.11907 |
| | Imaginary | 3.55038 | 5.20645 | 6.16739 |
| | Energy | 8.8779 | 8.385 | 7.2901 |
| | Damping % | 48.074098 | 29.295081 | 1.9302787 |

1207 MW Reduction

| | | | | |
|----------|-----------|-----------|----------|-----------|
| Window 1 | Freq [Hz] | 0.999 | 0.865 | 0.642 |
| | Real | -0.270063 | -0.17618 | -0.242455 |
| | Imaginary | 6.27381 | 5.43487 | 4.03451 |
| | Energy | 12.882 | 4.658 | 1.7077 |
| | Damping % | 4.3006265 | 3.239958 | 5.9987056 |

The following observations are made:

1. Brunswick Generation Only – Brunswick experiences relatively low damping ratio for the system conditions used. This is a separate issue that will need to be addressed. However, this is used as a baseline for this analysis in terms of oscillatory and transient stability.
2. Z1-086 Generation Only – At full output, Z1-086 is transient unstable for N-1-1 contingencies.
 - a. Therefore, MW output is restricted first to 1376 MW (to match Brunswick output) in the 2019SUM heavy summer case (which is more stable). Although the unit maintains synchronism, oscillation damping is insufficient.
 - b. Generating output is set to 1207, which is approximately 70% of maximum generating capability. The unit maintains synchronism with measured oscillation damping for the predominant mode of 0.999 Hz of 4.3% with a secondary mode of 0.865 Hz with 3.24% damping ration. This is considered sufficient for the purposes of this study, and the primary oscillation frequency is above the 4% criteria in the ITO Planning Manual.
3. Combined Brunswick & Z1-086 – For this analysis, Brunswick is dispatched at full output and Z1-086 is studied as variable scheduled generation. Results show that even with Z1-086 set to minimum output power, Pmin, oscillation damping remains negative. Therefore, it is determined that Z1-086 must remain offline when Brunswick is scheduled near full output for certain N-1 system conditions identified.




Figure 1. Undamped oscillation frequency for Brunswick + Z1-086 at Pmin.

Results – 2019 Heavy Summer with Modified PSS Settings

The tables below show oscillation ringdown analysis results for various perturbations of the PSS settings. These studies were performed on the base case with Brunswick-Rawlings 500 out of service pre-contingency and then the Z1-086-Carson contingency is applied, with the Brunswick unit offline and Z1-086 at 1376 MW output (to match maximum Brunswick output). Legend of case names is as follows:

- PSS0 – Data as Provided
- PSS1 – Change Washout Filters to 10 sec
- PSS2 – Change Gain to 10
- PSS3 – Change Gain to 2
- PSS4 – Change to PSS2A Model (Match Warren County Power Station)

The modal information contained below is generated from PSS/e modal analysis using Least Squares / Eigenvector Fit by Initial Points, and ensuring that small error ratio and high signal to noise ratio is achieved. Energy is ranked left to right in the table below.

Table 4. PSS Tuning Modal Analysis Results

| BRUNSWICK ONLY | | | | |
|----------------|-----------|-----------|-----------|-----------|
| Window 1 | Freq [Hz] | 1.053 | 0.282 | 0.718 |
| | Real | -0.180646 | -1.3404 | -0.432645 |
| | Imaginary | 6.61367 | 1.77036 | 4.51225 |
| | Energy | 16.156 | 5.5723 | 3.0951 |
| | Damping % | 2.730385 | 60.363397 | 9.5444593 |
| Window 2 | Freq [Hz] | 1.05 | 0.862 | 0.688 |
| | Real | -0.220996 | -0.327488 | -1.05016 |
| | Imaginary | 6.59975 | 5.41622 | 4.32335 |
| | Energy | 9.7463 | 3.3758 | 3.093 |
| | Damping % | 3.3466753 | 6.0354084 | 23.604054 |

PSS0

| | | | | |
|----------|-----------|-----------|-----------|-----------|
| Window 1 | Freq [Hz] | 0.953 | 0.925 | 0.563 |
| | Real | -0.161419 | -0.188842 | 0.0058838 |
| | Imaginary | 5.98723 | 5.80938 | 3.53445 |
| | Energy | 28.083 | 22.819 | 0.54607 |
| | Damping % | 2.6950755 | 3.2489234 | -0.166471 |
| Window 2 | Freq [Hz] | 0.981 | 0.873 | 0.68 |
| | Real | -0.114955 | -0.155767 | -1.32441 |
| | Imaginary | 6.1636 | 5.48389 | 4.27027 |
| | Energy | 6.4491 | 3.5218 | 2.1548 |
| | Damping % | 1.8647383 | 2.839302 | 29.622657 |

PSS1

| | | | | |
|----------|-----------|-----------|-----------|-----------|
| Window 1 | Freq [Hz] | 0.96 | 0.916 | 1.41 |
| | Real | -0.102707 | -0.281596 | -0.36387 |
| | Imaginary | 6.03318 | 5.758 | 8.8533 |
| | Energy | 15.41 | 14.566 | 0.2621 |
| | Damping % | 1.7021226 | 4.8846796 | 4.106526 |
| Window 2 | Freq [Hz] | 0.982 | 0.874 | 0.679 |
| | Real | -0.0993 | -0.143068 | -1.18524 |
| | Imaginary | 6.16873 | 5.48918 | 4.26742 |
| | Energy | 6.7119 | 3.2217 | 1.9723 |
| | Damping % | 1.6095231 | 2.605479 | 26.761149 |

PSS2

| | | | | |
|----------|-----------|-----------|-----------|-----------|
| Window 1 | Freq [Hz] | 0.898 | 0.947 | 1.325 |
| | Real | -0.392178 | -0.160423 | -1.10344 |
| | Imaginary | 5.6453 | 5.94978 | 8.32253 |
| | Energy | 15.196 | 11.004 | 0.25627 |
| | Damping % | 6.9302796 | 2.695305 | 13.143449 |
| Window 2 | Freq [Hz] | 0.976 | 0.866 | 0.646 |
| | Real | -0.221911 | -0.152419 | -0.98247 |
| | Imaginary | 6.13361 | 5.44092 | 4.05989 |
| | Energy | 3.8846 | 3.2778 | 1.0529 |
| | Damping % | 3.6155854 | 2.8002476 | 23.520527 |

PSS3

| | | | | |
|----------|-----------|-----------|-----------|----------|
| Window 1 | Freq [Hz] | 0.971 | 0.905 | 1.431 |
| | Real | -0.046875 | -0.286146 | -1.12292 |
| | Imaginary | 6.1014 | 5.68323 | 8.98932 |
| | Energy | 13.018 | 9.9402 | 0.40152 |

| | | | | |
|----------|-----------|-----------|-----------|-----------|
| | Damping % | 0.7682436 | 5.0285488 | 12.395376 |
| Window 2 | Freq [Hz] | 0.982 | 0.874 | 0.701 |
| | Real | -0.044479 | -0.123643 | -1.02159 |
| | Imaginary | 6.17307 | 5.49178 | 4.40707 |
| | Energy | 8.8839 | 3.0369 | 1.8017 |
| | Damping % | 0.7205142 | 2.250849 | 22.581931 |

PSS4

| | | | | |
|----------|-----------|-----------|-----------|-----------|
| Window 1 | Freq [Hz] | 0.763 | 0.828 | 0.954 |
| | Real | -1.06275 | -0.046525 | -0.103629 |
| | Imaginary | 4.79232 | 5.20437 | 5.99106 |
| | Energy | 5.0499 | 3.7681 | 1.8523 |
| | Damping % | 21.650141 | 0.8939188 | 1.7294686 |
| Window 2 | Freq [Hz] | 0.847 | 0.937 | 0.88 |
| | Real | -0.179459 | -0.393072 | -1.24357 |
| | Imaginary | 5.31872 | 5.88474 | 5.52795 |
| | Energy | 7.0207 | 4.7917 | 2.4065 |
| | Damping % | 3.3721823 | 6.6646625 | 21.947545 |

The results show no major improvement by increasing the washout filter time constants. Oscillation damping is moderately improved for an increase in PSS Gain from 5 to 10, and conversely negatively impacted by a reduction in PSS Gain from 5 to 2. Mirroring the Warren County Power Station units' PSS settings on the Z1-086 model does not produce sufficient damping, leading to the conclusion that it may not necessarily be an issue with the PSS. But further study is required.

Results – 2019 Heavy Summer and Light Load w/ Added Z1-086-Carson #2 500kV Line

Stability results in tabular form regarding transient swing angle are provided in Appendix 5. Observations regarding transient stability performance for Z1-086 and the Brunswick generating facility are as follows:

1. Z1-086 (and Brunswick plant) maintains transient stability with acceptable swing angle for all identified transient unstable conditions in the 2019SUM and 2019SLL discussed above. Oscillation damping is also improved for this addition.
2. In the N-1-1 conditions, all credible contingencies result in transient stability with the additional Z1-086-Carson #2 line.

Appendices

The following appendices contain additional information about each flowgate presented in the body of the report. For each appendix, a description of the flowgate and its contingency was included for convenience. However, the intent of the appendix section is to provide more information on which projects/generators have contributions to the flowgate in question. Although this information is not used "as is" for cost allocation purposes, it can be used to gage other generators impact.

It should be noted the generator contributions presented in the appendices sections are full contributions, whereas in the body of the report, those contributions take into consideration the commercial probability of each project.

Appendix 1

CONTINGENCY '1127_B2_A'

OPEN BRANCH FROM BUS 314902 TO BUS 916370 CKT 1
500 916370 Z1-086 500 1

/ 314902 8CARSON

END

| Bus Number | Bus Name | Full Contribution |
|------------|-----------|-------------------|
| 242750 | 05PHILPO | 0.03 |
| 315131 | 1EDGECEMA | 0.14 |
| 315132 | 1EDGECEMB | 0.14 |
| LTF | W4-049 | 7.98 |
| LTF | X2-042 | 34.53 |
| 909841 | X2-076 C | 6.51 |
| LTF | X4-041 | 8.48 |
| LTF | Y1-002 | 33.95 |
| LTF | Y1-004 | 43.79 |
| LTF | Y1-007 | 30.42 |
| LTF | Y2-004 | 17.09 |
| LTF | Y2-005 | 6.84 |
| LTF | Y2-006 | 17.55 |
| LTF | Y2-033 | 6.19 |
| LTF | Y2-034 | 20.04 |
| LTF | Y2-035 | 22.9 |
| LTF | Y2-114 | 5.61 |
| LTF | Y2-115 | 6.16 |
| LTF | Y3-028 | 10.83 |
| LTF | Y3-069 | 17.06 |
| LTF | Y3-072 | 17.06 |
| LTF | Y3-094 | 27.46 |
| LTF | Z1-025 | 12.45 |
| LTF | Z1-027 | 7.22 |
| LTF | Z1-046 | 13.64 |
| LTF | Z1-067 | 5.36 |
| LTF | Z1-071 | 4.31 |
| 916371 | Z1-086 C | 244.79 |

Appendix 2

CONTINGENCY '1127_B2_A'

OPEN BRANCH FROM BUS 314902 TO BUS 916370 CKT 1
500 916370 Z1-086 500 1

/ 314902 8CARSON

END

| Bus Number | Bus Name | Full Contribution |
|------------|-----------|-------------------|
| 242701 | 05LEESVI | 0.17 |
| 242750 | 05PHILPO | 0.04 |
| 246843 | 05SMG1 | 0.2 |
| 246844 | 05SMG2 | 0.54 |
| 246845 | 05SMG3 | 0.31 |
| 246846 | 05SMG4 | 0.55 |
| 246847 | 05SMG5 | 0.21 |
| 315150 | 1BUGGS 1 | 0.51 |
| 315151 | 1BUGGS 2 | 0.51 |
| 315131 | 1EDGECSMA | 0.15 |
| 315132 | 1EDGECSMB | 0.15 |
| 315165 | 1HURT 1 | 0.18 |
| 315166 | 1HURT 2 | 0.18 |
| 315158 | 1KERR 1 | 0.08 |
| 315159 | 1KERR 2 | 0.23 |
| 315160 | 1KERR 3 | 0.23 |
| 315161 | 1KERR 4 | 0.23 |
| 315162 | 1KERR 5 | 0.23 |
| 315163 | 1KERR 6 | 0.23 |
| 315164 | 1KERR 7 | 0.23 |
| 244221 | INDDRVL | 0.08 |
| 315167 | O06_DP01 | 0.02 |
| 315419 | Q-070 | 0.03 |
| 242889 | REUSENS | 0.01 |
| 297087 | V2-040 | 0.05 |
| 902621 | W2-049 | 0.51 |
| LTF | W4-049 | 7.4 |
| 907491 | X1-084 | 0.54 |
| LTF | X2-042 | 34.7 |
| 909841 | X2-076 C | 6.03 |
| LTF | X4-041 | 8.49 |
| LTF | Y1-002 | 33.98 |
| LTF | Y1-004 | 43.91 |
| LTF | Y1-007 | 30.5 |
| LTF | Y2-004 | 17.12 |
| LTF | Y2-005 | 6.84 |

| | | |
|--------|----------|--------|
| LTF | Y2-006 | 17.55 |
| LTF | Y2-033 | 6.17 |
| LTF | Y2-034 | 19.96 |
| LTF | Y2-035 | 21.66 |
| LTF | Y2-114 | 5.61 |
| LTF | Y2-115 | 6.16 |
| LTF | Y3-028 | 10.92 |
| LTF | Y3-069 | 17.13 |
| LTF | Y3-072 | 17.13 |
| LTF | Y3-094 | 27.66 |
| 915731 | Y3-119 C | 0.44 |
| LTF | Z1-025 | 12.45 |
| LTF | Z1-027 | 7.25 |
| LTF | Z1-046 | 13.77 |
| LTF | Z1-067 | 5.11 |
| LTF | Z1-071 | 4.4 |
| 916371 | Z1-086 C | 226.93 |

Appendix 3

CONTINGENCY '8MORRSVL_8NO ANNA_033'

DISCONNECT BRANCH FROM BUS 314916 TO BUS 314918 CKT 1
AREA 345/345.

/* 500/500KV,

END

| Bus Number | Bus Name | Full Contribution |
|------------|-----------|-------------------|
| 315170 | 1BREMO 3 | 0.31 |
| 315171 | 1BREMO 4 | 0.68 |
| 315150 | 1BUGGS 1 | 0.3 |
| 315151 | 1BUGGS 2 | 0.3 |
| 315094 | 1CHESPK1 | 16.3 |
| 315095 | 1CHESPK2 | 16.3 |
| 315096 | 1CHESPK3 | 22.17 |
| 315097 | 1CHESPK4 | 31.71 |
| 315098 | 1CHESPKA | 0.07 |
| 315099 | 1CHESPKB | 0.18 |
| 315153 | 1CLOVER1 | 2.42 |
| 315154 | 1CLOVER2 | 2.45 |
| 315131 | 1EDGECSMA | 0.24 |
| 315132 | 1EDGECSMB | 0.24 |
| 315108 | 1ELIZAR1 | 0.57 |
| 315109 | 1ELIZAR2 | 0.5 |
| 315110 | 1ELIZAR3 | 0.53 |
| 315139 | 1GASTONA | 0.5 |
| 315141 | 1GASTONB | 0.5 |
| 315260 | 1GOSPRTA | 0.01 |
| 315261 | 1GOSPRTB | 0.02 |
| 315262 | 1GOSPRTC | 0.01 |
| 315158 | 1KERR 1 | 0.06 |
| 315159 | 1KERR 2 | 0.18 |
| 315160 | 1KERR 3 | 0.18 |
| 315161 | 1KERR 4 | 0.18 |
| 315162 | 1KERR 5 | 0.18 |
| 315163 | 1KERR 6 | 0.18 |
| 315164 | 1KERR 7 | 0.18 |
| 315111 | 1LKKINGA | 0.26 |
| 315112 | 1LKKINGB | 0.26 |
| 315172 | 1LOISA A | 0.89 |
| 315173 | 1LOISA B | 0.89 |
| 315174 | 1LOISA C | 0.89 |
| 315175 | 1LOISA D | 0.89 |
| 315176 | 1LOISA E | 1.82 |
| 315225 | 1N ANNA1 | 21.88 |

| | | |
|--------|--------------|--------|
| 315226 | 1N ANNA2 | 21.54 |
| 315126 | 1ROARAP2 | 0.23 |
| 315128 | 1ROARAP4 | 0.21 |
| 315134 | 1ROAVALA | 0.75 |
| 315135 | 1ROAVALB | 0.2 |
| 315136 | 1ROSEMG1 | 0.35 |
| 315138 | 1ROSEMG2 | 0.17 |
| 315137 | 1ROSEMS1 | 0.22 |
| 315177 | 1SANNAG1 | 0.84 |
| 315179 | 1SANNAG2 | 0.84 |
| 315178 | 1SANNAS1 | 0.43 |
| 315180 | 1SANNAS2 | 0.43 |
| 315115 | 1SHAMPT1 | 0.29 |
| 315083 | 1SPRUNCA | 0.24 |
| 315084 | 1SPRUNCB | 0.24 |
| 315085 | 1SPRUNCC | 0.18 |
| 315086 | 1SPRUNCD | 0.18 |
| 315073 | 1STONECA | 4.35 |
| 315090 | 1YORKTN1 | 18.66 |
| 315091 | 1YORKTN2 | 19.36 |
| 314643 | 3O INLET | 0.08 |
| 314539 | 3UNCAMP | 2.03 |
| 314621 | 3WEYERH | 0.13 |
| 315446 | Q-065 | 1096.9 |
| 315419 | Q-070 | 0.05 |
| 297087 | V2-040 | 0.02 |
| 900671 | V4-068 C | 0.01 |
| 901081 | W1-029 C | 5.7 |
| 902241 | W2-022 C OP1 | 1.3 |
| 902621 | W2-049 | 0.21 |
| 903530 | W3-066 C1OP1 | 2.87 |
| 903531 | W3-066 C2OP1 | 2.87 |
| LTF | W4-049 | 6.16 |
| 909841 | X2-076 C | 7.5 |
| 913391 | Y1-086 C | 0.03 |
| 914001 | Y2-001 C | < 0.01 |
| 914181 | Y2-066 | 0.04 |
| 914221 | Y2-076 | 0.08 |
| 916051 | Z1-036 C | 5.64 |
| 916241 | Z1-068 C | 0.22 |
| 916371 | Z1-086 C | 291.53 |

Appendix 4

Generator Model Parameters

Combustion Turbine Generator Models:

Generator Model: GENROU
 Excitation Model: EXST1
 Governor Model: GAST
 Power System Stabilizer Model: PSS2B

Steam Turbine Generator Models:

Generator Model: GENROU
 Excitation Model: EXST1
 Governor Model: N/A
 Power System Stabilizer Model: PSS2B

```

/***** Z1-086 *****/
916372 'GENROU' 1      7.8    0.045  0.87   0.074
      4.34  0.0    2.02   1.97   0.289
      0.468 0.226  0.158  0.16   0.7 /
916372 'GAST' 1      0.04   0.1    1      5.0
      1.0    3      1.0    0.05  0.1 /
916372 'EXST1' 1     0.008  999   -999   0.5
      1.90  171.5  0.029  4.52  -1.82
      0.11  0.0    1      /
916372 'PSS2B' 1     2      0      3      0      4      1
      2      2      0.0  2      1000  2
      0.22  1.0    0.4   0.1   5
      0.28  0.02  0.28  0.02  0.25
      1.5   999   -999  999   -999
      0.05  -0.05 /
916373 'GENROU' 1      7.8    0.045  0.87   0.074
      4.34  0.0    2.02   1.97   0.289
      0.468 0.226  0.158  0.16   0.7 /
916373 'GAST' 1      0.04   0.1    1      5.0
      1.0    3      1.0    0.05  0.1 /
916373 'EXST1' 1     0.008  999   -999   0.5
      1.90  171.5  0.029  4.52  -1.82
      0.11  0.0    1      /
916373 'PSS2B' 1     2      0      3      0      4      1
      2      2      0.0  2      1000  2
      0.22  1.0    0.4   0.1   5
      0.28  0.02  0.28  0.02  0.25
      1.5   999   -999  999   -999
      0.05  -0.05 /
  
```

```

916374 'GENROU' 1      7.8    0.045  0.87   0.074
      4.34  0.0    2.02   1.97   0.289
      0.468 0.226  0.158  0.16   0.7 /
916374 'GAST' 1      0.04   0.1    1      5.0
      1.0    3      1.0    0.05  0.1 /
916374 'EXST1' 1     0.008  999   -999   0.5
      1.90  171.5  0.029  4.52  -1.82
      0.11  0.0    1      /
916374 'PSS2B' 1     2      0      3      0      4      1
      2      2      0.0  2      1000  2
      0.22  1.0    0.4   0.1   5
      0.28  0.02  0.28  0.02  0.25
  
```

| | | | | | | | |
|--------|----------|---------|-------|-------|-------|-------|---|
| | 1.5 | 999 | -999 | 999 | -999 | | |
| | 0.05 | -0.05 / | | | | | |
| 916375 | 'GENROU' | 1 | 6.7 | 0.017 | 0.74 | 0.029 | |
| | 4.05 | 0.0 | 1.60 | 1.57 | 0.258 | | |
| | 0.422 | 0.226 | 0.161 | 0.16 | 0.68 | / | |
| 916375 | 'EXST1' | 1 | 0.008 | 999 | -999 | 0.48 | |
| | 1.72 | 137.8 | 0.029 | 5.21 | -1.93 | | |
| | 0.19 | 0.0 | 1 | / | | | |
| 916375 | 'PSS2B' | 1 | 2 | 0 | 3 | 0 | 4 |
| | 2 | 2 | 0.0 | 2 | 1000 | 2 | 1 |
| | 0.247 | 1.0 | 0.4 | 0.1 | 5 | | |
| | 0.30 | 0.03 | 0.30 | 0.03 | 0.3 | | |
| | 1.5 | 999 | -999 | 999 | -999 | | |
| | 0.05 | -0.05 / | | | | | |

Appendix 5

| Case Name | Stable? | Max Angle | Element |
|--|---------|-----------|---|
| (2019SLL_1207_NoBruns_BRUNS-RAWL_OS_(2019SLL_Z086_(N1_L585_GRNS_CRNS).txt | Yes | 87.08 | |
| (2019SLL_1207_NoBruns_RAWL-CARS_OS_(2019SLL_Z086_(N1_L585_GRNS_CRNS).txt | Yes | 80.9 | |
| (2019SLL_1207_NoBruns_Z086-CARS_OS_(2019SLL_Z086_(N1_L591_BRUN_RAWL).txt | Yes | 61.04 | |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086_(FB_BRUN1).txt | No | 1.47E+05 | ANGL315105[1BRUNSWICKS119.000]S1 0.1467E+06 |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086_(FB_BRUN2).txt | No | 8.74E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086_(FB_RAWL1).txt | Yes | 82.13 | |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086_(N1_L511_RAWL_CRNS).txt | Yes | 89.55 | |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086_(N1_L556_CLOV_RAWL).txt | Yes | 77.45 | |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086_(N1_L570_BRUN_WAKE).txt | Yes | 92.46 | |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086_(N1_L585_GRNS_CRNS).txt | Yes | 97.02 | |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086_(N1_L591_BRUN_RAWL).txt | Yes | 94.06 | |
| (2019SLL_2013Series_Z-086_(2019SLL_Z086_(N1_L595_BRUN_GRNS).txt | Yes | 97.77 | |
| (2019SLL_2013Series_Z-086_BRUNS-RAWL_OS_(2019SLL_PSS2A_(N1_L585_GRNS_CRNS).txt | No | 5.18E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SLL_2013Series_Z-086_BRUNS-RAWL_OS_(2019SLL_Z086_(N1_L585_GRNS_CRNS).txt | No | 6.66E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SLL_2013Series_Z-086_Z086-CARS_OS_(2019SLL_Z086_(N1_L591_BRUN_RAWL).txt | No | 6.66E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SLL_N11_CARS2_BRUNS-RAWL_OS_(2019SLL_Z086_(N1_L585_GRNS_CRNS).txt | Yes | 92.11 | |
| (2019SLL_N11_CARS2_Z086-CARS_OS_(2019SLL_Z086_(N1_L591_BRUN_RAWL).txt | Yes | 91.31 | |
| (2019SLL_NoBruns_Z-086_BRUNS-RAWL_OS_(2019SLL_Z086_(N1_L585_GRNS_CRNS).txt | No | 1.48E+05 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SLL_NoBruns_Z-086_RAWL-CARS_OS_(2019SLL_Z086_(N1_L585_GRNS_CRNS).txt | Yes | 132.5 | |
| (2019SLL_NoBruns_Z-086_Z086-CARS_OS_(2019SLL_Z086_(N1_L591_BRUN_RAWL).txt | No | 7.90E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SLL_Z-086_PMIN_BRUNS-RAWL_OS_(2019SLL_Z086_(N1_L585_GRNS_CRNS).txt | Yes | 110.4 | |
| (2019SUM_1207_NoBruns_BRUNS-RAWL_OS_(19SUM_Z086_(N1_L585_GRNS_CRNS).txt | Yes | 58.52 | |
| (2019SUM_1376_NoBruns_BRUNS-RAWL_OS_(19SUM_Z086_(N1_L585_GRNS_CRNS).txt | Yes | 80.04 | |
| (2019SUM_1376_NoBruns_Z086-CARS_OS_(19SUM_Z086_(N1_L591_BRUN_RAWL).txt | Yes | 79.05 | |
| (2019SUM_1376_NoBruns_Z086-CARS_OS_(19SUM_Z086_Ed1_(N1_L591_BRUN_RAWL).txt | Yes | 79.05 | |
| (2019SUM_1376_PSS_BRUNS-RAWL_OS_(2019SUM_PSS0_(N1_L585_GRNS_CRNS).txt | Yes | 80.04 | |
| (2019SUM_1376_PSS_BRUNS-RAWL_OS_(2019SUM_PSS1_(N1_L585_GRNS_CRNS).txt | Yes | 80.04 | |
| (2019SUM_1376_PSS_BRUNS-RAWL_OS_(2019SUM_PSS2_(N1_L585_GRNS_CRNS).txt | Yes | 80.04 | |
| (2019SUM_1376_PSS_BRUNS-RAWL_OS_(2019SUM_PSS2A_(N1_L585_GRNS_CRNS).txt | Yes | 80.23 | |
| (2019SUM_1376_PSS_BRUNS-RAWL_OS_(2019SUM_PSS3_(N1_L585_GRNS_CRNS).txt | Yes | 80.04 | |

| | | | |
|---|-----|----------|---|
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(FB_BRUN1).txt | No | 1.47E+05 | ANGL315105[1BRUNSWICKS119.000]S1 0.1467E+06 |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(FB_BRUN2).txt | No | 8.74E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(FB_RAWL1).txt | Yes | 43.22 | |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(N1_L511_RAWL_CRSN).txt | Yes | 51.63 | |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(N1_L556_CLOV_RAWL).txt | Yes | 46.57 | |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(N1_L570_BRUN_WAKE).txt | Yes | 50.48 | |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(N1_L585_GRNS_CRSN).txt | Yes | 59.55 | |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(N1_L591_BRUN_RAWL).txt | Yes | 55.17 | |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(N1_L595_BRUN_GRNS).txt | Yes | 57.57 | |
| (2019SUM_2013Series_Z-086)_(2019SUM_2013Series_Z-086)_(P2_BRUN_GNSVL_Sim).txt | No | 1.51E+05 | ANGL315105[1BRUNSWICKS119.000]S1 0.1506E+06 |
| (2019SUM_2013Series_Z-086_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L511_RAWL_CRSN).txt | Yes | 48.53 | |
| (2019SUM_2013Series_Z-086_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L556_CLOV_RAWL).txt | Yes | 47.23 | |
| (2019SUM_2013Series_Z-086_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L570_BRUN_WAKE).txt | Yes | 55.58 | |
| (2019SUM_2013Series_Z-086_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | No | 6.63E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SUM_2013Series_Z-086_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L595_BRUN_GRNS).txt | Yes | 53.31 | |
| (2019SUM_2013Series_Z-086_BRUNS-WAKE_OS)_(19SUM_Z086)_(N1_L511_RAWL_CRSN).txt | Yes | 58.34 | |
| (2019SUM_2013Series_Z-086_BRUNS-WAKE_OS)_(19SUM_Z086)_(N1_L556_CLOV_RAWL).txt | Yes | 45.89 | |
| (2019SUM_2013Series_Z-086_BRUNS-WAKE_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | Yes | 68.15 | |
| (2019SUM_2013Series_Z-086_BRUNS-WAKE_OS)_(19SUM_Z086)_(N1_L591_BRUN_RAWL).txt | Yes | 63.09 | |
| (2019SUM_2013Series_Z-086_BRUNS-WAKE_OS)_(19SUM_Z086)_(N1_L595_BRUN_GRNS).txt | Yes | 59.36 | |
| (2019SUM_2013Series_Z-086_RAWL-CARS_OS)_(19SUM_Z086)_(N1_L556_CLOV_RAWL).txt | Yes | 45.02 | |
| (2019SUM_2013Series_Z-086_RAWL-CARS_OS)_(19SUM_Z086)_(N1_L570_BRUN_WAKE).txt | Yes | 54.01 | |
| (2019SUM_2013Series_Z-086_RAWL-CARS_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | No | 6.30E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SUM_2013Series_Z-086_RAWL-CARS_OS)_(19SUM_Z086)_(N1_L591_BRUN_RAWL).txt | Yes | 49.49 | |
| (2019SUM_2013Series_Z-086_RAWL-CARS_OS)_(19SUM_Z086)_(N1_L595_BRUN_GRNS).txt | Yes | 51.76 | |
| (2019SUM_2013Series_Z-086_RAWL-CLOV_OS)_(19SUM_Z086)_(N1_L511_RAWL_CRSN).txt | Yes | 48.8 | |
| (2019SUM_2013Series_Z-086_RAWL-CLOV_OS)_(19SUM_Z086)_(N1_L570_BRUN_WAKE).txt | Yes | 46.4 | |
| (2019SUM_2013Series_Z-086_RAWL-CLOV_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | Yes | 56.65 | |
| (2019SUM_2013Series_Z-086_RAWL-CLOV_OS)_(19SUM_Z086)_(N1_L591_BRUN_RAWL).txt | Yes | 51.82 | |
| (2019SUM_2013Series_Z-086_RAWL-CLOV_OS)_(19SUM_Z086)_(N1_L595_BRUN_GRNS).txt | Yes | 54.49 | |
| (2019SUM_2013Series_Z-086_Z086-CARS_OS)_(19SUM_Z086)_(N1_L511_RAWL_CRSN).txt | Yes | 130.5 | |
| (2019SUM_2013Series_Z-086_Z086-CARS_OS)_(19SUM_Z086)_(N1_L556_CLOV_RAWL).txt | Yes | 46.02 | |
| (2019SUM_2013Series_Z-086_Z086-CARS_OS)_(19SUM_Z086)_(N1_L570_BRUN_WAKE).txt | Yes | 60.4 | |

| | | | |
|--|-----|----------|-------------------------------|
| (2019SUM_2013Series_Z-086_Z086-CARS_OS_(19SUM_Z086_(N1_L591_BRUN_RAWL).txt | No | 6.61E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SUM_2013Series_Z-086_Z086-CARS_OS_(19SUM_Z086_(N1_L595_BRUN_GRNS).txt | No | 8.89E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SUM_BrunsOn_BRUNS-CARS_OS_(19SUM_Z086_(N1_L591_BRUN_RAWL).txt | Yes | 57.01 | |
| (2019SUM_BrunsOn_BRUNS-RAWL_OS_(19SUM_Z086_(N1_L595_BRUN_CARS).txt | Yes | 55.98 | |
| (2019SUM_BrunsOn_RAWL-CARS_OS_(19SUM_Z086_(N1_L595_BRUN_CARS).txt | Yes | 53.21 | |
| (2019SUM_N11_CARS2_BRUNS-RAWL_OS_(19SUM_Z086_(N1_L585_GRNS_CRSN).txt | Yes | 55.47 | |
| (2019SUM_N11_CARS2_BRUNS-RAWL_OS_(19SUM_Z086_(N1_L595_BRUN_GRNS).txt | Yes | 47.04 | |
| (2019SUM_N11_CARS2_RAWL-CARS_OS_(19SUM_Z086_(N1_L585_GRNS_CRSN).txt | Yes | 54.98 | |
| (2019SUM_N11_CARS2_RAWL-CARS_OS_(19SUM_Z086_(N1_L595_BRUN_GRNS).txt | Yes | 55.34 | |
| (2019SUM_N11_CARS2_Z086-CARS_OS_(19SUM_Z086_(N1_L591_BRUN_RAWL).txt | Yes | 55.17 | |
| (2019SUM_PSS1_1376_BR_OS_(2019SUM_PSS_(N1_L585_GRNS_CRSN).txt | Yes | 80.04 | |
| (2019SUM_Z-086_NoBruns_BRUNS-RAWL_OS_(19SUM_Z086_(N1_L585_GRNS_CRSN).txt | No | 1.47E+05 | ANGL916375[Z1-086_ST 23.000]1 |
| (2019SUM_Z-086_NoBruns_RAWL-CARS_OS_(19SUM_Z086_(N1_L585_GRNS_CRSN).txt | Yes | 91.61 | |
| (2019SUM_Z-086_NoBruns_RAWL-CARS_OS_(19SUM_Z086_(N1_L595_BRUN_GRNS).txt | Yes | 43.83 | |
| (2019SUM_Z-086_NoBruns_Z086-CARS_OS_(19SUM_Z086_(N1_L591_BRUN_RAWL).txt | No | 1.47E+05 | ANGL916375[Z1-086_ST 23.000]1 |

Appendix 6

| Description | Case Name | Stable? | Max Angle | Element |
|---|--|---------|-----------|-------------------------------|
| SLL Case - Z1-086 & Brunswick @ Pmax | (2019SLL_2013Series_Z-086_BRUNS-RAWL_OS)_(2019SLL_PSS2A)_(N1_L585_GRNS_CRSN).txt | No | 5.18E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| | (2019SLL_2013Series_Z-086_BRUNS-RAWL_OS)_(2019SLL_Z086)_(N1_L585_GRNS_CRSN).txt | No | 6.66E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| | (2019SLL_2013Series_Z-086_Z086-CARS_OS)_(2019SLL_Z086)_(N1_L591_BRUN_RAWL).txt | No | 6.66E+04 | ANGL916375[Z1-086_ST 23.000]1 |
| SLL Case - Z1-086 Dispatched to 1207 MW | (2019SLL_1207_NoBruns_BRUNS-RAWL_OS)_(2019SLL_Z086)_(N1_L585_GRNS_CRSN).txt | Yes | 87.08 | |
| | (2019SLL_1207_NoBruns_RAWL-CARS_OS)_(2019SLL_Z086)_(N1_L585_GRNS_CRSN).txt | Yes | 80.9 | |
| | (2019SLL_1207_NoBruns_Z086-CARS_OS)_(2019SLL_Z086)_(N1_L591_BRUN_RAWL).txt | Yes | 61.04 | |
| SUM Case - Z1-086 Dispatched to 1207 MW | (2019SUM_1207_NoBruns_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | Yes | 58.52 | |
| SUM Case - Z1-086 Dispatched to 1376 MW | (2019SUM_1376_NoBruns_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | Yes | 80.04 | |
| | (2019SUM_1376_NoBruns_Z086-CARS_OS)_(19SUM_Z086)_(N1_L591_BRUN_RAWL).txt | Yes | 79.05 | |
| | (2019SUM_1376_NoBruns_Z086-CARS_OS)_(19SUM_Z086_Ed1)_(N1_L591_BRUN_RAWL).txt | Yes | 79.05 | |
| SUM Case - Z1-086 Dispatched to Pmax | (2019SUM_Z-086_NoBruns_BRUNS-RAWL_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | No | 1.47E+05 | ANGL916375[Z1-086_ST 23.000]1 |
| | (2019SUM_Z-086_NoBruns_RAWL-CARS_OS)_(19SUM_Z086)_(N1_L585_GRNS_CRSN).txt | Yes | 91.61 | |
| | (2019SUM_Z-086_NoBruns_RAWL-CARS_OS)_(19SUM_Z086)_(N1_L595_BRUN_GRNS).txt | Yes | 43.83 | |
| | (2019SUM_Z-086_NoBruns_Z086-CARS_OS)_(19SUM_Z086)_(N1_L591_BRUN_RAWL).txt | No | 1.47E+05 | ANGL916375[Z1-086_ST 23.000]1 |